

Appendix 5B-A

Technical Memorandums of Water Management Analysis

The 2021 Plan includes a total of 61 recommended water management strategies (WMS) developed to ensure the East Texas Regional Water Planning Area continues to appropriately plan for water demands for the area's citizens, industries, and communities. Appendix 5B-A provides the required evaluation of each proposed WMS, contained in a technical memorandum for each strategy.

As required, each technical memorandum addresses the following elements:

- Project Description
- Supply Development
- Environmental Considerations
- Permitting and Development
- Planning-Level Opinion of Cost
- Project Evaluation

The planning-level opinion of cost (PLOC) is a critical element of the regional water planning process. The PLOC is important to project prioritization, which is one of a number of considerations in the TWDB's funding evaluation. For the 2021 Plan, PLOCs have been analyzed using the TWDB's costing tool, except where more detailed costs analysis has been provided by the WUG or WWP. In accordance with TWDB Guidance (Exhibit C, First Amended General Guidelines for Regional Water Planning Development – October 2012), the analysis of costs for recommended and alternative WMSs includes capital costs, debt service, and annual operating and maintenance expenses over the planning horizon.

Costs include expenses associated with infrastructure needed to convey water from sources and treat water for end user requirements. Capital costs consist of construction, engineering, contingencies, financial, legal, administration, environmental, permitting and mitigation, land acquisition and easements, and interest on loans. Water transmission lines were assumed to take the shortest route, following existing highways or roads where possible. Profiles were developed using GIS mapping software and USGS topographic maps. Pipes were sized to deliver peak-day flows within reasonable pressure and velocity ranges. Water losses associated with transmission were assumed to be negligible for regional planning purposes.

The annual costs for operation and maintenance infrastructure are generally based on percentages of estimated construction cost of the infrastructure. In addition, purchased water costs, power costs are included.



Technical Memorandum Table of Contents by Entity

1. ANGELINA MANUFACTURING	4
2. ANGELINA MINING.....	7
3. CHEROKEE ALTO RURAL WSC.....	10
4. CHEROKEE RUSK	13
5. CHEROKEE WRIGHT CITY WSC	16
6. CHEROKEE MINING.....	19
7. HENDERSON EDOM WSC	22
8. HENDERSON CHANDLER.....	25
9. HENDERSON MOORE STATION WSC	28
10. HENDERSON MINING	31
11. HOUSTON LIVESTOCK.....	34
12. JASPER LIVESTOCK.....	37
13. JEFFERSON BEAUMONT	40
14. JEFFERSON COUNTY-OTHER.....	43
15. JEFFERSON MANUFACTURING	47
16. JEFFERSON STEAM ELECTRIC POWER	50
17. NACOGDOCHES D&M WSC	53
18. NACOGDOCHES LIVESTOCK.....	56
19. NACOGDOCHES MINING	59
20. NEWTON MINING.....	62
21. ORANGE IRRIGATION.....	65
22. PANOLA LIVESTOCK.....	69
23. RUSK JACOBS WSC	72
24. RUSK LIVESTOCK	75
25. RUSK MINING	78
26. RUSK STEAM ELECTRIC POWER.....	81
27. SAN AUGUSTINE - SAN AUGUSTINE	84
28. SAN AUGUSTINE LIVESTOCK	87
29. SAN AUGUSTINE MINING	90
30. SHELBY SAND HILLS WSC	94
31. SHELBY LIVESTOCK	97
32. SMITH BULLARD.....	100
33. SMITH CRYSTAL SYSTEMS TEXAS, INC.	103



34. SMITH LINDALE.....	106
35. SMITH OVERTON.....	109
36. SMITH RPM WSC.....	112
37. SMITH WHITEHOUSE.....	115
38. SMITH MANUFACTURING.....	118
39. ANRA LAKE COLUMBIA.....	121
40. ANRA WTP.....	127
41. ANRA GW WELLS.....	131
42. ANWCID#1 LAKE STRIKER.....	134
43. ATHENS MWA FISH HATCHERIES.....	136
44. ATHENS MWA ADDITIONAL CARRIZO-WILCOX GROUNDWATER.....	138
45. ATHENS MWA GROUNDWATER SUPPLY EXPANSION.....	141
46. ATHENS MWA PUMP STATION.....	144
47. CITY OF CENTER REUSE PIPELINE.....	147
48. CITY OF CENTER TOLEDO BEND PIPELINE.....	150
49. HOUSTON COUNTY WCID #1 PERMIT AMENDMENT.....	153
50. CITY OF JACKSONVILLE RAW WATER TRANSMISSION.....	155
51. LNVA PURCHASE FROM SRA.....	158
52. LNVA BEAUMONT WEST REGIONAL RESERVOIR.....	161
53. LNVA NECHES-TRINITY BASIN INTERCONNECT.....	164
54. CITY OF LUFKIN.....	167
55. NACOGDOCHES RAW WATER TRANSMISSION.....	173
56. CITY OF PORT ADVANCED CONSERVATION.....	176
57. CITY OF TYLER LAKE PALESTINE EXPANSION.....	178
58. UNRMWA RUN OF RIVER, NECHES WITH LAKE PALESTINE.....	181
59. UNRMWA RUN OF RIVER, NECHES WITH TRIBUTARY STORAGE.....	184
60. UNRMWA RUN OF RIVER, NECHES WITH GROUNDWATER.....	187
61. MUNICIPAL CONSERVATION STRATEGIES.....	190



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR ANGELINA MANUFACTURING**

Water User Group Name:	Angelina - Manufacturing
Strategy Name:	Purchase from Lufkin (Sam Rayburn)
Strategy ID:	ANGL-MFG
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	1,625 ac-ft per year (1.5 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Capital Cost:	\$0
Project Annual Cost:	\$530,000 (Sam Rayburn to Kurth) (September 2018)
Unit Water Cost (Rounded):	\$326 per ac-ft (\$1.00 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Manufacturing in Angelina County and involves a contract between individual manufacturers and the City of Lufkin for raw water from Lake Kurth. Beginning in 2030, the City of Lufkin will begin transferring water from Sam Rayburn Lake to Lake Kurth, making more water available to meet manufacturing demands near Lake Kurth. Since 2011, The City of Lufkin installed a transmission system from Lake Kurth to multiple manufacturing water users. Therefore, the only cost for additional supply from the City of Lufkin is the cost of raw water. Ultimately, this cost will need to be negotiated with the City of Lufkin and will reflect the City's wholesale water rates at that time. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The City of Lufkin currently supplies approximately 3,000 ac-ft per year to meet manufacturing demands in Angelina County. The quantity of supply from this strategy represents a contract increase of 1,449 ac-ft per year, beginning in 2020, and increases to 1,625 ac-ft per year, beginning in 2030. The supply available in 2020 is limited by the available supply of Lake Kurth to the City of Lufkin. In 2030 through 2070, the supply is limited to the manufacturing need projected by the East Texas Regional Water Planning Group. These supplies are considered highly reliable.

ENVIRONMENTAL CONSIDERATIONS

There are not any significant environmental considerations associated with this strategy. A contract between manufacturers and the City of Lufkin should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries in close proximity to Lake Kurth.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. No capital costs were assumed, but an annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUGNAME:	Angelina Manufacturing			
STRATEGY:	Purchase from Lufkin			
Raw Water				
Quantity:	1,625	AF/Y	2.17	MGD
Treated Water				
Quantity:	0	AF/Y	0.00	MGD
CONSTRUCTION COSTS				
ANNUAL CONTRACT COSTS		Size	Quantity	Unit
Operational Costs*			530,000	1000 gal
				\$530,000
ANNUAL COSTS				
Total Annual Costs				\$530,000
UNIT COSTS (Until Amortized)				
Per Acre-Foot of water				\$326
Per 1,000 Gallons				\$1.00
UNIT COSTS (After Amortization)				
Per Acre-Foot				NA
Per 1,000 Gallons				NA

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits manufacturers in Angelina County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from Lake Kurth will reduce demands on other water supplies in Angelina County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Angelina Manufacturing recommended strategy to purchase water from the City of Lufkin was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.



Criteria	Rating	Explanation
Quantity	4	1,625 ac-ft per year
Reliability	5	Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsor unknown
Implementation Issues	4	No known risks

REFERENCES

2016 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR ANGELINA MINING**

Water User Group Name:	Angelina - Mining
Strategy Name:	Purchase from Angelina Neches River Authority (Run of River, Angelina)
Strategy ID:	ANGL-MIN
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	572 ac-ft per year (0.5 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$7,927,000 (September 2018)
Annual Cost:	\$1,245,000
Unit Water Cost (Rounded):	\$2,177 per ac-ft (\$6.68 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Mining in Angelina County and involves a contract between individual mining water users and the Angelina Neches River Authority for raw water from the Angelina River as their permit allows. The cost for supply from the Angelina River includes the cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Angelina Neches River Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the mining need projected in Angelina County by the East Texas Regional Water Planning Group. The reliability of this water supply is considered medium due to the availability of water projected in the Angelina River using the Texas Water Development Board's Water Availability Models. However, this strategy is dependent on sales with the Angelina Neches River Authority and their application for 10,000 ac-ft per year from the Angelina River (Strategy ID: ANRA-ROR). The quantity of supply from this strategy represents a contract of 473 ac-ft per year, beginning in 2020, and increase to 572 ac-ft per year in 2030, and decreases to 167 ac-ft per year, beginning in 2070. In 2030 through 2070, the supply is limited to the mining need projected by the East Texas Regional Water Planning Group.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between mining water users in Angelina County and the Angelina Neches River Authority should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries in close proximity Angelina County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 6 miles of pipeline (the approximate distance from the Angelina River to the center of Angelina County), a pump station with an intake, a booster pump station, and one terminal storage tank with one day of storage. The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required.

WUG NAME:	Angelina Mining				
STRATEGY:	Purchase from ANRA (Angelina River)				
Quantity:	57				
CAPITAL COSTS	2 AF/Y		0.77		MGD
Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	8 in.	31,680	LF	\$40	\$1,257,787
Right of Way Easements Rural (ROW)		31,680	LF	\$18	\$578,970
Land and Surveying (10%)					\$58,000
Engineering and Contingencies (30%)					\$377,000
Subtotal of Pipeline	6	miles			\$2,271,757
Pump Station(s)					
Pump with intake	53 HP	1	LS	\$3,547,000	\$3,547,000
Booster Pump Station		0	LS		
Engineering and Contingencies (35%)					\$1,241,000
Subtotal of Pump Station(s)					\$4,788,000
Storage Tanks	0.10 MG	1	LS	\$430,669	\$430,669
Engineering and Contingencies (35%)					\$151,000
Subtotal of Storage Tanks					\$581,669
Permitting and Mitigation					\$178,000
Interest During Construction			6	Months	\$100,000
TOTAL COST					\$7,927,000
ANNUAL COSTS					
Debt Service (3.5% for 20 years)					\$558,000
Operational Costs*					\$687,000
Total Annual Costs					\$1,245,000
UNIT COSTS (Until Amortized)					
Per Acre-Foot of treated water					\$2,177
Per 1,000 Gallons					\$6.68
UNIT COSTS (After Amortization)					
Per Acre-Foot					\$1,201
Per 1,000 Gallons					\$3.69



* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits mining users in Angelina County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Angelina River will reduce demands on other water supplies in Angelina County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Angelina Mining recommended strategy to purchase water from the Angelina Neches River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	572 ac-ft per year
Reliability	3	Moderate Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsor unknown
Implementation Issues	4	No known risks

REFERENCES

2016 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR CHEROKEE ALTO RURAL WSC**

Water User Group Name:	Cherokee County - Alto Rural WSC
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	CHER-ALT
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	191 ac-ft per year (0.2 MGD)
Implementation Decade:	2050
Development Timeline:	2050
Project Capital Cost:	\$2,426,000 (September 2018)
Annual Cost:	\$202,000
Unit Water Cost (Rounded):	\$1,058 per ac-ft (\$3.25 per 1,000 gallons)

PROJECT DESCRIPTION

Alto Rural WSC is a municipal water user in Cherokee County. This water user currently relies on groundwater in the Carrizo Wilcox aquifer in Cherokee County. Alto Rural WSC has a small need starting in 2050 and the maximum need is approximately 215 ac-ft per year. To meet this need, it is recommended that Alto Rural WSC continue to use supplies from Carrizo Wilcox by drilling additional wells. This strategy is a recommended strategy for Alto Rural WSC in Cherokee County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Cherokee County. The wells will provide approximately 191 ac-ft per year and are assumed to have a depth of 800 feet. A peaking factor of two was assumed for the well, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply is required only in the later part of the planning cycle, for decades 2050 to 2070. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Cherokee County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that the wells will provide sufficient acre feet per year to meet Alto Rural WSC's needs in Cherokee County providing a total yield required for the strategy. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Cherokee County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 1.2 miles of pipeline, two wells, a peaking factor of two, and a maximum well yield of 250 gpm for each well. This equates to \$1,058 per acre-foot (\$3.25 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$162 per acre-foot (\$0.50 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

**WUG: Cherokee County Alto Rural WSC
 STRATEGY: Cherokee County - GW Wells**

	Supply	191	Acre-feet	
	Well Depth	800	per year	118 gpm
	Wells Needed	2	ft	

CAPITAL COST

Transmission Pipeline (6 in dia., 1.2 miles)	\$161,000
Primary Pump Stations (0.2 MGD)	\$417,000
Well Fields (Wells, Pumps, and Piping)	\$1,113,000
TOTAL COST OF FACILITIES	\$1,691,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$583,000
Environmental & Archaeology Studies and Mitigation	\$59,000
Land Acquisition and Surveying (6 acres)	\$28,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	<u>\$65,000</u>
TOTAL COST OF PROJECT	\$2,426,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$171,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$13,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$10,000
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (95483 kW-hr @ 0.08 \$/kW-hr)	\$8,000
Purchase of Water (acft/yr @ \$/acft)	<u>\$0</u>
TOTAL ANNUAL COST	\$202,000

Available Project Yield (acft/yr)	191
Annual Cost of Water (\$ per acft), based on PF=1.2	\$1,058
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1.2	\$162
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1.2	\$3.25
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1.2	\$0.50

PROJECT EVALUATION

This strategy benefits municipal user Alto Rural WSC in Cherokee County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. New wells in the county will reduce demands on other



water supplies in Cherokee County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the recommended strategy to drill new wells in Cherokee County for Alto Rural WSC's use was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	191 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	2	Moderate to High Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	Local Sponsorship by Alto Rural WSC
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR CHEROKEE RUSK**

Water User Group Name:	Cherokee - Rusk
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	CHER-RUS
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	122 ac-ft per year (0.11 MGD)
Implementation Decade:	2070
Development Timeline:	2070
Project Capital Cost:	\$2,361,000 (September 2018)
Annual Cost:	\$192,000
Unit Water Cost (Rounded):	\$1,574 per ac-ft (\$4.83 per 1,000 gallons)

PROJECT DESCRIPTION

Rusk is a municipal water user in Cherokee County. This water user currently relies on groundwater in the Carrizo Wilcox aquifer in Cherokee County. Rusk has a small need starting in 2070 of approximately 122 ac-ft per year. To meet this need, it is recommended that Rusk continue to use supplies from Carrizo Wilcox by drilling additional wells. This strategy is a recommended strategy for Rusk in Cherokee County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Cherokee County. The wells will provide approximately 122 ac-ft per year and are assumed to have a depth of 800 feet. A peaking factor of two was assumed for the well, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply is required only in the later part of the planning cycle, for the decade of 2070. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Cherokee County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that the wells will provide sufficient acre feet per year to meet Rusk's needs in Cherokee County providing a total yield required for the strategy. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Cherokee County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 1 mile of pipeline, two wells, a peaking factor of two, and a maximum well yield of 250 gpm for each well. This equates to \$1,574 per acre-foot (\$4.83 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$213 per acre-foot (\$0.65 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Cherokee County - Rusk

STRATEGY: New wells - Carrizo Aquifer Wells

Supply	122	Acre-feet per year	62	gpm
Well Depth	800	ft		
Wells Needed	2			

CAPITAL COST

Transmission Pipeline (6 in dia., 1 miles)	\$134,000
Primary Pump Stations (0.2 MGD)	\$399,000
Well Fields (Wells, Pumps, and Piping)	\$1,113,000
	\$1,646,000

TOTAL COST OF FACILITIES

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$569,000
Environmental & Archaeology Studies and Mitigation	\$54,000
Land Acquisition and Surveying (6 acres)	\$28,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	\$64,000
	\$2,361,000

TOTAL COST OF PROJECT

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$166,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$12,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$10,000
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (55507 kW-hr @ 0.08 \$/kW-hr)	\$4,000
Purchase of Water (acft/yr @ \$/acft)	\$0
	\$192,000

Available Project Yield (acft/yr)	122
Annual Cost of Water (\$ per acft), based on PF=1.2	\$1,574
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1.2	\$213
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1.2	\$4.83
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1.2	\$0.65

PROJECT EVALUATION

This strategy benefits municipal users in Cherokee County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources



or to key parameters of water quality. Developing groundwater supplies in Cherokee County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Cherokee County Rusk WUG recommended strategy to develop new wells in Carrizo Wilcox was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	122 ac-ft per year
Reliability	4	Medium Reliable Supply
Cost	2	Moderate to High Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	Sponsor identified
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR CHEROKEE WRIGHT CITY WSC**

Water User Group Name:	Cherokee - Wright City WSC
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	CHER-WCW
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	25 - 121 ac-ft per year (Varies) (0.02 – 0.11 MGD)
Implementation Decade:	2050
Development Timeline:	2050
Project Capital Cost:	\$2,361,000 (September 2018)
Annual Cost:	\$192,000
Unit Water Cost (Rounded):	\$1,574 per ac-ft (\$4.83 per 1,000 gallons)

PROJECT DESCRIPTION

Wright City WSC is a municipal water user in Cherokee and Rusk Counties. This water user currently relies on groundwater in the Carrizo Wilcox aquifer in Cherokee County. Wright City has a small need starting in 2050 of approximately 25 ac-ft per year, and increases to 121 ac-ft per year in 2070. To meet this need, it is recommended that Wright City WSC continue to use supplies from Carrizo Wilcox by drilling additional wells. This strategy is a recommended strategy for Rusk in Cherokee County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Cherokee County. The wells will provide approximately 122 ac-ft per year and are assumed to have a depth of 800 feet. A peaking factor of two was assumed for the well, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply is required only in the later part of the planning cycle, for the decades 2050 through 2070. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Cherokee County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that the wells will provide sufficient acre feet per year to meet Rusk's needs in Cherokee County providing a total yield required for the strategy. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Cherokee County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 1 mile of pipeline, two wells, a peaking factor of two, and a maximum well yield of 250 gpm for each well. This equates to \$1,574 per acre-foot (\$4.83 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$213 per acre-foot (\$0.65 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Cherokee County – Wright City WSC
STRATEGY: New wells - Carrizo Aquifer Wells

	Supply	122	Acre-feet per year	62	gpm
	Well Depth	800	ft		
	Wells Needed	2			
CAPITAL COST					
Transmission Pipeline (6 in dia., 1 miles)					\$134,000
Primary Pump Stations (0.2 MGD)					\$399,000
Well Fields (Wells, Pumps, and Piping)					\$1,113,000
					\$1,646,000
TOTAL COST OF FACILITIES					
					0
Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)					
					\$569,000
Environmental & Archaeology Studies and Mitigation					\$54,000
Land Acquisition and Surveying (6 acres)					\$28,000
Interest During Construction (3% for 1 years with a 0.5% ROI)					\$64,000
					\$2,361,000
TOTAL COST OF PROJECT					
0					
ANNUAL COST					
Debt Service (3.5 percent, 20 years)					\$166,000
Reservoir Debt Service (3.5 percent, 40 years)					\$0
Operation and Maintenance					
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)					\$12,000
Intakes and Pump Stations (2.5% of Cost of Facilities)					\$10,000
Dam and Reservoir (1.5% of Cost of Facilities)					\$0
Water Treatment Plant					\$0
Advanced Water Treatment Facility					\$0
Pumping Energy Costs (55507 kW-hr @ 0.08 \$/kW-hr)					\$4,000
Purchase of Water (acft/yr @ \$/acft)					\$0
TOTAL ANNUAL COST					\$192,000
Available Project Yield (acft/yr)					122
Annual Cost of Water (\$ per acft), based on PF=1.2					\$1,574
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1.2					\$213
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1.2					\$4.83
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1.2					\$0.65

PROJECT EVALUATION

This strategy benefits mining users in Cherokee County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to



key parameters of water quality. Developing new wells in Carrizo Wilcox in Cherokee County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Cherokee County Wright City WSC WUG recommended strategy to develop new wells in Carrizo Wilcox was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	121 ac-ft per year
Reliability	4	Medium Reliable Supply
Cost	3	Moderate Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	Sponsor identified
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR CHEROKEE MINING**

Water User Group Name:	Cherokee - Mining
Strategy Name:	Purchase from Angelina Neches River Authority (Angelina River)
Strategy ID:	CHER-MIN
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	247 – 40 ac-ft per year (Varies) (0.2 – 0.03 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$7,013,000 (September 2018)
Annual Cost:	\$853,000
Unit Water Cost (Rounded):	\$3,453 per ac-ft (\$10.60 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Mining in Cherokee County and involves a contract between individual mining water users and the Angelina Neches River Authority for raw water from the Angelina River as their permit allows. The cost for supply from the Angelina River includes the cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Angelina Neches River Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the mining need projected in Angelina County by the East Texas Regional Water Planning Group. The reliability of this water supply is considered medium due to the availability of water projected in the Angelina River using the Texas Water Development Board’s Water Availability Models. However, this strategy is dependent on sales with the Angelina Neches River Authority and their application for 30,000 ac-ft per year from the Angelina River (Strategy ID: ANGL-ROR). The quantity of supply from this strategy represents a contract of 238 ac-ft per year, beginning in 2020, and decreases to 40 ac-ft per year, beginning in 2070. In 2030 through 2070, the supply is limited to the mining need projected by the East Texas Regional Water Planning Group.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between mining water users in Cherokee County and the Angelina Neches River Authority should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries in close proximity Cherokee County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 7 miles of pipeline (the approximate distance from the Angelina River to the center of Cherokee County), a pump station with an intake, and one terminal storage tank with 0.2 MG of storage. The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required.

WUG	Cherokee Mining	
STRATEGY:	Purchase from ANRA (Angelina River)	
Quantity:	247 AF/Y	0.33 MGD

CAPITAL COSTS

	Size	Quantity	Unit	Unit Price	Cost
Pipeline					
Pipeline Rural	6 in.	36,960	LF	\$25	\$939,000
Right of Way Easements Rural (ROW)		36,960	LF	\$18	\$675,000
Land and Surveying (10%)					\$68,000
Engineering and Contingencies (30%)					\$282,000
Subtotal of Pipeline	7	miles			\$1,964,000
Pump Station(s)					
Pump with intake	23 HP	1	LS	\$3,048,869	\$3,049,000
Engineering and Contingencies (35%)					\$1,067,000
Subtotal of Pump Station(s)					\$4,116,000
Storage Tanks	0.20 MG	1	LS	\$470,060	\$470,000
Engineering and Contingencies (35%)					\$164,500
Subtotal of Storage Tanks					\$634,500
Permitting and Mitigation					\$203,000
Debt Service (3.5% for 20 years)					\$6,918,000
Interest During Construction			6	Months	\$95,000
TOTAL COST					\$7,013,000

ANNUAL COSTS

Debt Service (3.5% for 20 years)	\$493,000
Operational Costs*	\$360,000
Total Annual Costs	\$853,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water **\$3,453**

Per 1,000 Gallons **\$10.60**

UNIT COSTS (After Amortization)

Per Acre-Foot **\$1,457**

Per 1,000 Gallons **\$4.47**

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.



PROJECT EVALUATION

This strategy benefits mining users in Cherokee County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Angelina River will reduce demands on other water supplies in Cherokee County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Cherokee Mining recommended strategy to purchase water from the Angelina Neches River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	247 ac-ft per year
Reliability	4	Medium Reliable Supply
Cost	2	Moderate to High Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	Sponsor identified
Implementation Issues	4	No known risks

REFERENCES

Discussions with Angelina Neches River Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR HENDERSON EDM WSC**

Water User Group Name:	Henderson County – EDM WSC
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	HDSN- EDM
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	2 - 9 ac-ft per year (varies) (0.002 - 0.01 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$1,088,000 (September 2018)
Annual Cost:	\$136,000
Unit Water Cost (Rounded):	\$2,125 per ac-ft (\$6.52 per 1,000 gallons)

PROJECT DESCRIPTION

Edom WSC provides water service in Van Zandt and Henderson Counties. The WUG population is projected to be 1,395 by 2020 and increases to 2,025 by 2070. Edom WSC supplies its customers with groundwater from the Carrizo-Wilcox aquifer with water wells in Van Zandt County. Edom WSC is projected to have a total deficit of 13 ac-ft/yr in 2020 and increasing to a deficit of 64 ac-ft/yr by 2070; the shortage projected to occur in Van Zandt County is 11 ac-ft/yr in 2020 increasing to 55 ac-ft/yr by 2070. The shortage in Henderson County is 2 ac-ft/yr in 2020, increasing to 9 ac-ft/yr in 2070.

SUPPLY DEVELOPMENT

There are sufficient supplies available in the Henderson County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that the wells will provide sufficient acre feet per year to meet Edom WSC's needs in Henderson County providing a total yield required for the strategy. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Henderson County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital cost includes wells, pumps and piping. This equates to \$2,125 per acre-foot (\$6.52 per 1,000 gallons); after the



infrastructure is fully paid (30 years), the cost drops to \$922 per acre-foot (\$2.83 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Henderson County – EDOM WSC
WMS: New wells in Carrizo-Wilcox Aquifer

	Supply Well Depth	64 560	Ac-ft/yr
Well Fields (Wells, Pumps, and Piping)			\$715,000
Water Treatment Plant (0.2 MGD)			\$28,000
TOTAL COST OF FACILITIES			\$743,000
Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)			\$260,000
Environmental & Archaeology Studies and Mitigation			\$36,000
Land Acquisition and Surveying (3 acres)			\$19,000
Interest During Construction (3% for 1 years with a 0.5% ROI)			<u>\$30,000</u>
TOTAL COST OF PROJECT			\$1,088,000
ANNUAL COST			
Debt Service (3.5 percent, 20 years)			\$77,000
Operation and Maintenance			
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)			\$7,000
Intakes and Pump Stations (2.5% of Cost of Facilities)			\$0
Dam and Reservoir (1.5% of Cost of Facilities)			\$0
Water Treatment Plant			\$17,000
Advanced Water Treatment Facility			\$0
Pumping Energy Costs (41446 kW-hr @ 0.08 \$/kW-hr)			\$3,000
Purchase of Water (64 acft/yr @ 500 \$/acft)			<u>\$32,000</u>
TOTAL ANNUAL COST			\$136,000
Available Project Yield (acft/yr)			64
Annual Cost of Water (\$ per acft), based on PF=1			\$2,125
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1			\$922
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1			\$6.52
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1			\$2.83



PROJECT EVALUATION

This strategy benefits municipal water users in Henderson County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Edom WSC recommended strategy to develop new Groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	9 ac-ft per year
Reliability	4	Reliable Supply
Cost	2	High Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	Local Sponsorship by Edom WSC
Implementation Issues	4	No known risks

REFERENCES

Discussions with Region D.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR HENDERSON CHANDLER**

Water User Group Name:	Henderson County – City of Chandler
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	HDSN-CHN
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	101 ac-ft per year (0.1 MGD)
Implementation Decade:	2070
Development Timeline:	2070
Project Capital Cost:	\$1,397,000 (September 2018)
Annual Cost:	\$113,000
Unit Water Cost (Rounded):	\$1,119 per ac-ft (\$3.43 per 1,000 gallons)

PROJECT DESCRIPTION

The City of Chandler is a municipal water user in Henderson County. The City currently relies on groundwater in the Carrizo Wilcox aquifer in Henderson County. The City has a small need starting in 2070 of approximately 118 ac-ft per year. To meet this need, it is recommended that the City of Chandler continue to use supplies from Carrizo Wilcox by drilling additional wells. This strategy is a recommended strategy for the City of Chandler in Henderson County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Henderson County. The wells will provide approximately 101 ac-ft per year and are assumed to have a depth of 700 feet. A peaking factor of two was assumed for the well, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply is required only in the later part of the planning cycle, for the decade of 2070. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Henderson County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that the wells along with municipal conservation will provide sufficient acre feet per year to meet the City's needs in Henderson County. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Henderson County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 1 mile of pipeline, two wells, a peaking factor of two, and a maximum well yield of 100 gpm for each well. This equates to \$1,119 per acre-foot (\$3.43 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$149 per acre-foot (\$0.46 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Henderson County – City of Chandler
WMS: New wells in Carrizo-Wilcox Aquifer

Supply	101	Ac-ft/yr	63	gpm
Well Depth	700			
Wells Needed	2			

CAPITAL COST

Transmission Pipeline (6 in dia., 1 miles)	\$134,000
Primary Pump Stations (0.1 MGD)	\$180,000
Well Fields (Wells, Pumps, and Piping)	\$637,000
	\$951,000

TOTAL COST OF FACILITIES

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$326,000
Environmental & Archaeology Studies and Mitigation	\$54,000
Land Acquisition and Surveying (6 acres)	\$28,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	<u>\$38,000</u>
	\$1,397,000

TOTAL COST OF PROJECT

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$98,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$8,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$4,000
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (32509 kW-hr @ 0.08 \$/kW-hr)	\$3,000
Purchase of Water (acft/yr @ \$/acft)	<u>\$0</u>
	\$113,000

TOTAL ANNUAL COST

Available Project Yield (acft/yr)	101
Annual Cost of Water (\$ per acft), based on PF=1	\$1,119
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1	\$149
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1	\$3.43
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1	\$0.46



PROJECT EVALUATION

This strategy benefits municipal water users in Henderson County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the City of Chandler recommended strategy to develop new wells in Carrizo Wilcox was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	101 ac-ft per year
Reliability	4	Reliable Supply
Cost	2	Medium to High Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	Local Sponsorship by City of Chandler
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR HENDERSON MOORE STATION WSC**

Water User Group Name:	Henderson County – Moore Station WSC
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	HDSN-MSW
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	38 - 111 ac-ft per year (Varies) (0.03 - 0.1 MGD)
Implementation Decade:	2060
Development Timeline:	2060
Project Capital Cost:	\$1,417,000 (September 2018)
Annual Cost:	\$116,000
Unit Water Cost (Rounded):	\$1,045 per ac-ft (\$3.21 per 1,000 gallons)

PROJECT DESCRIPTION

Moore Station WSC is a municipal water user in Henderson County. Moore Station WSC currently relies on groundwater in the Carrizo Wilcox aquifer in Henderson County. This water user has a small need starting in 2060 of approximately 38 ac-ft per year, and increases to 111 ac-ft per year beginning in 2070. To meet this need, it is recommended that Moore Station WSC continue to use supplies from Carrizo Wilcox by drilling additional wells. This strategy is a recommended strategy for Moore Station WSC in Henderson County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Henderson County. The wells will provide approximately 111 ac-ft per year and are assumed to have a depth of 700 feet. A peaking factor of two was assumed for the well, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply is required only in the later part of the planning cycle, for decades 2060 through 2070. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Henderson County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that the wells will provide sufficient acre feet per year to meet the City's needs in Henderson County. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Henderson County.



PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 1 mile of pipeline, two wells, a peaking factor of two, and a maximum well yield of 100 gpm for each well. This equates to \$1,045 per acre-foot (\$3.21 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$144 per acre-foot (\$0.44 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Henderson County – Moore Station WSC

WMS: New wells in Carrizo-Wilcox Aquifer

Supply	111	Ac-ft/yr	69	gpm
Well Depth	700			
Wells Needed	2			

CAPITAL COST

Transmission Pipeline (6 in dia., 1 miles)	\$134,000
Primary Pump Stations (0.1 MGD)	\$195,000
Well Fields (Wells, Pumps, and Piping)	\$637,000
TOTAL COST OF FACILITIES	\$966,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$331,000
Environmental & Archaeology Studies and Mitigation	\$54,000
Land Acquisition and Surveying (6 acres)	\$28,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	<u>\$38,000</u>
TOTAL COST OF PROJECT	\$1,417,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$100,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$8,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$5,000
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (35811 kW-hr @ 0.08 \$/kW-hr)	\$3,000
Purchase of Water (acft/yr @ \$/acft)	<u>\$0</u>
TOTAL ANNUAL COST	\$116,000

Available Project Yield (acft/yr)	111
Annual Cost of Water (\$ per acft), based on PF=1	\$1,045
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1	\$144
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1	\$3.21
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1	\$0.44



PROJECT EVALUATION

This strategy benefits municipal water users in Henderson County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Moore Station WSC recommended strategy to develop new groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	111 ac-ft per year
Reliability	4	Reliable Supply
Cost	2	Medium to High Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	Local Sponsorship by Moore Station WSC
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR HENDERSON MINING**

Water User Group Name:	Henderson County – Mining
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	HDSN-MIN
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	10 - 19 ac-ft per year (Varies) (0.01 - 0.02 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$201,000 (September 2018)
Annual Cost:	\$15,000
Unit Water Cost (Rounded):	\$789 per ac-ft (\$2.42 per 1,000 gallons)

PROJECT DESCRIPTION

Mining users in Henderson County show a projected need in the early decades of the planning cycle. To meet this need, it is recommended that mining users utilize additional supplies from Carrizo Wilcox by drilling additional wells. This strategy is a recommended strategy for mining users in Henderson County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Henderson County. The wells will provide approximately 19 ac-ft per year and are assumed to have a depth of 200 feet. A peaking factor of two was assumed for the wells.

SUPPLY DEVELOPMENT

The supply is required only in the early part of the planning cycle, for decades 2020 through 2040. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Henderson County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that the wells will provide sufficient acre feet per year to meet the City's needs in Henderson County. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Henderson County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed two wells, a peaking factor of two, and a maximum well yield of 50 gpm for each well. This equates to \$789 per acre-foot (\$2.42 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$53 per acre-foot (\$0.16 per 1,000 gallons). Overall, this strategy has a low cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Henderson County – Mining

WMS: New wells in Carrizo-Wilcox Aquifer

Supply	19	Ac-ft/yr	12	gpm
Well Depth	200			
Wells Needed	2			

CAPITAL COST

Well Fields (Wells, Pumps, and Piping)	\$135,000
TOTAL COST OF FACILITIES	\$135,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$47,000
Environmental & Archaeology Studies and Mitigation	\$8,000
Land Acquisition and Surveying (1 acres)	\$5,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	<u>\$6,000</u>
TOTAL COST OF PROJECT	\$201,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$14,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$1,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$0
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (5038 kW-hr @ 0.08 \$/kW-hr)	\$0
Purchase of Water (acft/yr @ \$/acft)	<u>\$0</u>
TOTAL ANNUAL COST	\$15,000

Available Project Yield (acft/yr)	19
Annual Cost of Water (\$ per acft), based on PF=1	\$789
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1	\$53
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1	\$2.42
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1	\$0.16



PROJECT EVALUATION

This strategy benefits municipal water users in Henderson County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Henderson County Mining recommended strategy to develop new groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	19 ac-ft per year
Reliability	4	Reliable Supply
Cost	3	Medium Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Sponsorship Unknown
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR HOUSTON LIVESTOCK**

Water User Group Name:	Houston - Livestock
Strategy Name:	New wells in Yegua-Jackson
Strategy ID:	HOUS-LTK
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	201 ac-ft per year (0.2 MGD)
Implementation Decade:	2070
Development Timeline:	2070
Project Capital Cost:	\$399,000 (September 2018)
Annual Cost:	\$39,000
Unit Water Cost (Rounded):	\$194 per ac-ft (\$0.60 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Livestock in Houston County and involves the development of four wells located within the Yegua-Jackson Aquifer as this aquifer has been identified as a potential source of water in Houston County. These wells will provide approximately 201 ac-ft per year and are assumed to have a depth of 200 feet. A peaking factor of two was assumed for the wells, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

It is assumed that each well will provide 50 ac-ft per year to meet livestock demands in Houston County providing a total strategy yield of 201 ac-ft per year beginning in 2070. A target yield for this strategy was set to the highest need projected by the East Texas Regional Water Planning Group; the highest need occurs in 2070. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Houston County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed four wells, a peaking factor of two, and a maximum well yield of 50 gpm for each well. This



equates to \$194 per acre-foot (\$0.60 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$55 per acre-foot (\$0.17 per 1,000 gallons). Overall, this strategy has a low cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Houston County - Livestock

Strategy: New wells - Yegua-Jackson

Supply	201	Ac-ft/yr	125 gpm
Well Depth	200		
Wells Needed	4		

CAPITAL COST

Well Fields (Wells, Pumps, and Piping)	\$270,000
TOTAL COST OF FACILITIES	\$270,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$94,000
Environmental & Archaeology Studies and Mitigation	\$15,000
Land Acquisition and Surveying (2 acres)	\$9,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	<u>\$11,000</u>
TOTAL COST OF PROJECT	\$399,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$28,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$3,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$0
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (100751 kW-hr @ 0.08 \$/kW-hr)	\$8,000
Purchase of Water (acft/yr @ \$/acft)	<u>\$0</u>
TOTAL ANNUAL COST	\$39,000

Available Project Yield (acft/yr)	201
Annual Cost of Water (\$ per acft), based on PF=1	\$194
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1	\$55
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1	\$0.60
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1	\$0.17

PROJECT EVALUATION

This strategy benefits livestock users in Houston County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. New wells in the county will reduce demands on other water supplies in Houston County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the recommended strategy to drill new wells in Houston County for livestock use was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results



of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	201 ac-ft per year
Reliability	4	Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low to Medium Impacts
Impact on Other State Water Resources	4	No Known Impacts.
Threat to Agricultural Resources/Rural Areas	5	No Impacts to Rural Areas. Positively benefits Agricultural Resources.
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsorship unknown
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR JASPER LIVESTOCK**

Water User Group Name:	Jasper - Livestock
Strategy Name:	New wells in Gulf Coast
Strategy ID:	JASP-LTK
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	8,932 ac-ft per year (8 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$14,026,000 (September 2018)
Annual Cost:	\$1,686,000
Unit Water Cost (Rounded):	\$189 per ac-ft (\$0.58 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Livestock in Jasper County and involves the development of 65 wells located within the Gulf Coast Aquifer as this aquifer has been identified as a potential source of water in Jasper County. These wells will provide approximately 8,932 ac-ft per year and are assumed to have a depth of 400 feet. A peaking factor of two was assumed for the wells.

SUPPLY DEVELOPMENT

It is assumed that each well will provide approximately 140 ac-ft per year to meet livestock water demands in Jasper County providing a total strategy yield of 8,932 ac-ft per year beginning in 2020. A target yield for this strategy was set to the highest need projected by the East Texas Regional Water Planning Group; the highest need occurs in 2020 and continuing throughout the planning cycle. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Jasper County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 65 wells, a peaking factor of two, and a maximum well yield of 100 gpm for each well. This equates to \$189 per acre-foot (\$0.58 per 1,000 gallons); after the infrastructure is fully paid (30 years),



the cost drops to \$78 per acre-foot (\$0.24 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Jasper - Livestock

WMS: New wells in Gulf Coast

Supply	8,932	Ac-ft/yr		5,538	gpm
Well Depth	400				
Wells Needed	65				

CAPITAL COST

Well Fields (Wells, Pumps, and Piping)	\$9,813,000
TOTAL COST OF FACILITIES	\$9,813,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$3,434,000
Environmental & Archaeology Studies and Mitigation	\$249,000
Land Acquisition and Surveying (33 acres)	\$154,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	\$376,000
TOTAL COST OF PROJECT	\$14,026,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$987,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$98,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$0
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (7510211 kW-hr @ 0.08 \$/kW-hr)	\$601,000
Purchase of Water (acft/yr @ \$/acft)	\$0
TOTAL ANNUAL COST	\$1,686,000

Available Project Yield (acft/yr)	8,932
Annual Cost of Water (\$ per acft), based on PF=1	\$189
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1	\$78
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1	\$0.58
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1	\$0.24

PROJECT EVALUATION

This strategy benefits livestock users in Jasper County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. Developing new groundwater wells Jasper County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Jasper Livestock recommended strategy to develop new groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.



Criteria	Rating	Explanation
Quantity	4	8,932 ac-ft per year
Reliability	4	Reliable Supply
Cost	4	Low to Medium Cost
Environmental Factors	4	Low to Medium Impacts
Impact on Other State Water Resources	4	No Known Impacts
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsorship unknown
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR JEFFERSON BEAUMONT**

Water User Group Name:	Jefferson - Beaumont
Strategy Name:	Amendment to Supplemental Contract with LNVA
Strategy ID:	JEFF-BEA
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	54 – 2,249 ac-ft per year (0.05 – 2.01 MGD)
Implementation Decade:	2040
Development Timeline:	2040
Project Capital Cost:	\$ 0 (September 2018)
Annual Cost:	\$ 2,199,000
Unit Water Cost (Rounded):	\$977 per ac-ft (\$3.00 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for the City of Beaumont in Jefferson County and involves an amendment to an existing supplement contract between the City and the Lower Neches Valley Authority for additional water supply. Beginning in 2040, the City of Beaumont will have an additional need of 1,248 ac-ft per year. The City's need increases each decade of the planning cycle, with a maximum need of 9,218 ac-ft per year in 2070. The City of Beaumont already has in place existing infrastructure and transmission lines for their existing supply from the Lower Neches Valley Authority. Therefore, the only cost for additional supply from the Lower Neches Valley Authority is the cost of raw water. Ultimately, this cost will need to be negotiated with the Lower Neches Valley Authority and will reflect the City's wholesale water rates at that time. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The Lower Neches Valley Authority currently supplies approximately 3,000 ac-ft per year to meet the City of Beaumont's demands in Jefferson County. The quantity of supply from this strategy represents a contract increase of 1,248 ac-ft per year, beginning in 2040, and increases to 9,218 ac-ft per year, beginning in 2070. In 2040 through 2070, the supply is limited to the municipal need projected by the East Texas Regional Water Planning Group. These supplies are considered highly reliable.

ENVIRONMENTAL CONSIDERATIONS

There are not any significant environmental considerations associated with this strategy. A contract between the City of Beaumont and the Lower Neches Valley Authority should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. As there is no new infrastructure required for this strategy, there will be no impacts to bays or estuaries in close proximity to the City of Beaumont.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST.

A planning level opinion of cost (PLOC) for this strategy is included in the table below. No capital costs were assumed, but an annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG STRATEGY:	City of Beaumont Amendment to Supplemental Contract with LNVA	
		3.01
Raw Water Quantity:	2,249 AF/Y	MGD
CONSTRUCTION COSTS		
ANNUAL CONTRACT COSTS		
ANNUAL COSTS		
Operational Costs*		\$2,199,000
UNIT COSTS (Until Amortized)		
Per Acre-Foot of treated water		\$978
Per 1,000 Gallons		\$3.00
UNIT COSTS (After Amortization)		
Per Acre-Foot		NA
Per 1,000 Gallons		NA

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits municipal users in Jefferson County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from Sam Rayburn will reduce demands on other water supplies in Jefferson County and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the Jefferson Beaumont recommended strategy to purchase water from the Lower Neches Valley Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	2,249 ac-ft per year
Reliability	4	Reliable Supply
Cost	3	Medium Cost

Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No Known Impacts.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	City of Beaumont
Implementation Issues	4	No known risks

REFERENCES

2016 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR JEFFERSON COUNTY-OTHER**

Water User Group Name:	Jefferson County-Other
Strategy Name:	Purchase from Lower Neches Valley Authority (Sam Rayburn)
Strategy ID:	JEFF-CTR
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	855 – 1,950 ac-ft per year (0.8 – 1.7 MGD)
Implementation Decade:	2060
Development Timeline:	2060
Project Capital Cost:	\$21,665,000 (September 2018)
Annual Cost:	\$2,402,000
Unit Water Cost (Rounded):	\$1,232 per ac-ft (\$3.78 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for County-Other in Jefferson County and involves a contract between individual municipal water users and the Lower Neches Valley Authority for raw water from Sam Rayburn, as their permit allows. The cost for supply from Sam Rayburn includes the contractual cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Lower Neches Valley Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water need projected for County-Other in Jefferson County by the East Texas Regional Planning Group during the planning period (2020-2070). The quantity of supply from this strategy represents a contract of 855 ac-ft per year, beginning in 2060, and increases over time to 1,950 ac-ft per year, beginning in 2070. The reliability of this water supply is considered high due to the availability of water projected in Sam Rayburn using the Texas Water Development Board's Water Availability Models. However, this strategy is dependent on coordination with the Lower Neches Valley Authority. This strategy is not dependent on any other water management strategies in the 2021 East Texas Regional Water Plan.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between municipal water users in Jefferson County, categorized by the Texas Water Development Board as County-Other, and the Lower Neches Valley Authority should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. This analysis was performed assuming that a project site would be chosen that had minimal impact to bays or estuaries in Jefferson County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 12 miles of pipeline (25% of the approximate distance across Jefferson County), a pump station with an intake, a booster pump station, and one terminal storage tank with one day of storage. The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required.

WUG	Jefferson County-Other				
STRATEGY:	Purchase from Lower Neches Valley Authority (Sam Rayburn)				
Raw Water Quantity:	1,950	AF/Y		2.6	MGD
CAPITAL COSTS					
Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	18 in.	63,360	LF	\$135	\$8,562,000
Right of Way Easements Rural (ROW)		63,360	LF	\$30	\$2,092,530
Engineering and Contingencies (30%)					\$2,569,000
Pump Station(s)					
				\$3,614,000	
Pump with intake	57 HP	1	LS	0	\$3,614,000
Booster Pump Station	57 HP	1	LS	\$930,000	\$930,000
Engineering and Contingencies (35%)					\$1,590,400
					\$6,134,400
Subtotal of Pump Station(s)					0
				\$1,036,300	
Storage Tanks	1.7 MG	1	LS	0	\$1,036,300
Engineering and Contingencies (35%)					\$362,705
					\$1,399,005
Subtotal of Storage Tanks					5
Permitting and Mitigation					\$328,000
					\$21,084,935
CONSTRUCTION TOTAL					35
Interest During Construction			12	Months	\$580,000
					\$21,665,000
TOTAL CAPITAL COST					00
ANNUAL COSTS					
Debt Service (3.5% for 20 years)					\$1,524,000
Operational Costs*					\$878,000
					\$2,402,000
Total Annual Costs					0
UNIT COSTS (Until Amortized)					
Per Acre-Foot of treated water					\$1,232
Per 1,000 Gallons					\$3.78



UNIT COSTS (After Amortization)

Per Acre-Foot \$450
 Per 1,000 Gallons \$1.38

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits municipal users in Jefferson County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from Sam Rayburn will reduce demands on other water supplies in Jefferson County and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the Jefferson County-Other recommended strategy to purchase water from the Lower Neches Valley Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	1,950 ac-ft per year
Reliability	4	Reliable Supply
Cost	2	Medium to High Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No Known Impacts.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsorship unknown
Implementation Issues	4	No known risks



REFERENCES

2016 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR JEFFERSON MANUFACTURING**

Water User Group Name:	Jefferson Manufacturing
Strategy Name:	Purchase from Lower Neches Valley Authority (Sam Rayburn)
Strategy ID:	JEFF-MFG
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	101,138 – 143,447 ac-ft per year (90.3 – 128.1 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$435,726,000 (September 2018)
Annual Cost:	\$83,968,000
Unit Water Cost (Rounded):	\$585 per ac-ft (\$1.80 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Manufacturing in Jefferson County and involves a contract between individual manufacturers and the Lower Neches Valley Authority for raw water from their Sam Rayburn system, as their permit allows. The Lower Neches Valley Authority currently supplies water to manufacturing water users in Jefferson County. Therefore, the only cost for additional supply is from the contractual cost of raw water. Ultimately, this cost will need to be negotiated with the Lower Neches Valley Authority and will reflect their wholesale water rates at that time. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The Lower Neches Valley Authority is projected to supply Jefferson Manufacturing with over 230,000 ac-ft per year beginning in 2020; this supply increases through 2070. The strategy recommended for Jefferson Manufacturing is equal to the need projected for this entity during the planning period (2020-2070). The contract required for this strategy increases their supply by 101,138 ac-ft per year beginning in 2020 and increases over time to approximately 143,500 ac-ft per year beginning in 2030 continuing until 2070. These supplies are considered highly reliable; however, the supply is dependent on coordination with the Lower Neches Valley Authority.

ENVIRONMENTAL CONSIDERATIONS

There are not any significant environmental considerations associated with this strategy. A contract between manufacturers in Jefferson County and the Lower Neches Valley Authority should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. Since this strategy does not include any new construction, there is no impact expected to bays or estuaries located in Jefferson County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. A regional rate for raw surface water was used for the purchase costs. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG	Jefferson County - Manufacturing				
STRATEGY:	Purchase from Lower Neches Valley Authority (Sam Rayburn)				
Raw Water Quantity:	143,479	AF/Y		192	MGD
CAPITAL COSTS					
Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	102 in.	89,760	2	\$1,257	\$225,665,000
Pipeline Urban	102 in.	0	LF	\$1,562	\$0
Right of Way Easements Rural (ROW)		89,760	LF	\$30	\$2,695,000
Land and Surveying (10%)					\$269,500
Right of Way Easements Urban (ROW)		0	0	\$0	\$0
Engineering and Contingencies (30%)					\$67,700,000
Subtotal of Pipeline	17	miles			\$296,329,500
Pump Station(s)					
Pump with intake	6733 HP	1	LS	\$41,983,000	\$41,983,000
Booster Pump Station	6733 HP	1	LS	\$32,670,000	\$32,670,000
Engineering and Contingencies (35%)					\$26,128,550
Subtotal of Pump Station(s)					\$100,781,550
Storage Tanks	4.0 MG	6	LS	\$1,904,493	\$11,426,958
Engineering and Contingencies (35%)					\$3,999,435
Subtotal of Storage Tanks					\$15,426,393
Permitting and Mitigation					\$473,000
CONSTRUCTION TOTAL					\$413,010,000
Interest During Construction			24	Months	\$22,716,000
TOTAL CAPITAL COST					\$435,726,000
ANNUAL COSTS					
Debt Service (3.5% for 20 years)					\$30,658,000
Operational Costs*					\$53,309,650
Total Annual Costs					\$83,968,000
UNIT COSTS (Until Amortized)					
Per Acre-Foot of treated water					\$585
Per 1,000 Gallons					\$1.80
UNIT COSTS (After Amortization)					
Per Acre-Foot					\$372
Per 1,000 Gallons					\$1.14
* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.					



PROJECT EVALUATION

This strategy benefits manufacturers in Jefferson County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Lower Neches Valley Authority’s Sam Rayburn system will reduce demands on other water supplies in Angelina County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Jefferson Manufacturing recommended strategy to purchase water from the Lower Neches Valley Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	143,479 ac-ft per year
Reliability	4	Reliable Supply
Cost	3	Medium Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No Known Impacts.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsorship unknown
Implementation Issues	4	No known risks

REFERENCES

2016 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR JEFFERSON STEAM ELECTRIC POWER**

Water User Group Name:	Jefferson Steam Electric Power
Strategy Name:	Purchase from Lower Neches Valley Authority (Sam Rayburn)
Strategy ID:	JEFF-SEP
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	2,391 ac-ft per year (2.13 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$32,302,000 (September 2018)
Annual Cost:	\$3,464,000
Unit Water Cost (Rounded):	\$1,449 per ac-ft (\$4.45 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Steam Electric Power in Jefferson County and involves a contract between individual steam electric power water users and the Lower Neches Valley Authority for raw water from their Sam Rayburn system, as their permit allows. The cost for supply from Sam Rayburn includes the contractual cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Lower Neches Valley Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water need projected for Steam Electric Power in Jefferson County by the East Texas Regional Planning Group during the planning period (2020-2070). The quantity of supply from this strategy represents a contract of 2,391 ac-ft per year, beginning in 2020, and remains constant over time to 2070. The reliability of this water supply is considered high due to the availability of water projected in Sam Rayburn using the Texas Water Development Board's Water Availability Models. However, this strategy is dependent on coordination with the Lower Neches Valley Authority. This strategy is not dependent on any other water management strategies in the 2021 East Texas Regional Water Plan.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between steam electric power water users in Jefferson County and the Lower Neches Valley Authority should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. This analysis was performed assuming that a project site would be chosen that had minimal impact to bays or estuaries in Jefferson County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 17 miles of pipeline (25% of the approximate distance across Jefferson County), a pump station with an intake, and a booster pump station. The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required.

WUG STRATEGY:	Jefferson County - Steam Electric Power				
Raw Water Quantity:	2,391 AF/Y		Purchase from Lower Neches Valley Authority 3.20 MGD		
CAPITAL COSTS					
Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	16 in.	89,760	LF	\$118	\$10,562,000
Right of Way Easements Rural (ROW)		89,760	LF	\$30	\$2,695,000
Land and Surveying (10%)					\$269,500
Engineering and Contingencies (30%)					\$3,169,000
Subtotal of Pipeline	17	miles			\$16,695,500
Pump Station(s)					
Pump with intake	296 HP	1	LS	\$7,542,000	\$7,542,000
Booster Pump Station	296 HP	1	LS	\$1,875,000	\$1,875,000
Engineering and Contingencies (35%)					\$3,295,950
Subtotal of Pump Station(s)					\$12,712,950
Storage Tanks	0.4 MG	1	LS	\$545,540	\$545,540
Engineering and Contingencies (35%)					\$190,939
Subtotal of Storage Tanks					\$736,479
Permitting and Mitigation					\$473,000
CONSTRUCTION TOTAL					\$30,618,000
Interest During Construction			24	Months	\$1,684,000
TOTAL CAPITAL COST					\$32,302,000
Debt Service (3.5% for 20 years)					\$2,273,000
Operational Costs*					\$1,191,000
Total Annual Costs					\$3,464,000
UNIT COSTS (Until Amortized)					
Per Acre-Foot of treated water					\$1,449
Per 1,000 Gallons					\$4.45
UNIT COSTS (After Amortization)					
Per Acre-Foot					\$526
Per 1,000 Gallons					\$1.61



* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits steam electric power users in Jefferson County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from Sam Rayburn will reduce demands on other water supplies in Jefferson County and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the Jefferson Steam Electric Power recommended strategy to purchase water from the Lower Neches Valley Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	2,391 ac-ft per year
Reliability	4	Reliable Supply
Cost	2	Medium to High Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No Known Impacts.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsorship unknown
Implementation Issues	4	No known risks

REFERENCES

2016 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR NACOGDOCHES D&M WSC**

Water User Group Name:	Nacogdoches County - D&M WSC
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	NACW-DMW
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	32 - 374 ac-ft per year (Varies) (0.03 – 0.33 MGD)
Implementation Decade:	2040
Development Timeline:	2040
Project Capital Cost:	\$4,567,000 (September 2018)
Annual Cost:	\$373,000
Unit Water Cost (Rounded):	\$ 997 per ac-ft (\$3.06 per 1,000 gallons)

PROJECT DESCRIPTION

D&M WSC is a municipal water user in Nacogdoches County. This water user currently relies on groundwater in the Carrizo Wilcox aquifer in Nacogdoches County. D&M WSC has a small need starting in 2040 and the maximum need is approximately 374 ac-ft per year. To meet this need, it is recommended that D&M WSC continue to use supplies from Carrizo Wilcox by drilling additional wells. This strategy is a recommended strategy for D&M WSC in Nacogdoches County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Nacogdoches County. These wells will provide approximately 400 ac-ft per year and are assumed to have a depth of 600 feet. A peaking factor of two was assumed for the wells, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply is required only in the later part of the planning cycle, for decades 2040 and 2070. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Nacogdoches County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that each well provide 200 ac-ft per year to meet D&M WSC's needs in Nacogdoches County providing a total yield required for the strategy. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Nacogdoches County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed ten miles of pipeline, two wells, a peaking factor of two, and a maximum well yield of 250 gpm for each well. This equates to \$997 per acre-foot (\$3.06 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$139 per acre-foot (\$0.43 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Nacogdoches County - D&M WSC
WMS: New wells in Carrizo-Wilcox Aquifer

Supply	374	Ac-ft/yr	232	gpm
Well Depth	600			
Wells Needed	2			

CAPITAL COST

Transmission Pipeline (6 in dia., 10 miles)	\$1,339,000
Primary Pump Stations (0.2 MGD)	\$819,000
Well Fields (Wells, Pumps, and Piping)	\$956,000
TOTAL COST OF FACILITIES	\$3,114,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$1,023,000
Environmental & Archaeology Studies and Mitigation	\$279,000
Land Acquisition and Surveying (6 acres)	\$28,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	\$123,000
TOTAL COST OF PROJECT	\$4,567,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$321,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$23,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$20,000
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (115018 kW-hr @ 0.08 \$/kW-hr)	\$9,000
Purchase of Water (acft/yr @ \$/acft)	\$0
TOTAL ANNUAL COST	\$373,000

Available Project Yield (acft/yr)	374
Annual Cost of Water (\$ per acft), based on PF=1.2	\$997
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1.2	\$139
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1.2	\$3.06
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1.2	\$0.43

PROJECT EVALUATION

This strategy benefits municipal user D&M WSC in Nacogdoches County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. New wells in the county will reduce demands on other water supplies in Nacogdoches County and will have no other apparent impact on other State water



resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the recommended strategy to drill new wells in Nacogdoches County for D&M WSC’s use was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	374 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	3	Moderate Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	2	Sponsor identified but uncommitted.
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR NACOGDOCHES LIVESTOCK**

Water User Group Name:	Nacogdoches County - Livestock
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	NACW-LTK
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	5,970 to 9,113 ac-ft per year (Varies) (5.3 – 8.1 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$ 26,677,000 (September 2018)
Annual Cost:	\$2,695,000
Unit Water Cost (Rounded):	\$296 per ac-ft (\$0.91 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for livestock users in Nacogdoches County and involves the development of 27 wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Nacogdoches County. These wells will provide approximately 9,100 ac-ft per year and are assumed to have a depth of 500 feet. A peaking factor of two was assumed for the wells, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply is required for all decades of the planning cycle to help meet the needs. Currently, local supply provides half of the supply for the livestock needs and the remainder is taken from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Nacogdoches County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that each well will provide 340 ac-ft per year to meet livestock demands in Nacogdoches County providing a total yield required for the strategy. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Nacogdoches County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs



assumed 10 miles of pipeline, 27 wells, a peaking factor of two, and a maximum well yield of 250 gpm for each well. This equates to \$296 per acre-foot (\$0.91 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$90 per acre-foot (\$0.28 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Nacogdoches County – Livestock
WMS: New wells in Carrizo-Wilcox Aquifer

Supply	9,113	Ac-ft/yr	5,650	Gpm
Well Depth	500			
Wells Needed	27			

CAPITAL COST

Transmission Pipeline (24 in dia., 10 miles)	\$8,112,000
Primary Pump Stations (9.8 MGD)	\$3,406,000
Well Fields (Wells, Pumps, and Piping)	\$7,670,000
	\$19,188,000

TOTAL COST OF FACILITIES

0

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$6,311,000
Environmental & Archaeology Studies and Mitigation	\$376,000
Land Acquisition and Surveying (19 acres)	\$88,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	\$714,000
	\$26,677,000

TOTAL COST OF PROJECT

0

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$1,877,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$158,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$85,000
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (7182267 kW-hr @ 0.08 \$/kW-hr)	\$575,000
Purchase of Water (acft/yr @ \$/acft)	\$0
TOTAL ANNUAL COST	\$2,695,000

Available Project Yield (acft/yr)	9,113
Annual Cost of Water (\$ per acft), based on PF=1.2	\$296
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1.2	\$90
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1.2	\$0.91
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1.2	\$0.28

PROJECT EVALUATION

This strategy benefits livestock users in Nacogdoches County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. New wells in the county will reduce demands on other water supplies in Nacogdoches County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because



it provides water for economic growth.

Based on the analyses provided above, the recommended strategy to drill new wells in Nacogdoches County for livestock use was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	9,113 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsorship unknown
Implementation Issues	4	No known risks

REFERENCES

2016 East Texas Regional Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
 TECHNICAL MEMORANDUM FOR NACOGDOCHES MINING**

Water User Group Name:	Nacogdoches County - Mining
Strategy Name:	Purchase from Angelina Neches River Authority (Angelina River)
Strategy ID:	NACW-MIN
Strategy Type:	New Surface Water Source
Potential Supply Quantity:	118 - 5,475 ac-ft per year (Varies) (0.15 - 4.88 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$18,647,000 (September 2018)
Annual Cost:	\$7,015,000
Unit Water Cost (Rounded):	\$1,281 per ac-ft (\$3.93 per 1,000 gallons)

PROJECT DESCRIPTION

Mining users in Nacogdoches County show a projected need in the early decades of the planning cycle. This strategy is a recommended strategy for Mining in Nacogdoches County and involves a contract between individual mining water users and the Angelina Neches River Authority for raw water from the Angelina River, as their permit allows. Potential mining customers in Nacogdoches County have reached out to Angelina Neches River Authority for a contract to sell water. It is assumed that the individual mining customers will develop the infrastructure required to access supplies from Angelina River to the project location. The cost for supply from the Angelina River includes the cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Angelina Neches River Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the mining need projected in Nacogdoches County by the East Texas Regional Water Planning Group. Currently mining needs are met by local supplies in Nacogdoches County and groundwater supplies from other aquifers in the County. The recommended source of supply for the future mining needs will be the run-of-river supplies from Angelina River that Angelina Neches River Authority is applying for. The reliability of this water supply is considered medium due to the availability of water projected in the Angelina River using the Texas Water Development Board’s Water Availability Models. However, this strategy is dependent on sales with the Angelina Neches River Authority and their application for 30,000 ac-ft per year from the Angelina River (Strategy ID: ANRA-ROR). The quantity of supply from this strategy represents a contract of 5,475 ac-ft per year, beginning in 2020 and decreases to 118 ac-ft per year by 2040.



ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between mining water users in Nacogdoches County and the Angelina Neches River Authority should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries in Nacogdoches County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 6 miles of pipeline (approximate distance from the potential location for run-of-river diversions on Angelina River to the center of Nacogdoches County), a pump station with an intake and one terminal storage tank with 1.2 MG of storage. The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required.

WUG:	Nacogdoches County Mining				
STRATEGY:	Purchase from ANRA (Angelina ROR)				
Raw Water Quantity:	5,475	AF/Y		9.77 MGD	
Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	24 in.	31,680	LF	\$154	\$4,879,000
Right of Way Easements Rural (ROW)		31,680	LF	\$18	\$579,000
Land and Surveying (10%)					\$58,000
Engineering and Contingencies (30%)					\$1,464,000
Subtotal of Pipeline	6	miles			\$6,980,000
Pump Station(s)					
Pump with intake	281 HP	1	LS	\$7,286,000	\$7,286,000
Booster Pump Station	0 HP	0	LS	\$0	\$0
Engineering and Contingencies (35%)					\$2,550,000
Subtotal of Pump Station(s)					\$9,836,000
Storage Tanks	1.2 MG	1	LS	\$855,465	\$855,000
Engineering and Contingencies (35%)					\$299,000
Subtotal of Storage Tanks					\$1,154,000
Permitting and Mitigation					\$178,000
Debt Service (3.5% for 20 years)					\$18,148,000
Interest During Construction			12	Months	\$499,000
TOTAL CAPITAL COST					\$18,647,000
ANNUAL COSTS					
Debt Service (3.5% for 20 years)					\$1,312,000
Operational Costs*					\$5,703,000
Total Annual Costs					\$7,015,000



UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water \$1,281
 Per 1,000 Gallons \$3.93

UNIT COSTS (After Amortization)

Per Acre-Foot \$1,042
 Per 1,000 Gallons \$3.20

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits mining users in Nacogdoches County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Angelina River will reduce demands on other water supplies in Nacogdoches County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Nacogdoches Mining recommended strategy to purchase water from the Angelina Neches River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	5,475 ac-ft per year
Reliability	3	Medium Reliable Supply
Cost	3	Medium Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Sponsor identified and committed to the strategy
Implementation Issues	4	No known risks

REFERENCES

2016 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR NEWTON MINING**

Water User Group Name:	Newton Mining
Strategy Name:	Purchase from Sabine River Authority (Toledo Bend)
Strategy ID:	NEWT-MIN
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	115 – 59 ac-ft per year (0.1 – 0.05 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$0 (September 2018)
Annual Cost:	\$111,000
Unit Water Cost (Rounded):	\$965 per ac-ft (\$2.96 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Mining in Newton County and involves a contract between individual mining water users and the Sabine River Authority from their Toledo Bend system, as their permit allows. The Sabine River Authority currently supplies water to mining water users in Newton County. Therefore, the only cost for additional supply from is the contractual cost of raw water. Ultimately, this cost will need to be negotiated with the Sabine River Authority and will reflect their wholesale water rates at that time. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

Currently, the Sabine River Authority is the only provider of water to mining users in Newton County. Therefore, this recommended strategy calls for a contract amendment equal to the projected need of Newton Mining during the planning period. The contract required for this strategy increases their supply by 115 ac-ft per year beginning in 2020 and decreases to 59 ac-ft per year beginning in 2030. Newton mining is not projected to have a need from 2040 through 2070. These supplies are considered highly reliable because the supply is available in Toledo Bend and the infrastructure is already in place; however, the supply is dependent on coordination with the Sabine River Authority.

ENVIRONMENTAL CONSIDERATIONS

There are not any significant environmental considerations associated with this strategy. A contract between mining water users in Newton County and the Sabine River Authority should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries located in Newton County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. No capital costs



were assumed, but an annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water equal to \$3.00 per 1,000 gallons. Overall, this strategy has a low cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG NAME:	Newton Mining		
STRATEGY:	Purchase from Sabine River Authority (Toledo Bend)		
			0.15
Raw Water Quantity:	115	AF/Y	MGD
CONSTRUCTION COSTS			
ANNUAL CONTRACT COSTS			
ANNUAL COSTS			
Operational Costs*			\$111,000
UNIT COSTS (Until Amortized)			
Per Acre-Foot of treated water			\$965
Per 1,000 Gallons			\$2.96
UNIT COSTS (After Amortization)			
Per Acre-Foot			NA
Per 1,000 Gallons			NA

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.



PROJECT EVALUATION

This strategy benefits mining water users in Newton County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Sabine River Authority’s Toledo Bend system will reduce demands on other water supplies in Newton County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Newton Mining recommended strategy to purchase water from the Sabine River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	115 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	3	Medium Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsorship unknown
Implementation Issues	4	Limited Risk

REFERENCES

2016 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR ORANGE IRRIGATION**

Water User Group Name:	Orange Irrigation
Strategy Name:	Purchase from Sabine River Authority (Sabine River)
Strategy ID:	ORAN-IRR
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	526 ac-ft per year (0.47 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$14,624,000 (September 2018)
Annual Cost:	\$1,355,000
Unit Water Cost (Rounded):	\$2,576 per ac-ft (\$7.91 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for irrigation water users in Orange County and involves a contract between individual irrigators and the Sabine River Authority for raw water from the Sabine River, as their permit allows. The cost for supply from the Sabine River includes the contractual cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Sabine River Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water need projected for irrigation users in Orange County projected by the East Texas Regional Planning Group during the planning period (2020-2070). The quantity of supply from this strategy represents a contract of 526 ac-ft per year, beginning in 2020 and continuing to 2070. The reliability of this water supply is considered high due to the availability of water projected in the Sabine River using the Texas Water Development Board's Water Availability Models. However, this strategy is dependent on coordination with the Sabine River Authority. This strategy is not dependent on any other water management strategies in the 2021 East Texas Regional Water Plan.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between irrigators in Orange County and the Sabine River Authority should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. Sabine River Authority already supplies to some irrigation users in Orange County. The strategy is highly reliable since some of the transmission connections may be already in place.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 13 miles of pipeline (the approximate distance from the Sabine River to the center of Orange County), a pump station with an intake, a booster pump station, and a terminal storage tank (0.1 million gallon). The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required and the large supply volume.

WUG **Orange County – Irrigation**
STRATEGY: **Purchase from Sabine River Authority (Sabine River)**
Raw Water Quantity: **526 AF/Y** **0.9 MGD**

CAPITAL COSTS

Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	10 in.	68,640	LF	\$65	\$4,481,000
Right of Way Easements Rural (ROW)		68,640	LF	\$30	\$2,060,900
Land and Surveying (10%)					\$206,090
Engineering and Contingencies (30%)					\$1,344,000
Subtotal of Pipeline	13	miles			\$8,091,990

Pump Station(s)

				\$2,997,00	
Pump with intake	20 HP	1	LS	0	\$2,997,000
Booster Pump Station	20 HP	1	LS	\$837,000	\$837,000
Engineering and Contingencies (35%)					\$1,341,900
Subtotal of Pump Station(s)					\$5,175,900

Storage Tanks	0.1 MG	1	LS	\$438,839	\$438,839
Engineering and Contingencies (35%)					\$153,594
Subtotal of Storage Tanks					\$592,433

Permitting and Mitigation \$373,000
\$14,233,00

CONSTRUCTION TOTAL

Interest During Construction 12 Months \$391,000
\$14,624,00

TOTAL CAPITAL COST **0**

ANNUAL COSTS

Debt Service (3.5% for 20 years) \$1,029,000
 Operational Costs* \$326,000
Total Annual Costs **\$1,355,000**

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water \$2,576
 Per 1,000 Gallons \$7.91



UNIT COSTS (After Amortization)

Per Acre-Foot \$639
 Per 1,000 Gallons \$1.96

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits irrigation water users in Orange County and is expected to have a positive impact on their water supply security. Sabine River Authority currently supplies water to some irrigators in Orange County. Therefore, this strategy is highly reliable as some of the connections may already be in place and the strategy may be just an extension of current contracts. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Sabine River will reduce demands on other water supplies in Orange County and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the Orange Irrigation recommended strategy to purchase water from the Sabine River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	526 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	2	Medium – High Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	5	Positive Impacts to Agricultural Resources
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsorship unknown
Implementation Issues	4	No known risks



REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS TECHNICAL MEMORANDUM FOR PANOLA LIVESTOCK

Water User Group Name:	Panola County – Livestock
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	PANL-LTK
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	982 ac-ft per year (0.88 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$1,172,000 (September 2018)
Annual Cost:	\$122,000
Unit Water Cost (Rounded):	\$124 per ac-ft (\$0.38 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for livestock users in Panola County and involves the development of four wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Panola County. These wells will provide approximately 982 ac-ft per year and are assumed to have a depth of 200 feet. A peaking factor of two was assumed for the wells, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

It is assumed that each well will provide 245 ac-ft per year to meet livestock demands in Panola County providing a total strategy yield of 982 ac-ft per year beginning in 2020. A target yield for this strategy was set to the highest need projected by the East Texas Regional Water Planning Group; the highest need occurs in 2020 and continues throughout the planning period. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Panola County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed four wells, a peaking factor of two, and a maximum well yield of 275 gpm for each well. This equates to \$124 per acre-foot (\$0.38 per 1,000 gallons); after the infrastructure is fully paid (30 years),



the cost drops to \$40 per acre-foot (\$0.12 per 1,000 gallons). Overall, this strategy has a low cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Panola County – Livestock

WMS: New wells in Carrizo-Wilcox Aquifer

Supply	982	Ac-ft/yr		609	gpm
Well Depth	200				
Wells Needed	4				

CAPITAL COST

Well Fields (Wells, Pumps, and Piping)	\$827,000
TOTAL COST OF FACILITIES	\$827,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$289,000
Environmental & Archaeology Studies and Mitigation	\$15,000
Land Acquisition and Surveying (2 acres)	\$9,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	\$32,000
TOTAL COST OF PROJECT	\$1,172,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$83,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$8,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$0
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (391758 kW-hr @ 0.08 \$/kW-hr)	\$31,000
Purchase of Water (acft/yr @ \$/acft)	\$0
TOTAL ANNUAL COST	\$122,000

Available Project Yield (acft/yr)	982
Annual Cost of Water (\$ per acft), based on PF=1	\$124
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1	\$40
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1	\$0.38
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1	\$0.12

PROJECT EVALUATION

This strategy benefits livestock water users in Panola County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. Developing new groundwater wells in Panola County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Panola County livestock recommended strategy to develop groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.



Criteria	Rating	Explanation
Quantity	4	982 ac-ft per year
Reliability	4	Very Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low to No Impacts
Interbasin Transfers		No
Other Natural Resources	4	Low to No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	No Local Sponsor identified
Implementation Issues	4	No known risks

REFERENCES

Discussions with Regional Water Planning Group and Groundwater Management Areas.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR RUSK JACOBS WSC**

Water User Group Name:	Rusk – Jacobs WSC
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	RUSK-JAW
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	22 ac-ft per year (0.02 MGD)
Implementation Decade:	2070
Development Timeline:	2070
Project Capital Cost:	\$1,795,000 (September 2018)
Annual Cost:	\$140,000
Unit Water Cost (Rounded):	\$6,364 per ac-ft (\$19.53 per 1,000 gallons)

PROJECT DESCRIPTION

Jacobs WSC has a small need starting in 2070 of approximately 22 ac-ft per year. This strategy is a recommended strategy for Jacobs WSC in Rusk County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Rusk County. The wells will provide approximately 22 ac-ft per year and are assumed to have a depth of 400 feet. A peaking factor of two was assumed for the well, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply is required only in the later part of the planning cycle beginning in 2070. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Rusk County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that the wells will provide sufficient acre feet per year to meet Jacobs WSC's needs in Rusk County providing a total yield required for the strategy. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Rusk County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs



assumed 1 mile of pipeline, two wells, a peaking factor of two, and a maximum well yield of 350 gpm for each well. This equates to \$6,364 per acre-foot (\$19.53 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$636 per acre-foot (\$1.95 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Rusk – Jacobs WSC

WMS: New wells in Carrizo-Wilcox Aquifer

Supply	22	Ac-ft/yr		14	gpm
Well Depth	400				
Wells Needed	2				

CAPITAL COST

Transmission Pipeline (6 in dia., 1 miles)	\$134,000
Primary Pump Stations (0 MGD)	\$76,000
Well Fields (Wells, Pumps, and Piping)	\$1,028,000
TOTAL COST OF FACILITIES	\$1,238,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$426,000
Environmental & Archaeology Studies and Mitigation	\$54,000
Land Acquisition and Surveying (6 acres)	\$28,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	\$49,000
TOTAL COST OF PROJECT	\$1,795,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$126,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$12,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$2,000
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (6151 kW-hr @ 0.08 \$/kW-hr)	\$0
Purchase of Water (acft/yr @ \$/acft)	\$0
TOTAL ANNUAL COST	\$140,000

Available Project Yield (acft/yr)	22
Annual Cost of Water (\$ per acft), based on PF=1	\$6,364
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1	\$636
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1	\$19.53
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1	\$1.95

PROJECT EVALUATION

This strategy benefits Jacobs WSC municipal users in Rusk County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. Developing new groundwater supplies Rusk County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this new supply will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Rusk Jacobs WSC recommended strategy to develop new



groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	22 ac-ft per year
Reliability	3	Medium Reliable Supply
Cost	1	Very High Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Sponsorship by Jacobs WSC
Implementation Issues	4	No known risk

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR RUSK LIVESTOCK**

Water User Group Name:	Rusk County - Livestock
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	RUSK-LTK
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	20 – 83 ac-ft per year (Varies) (0.02 – 0.07 MGD)
Implementation Decade:	2040
Development Timeline:	2040
Project Capital Cost:	\$283,000 (September 2018)
Annual Cost:	\$24,000
Unit Water Cost (Rounded):	\$289 per ac-ft (\$0.89 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for livestock users in Rusk County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Rusk County. These wells will provide approximately 83 ac-ft per year and are assumed to have a depth of 190 feet. A peaking factor of two was assumed for the wells, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

It is assumed that each well will provide approximately 42 ac-ft per year to meet irrigation demands in Rusk County providing a total strategy yield of 83 ac-ft per year beginning in 2040. A target yield for this strategy was set to the highest need projected by the East Texas Regional Water Planning Group; the highest needs occurs beginning in 2060. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Rusk County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed two wells, a peaking factor of two, and a maximum well yield of 200 gpm for each well. This equates to \$289 per acre-foot (\$0.89 per 1,000 gallons); after the infrastructure is fully paid (30 years),



the cost drops to \$48 per acre-foot (\$0.15 per 1,000 gallons). Overall, this strategy has a low cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: Rusk County - Livestock

WMS: New wells in Carrizo-Wilcox Aquifer

Supply	83	Ac-ft/yr	51	gpm
Well Depth	190			
Wells Needed	2			

CAPITAL COST

Well Fields (Wells, Pumps, and Piping)	\$194,000
TOTAL COST OF FACILITIES	\$194,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$68,000
Environmental & Archaeology Studies and Mitigation	\$8,000
Land Acquisition and Surveying (1 acres)	\$5,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	\$8,000
TOTAL COST OF PROJECT	\$283,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$20,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$2,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$0
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (19000 kW-hr @ 0.08 \$/kW-hr)	\$2,000
Purchase of Water (acft/yr @ \$/acft)	\$0
TOTAL ANNUAL COST	\$24,000

Available Project Yield (acft/yr)	83
Annual Cost of Water (\$ per acft), based on PF=1	\$289
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1	\$48
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1	\$0.89
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1	\$0.15

PROJECT EVALUATION

This strategy benefits livestock users in Rusk County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. Developing new groundwater wells in Rusk County will have no other apparent impact on other State water resources. From a third party social and economic perspective, this new supply will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Rusk Livestock recommended strategy to purchase water from the Angelina Neches River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.



Criteria	Rating	Explanation
Quantity	4	83 ac-ft per year
Reliability	3	Medium Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	No sponsor identified
Implementation Issues	4	No known risk

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR RUSK MINING**

Water User Group Name:	Rusk Mining
Strategy Name:	Purchase from Angelina Neches River Authority (Angelina River)
Strategy ID:	RUSK-MIN
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	22 – 305 ac-ft per year (Varies) (0.02 – 0.27 MGD)
Implementation Decade:	2030
Development Timeline:	2030
Project Capital Cost:	\$14,808,000 (September 2018)
Annual Cost:	\$1,291,000
Unit Water Cost (Rounded):	\$4,233 per ac-ft (\$12.99 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Mining in Rusk County and involves a contract between individual mining water users and the Angelina Neches River Authority for raw water from the Angelina River, as their permit allows. The cost for supply from the Angelina River includes the cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Angelina Neches River Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the mining need projected in Rusk County by the East Texas Regional Water Planning Group. The reliability of this water supply is considered medium due to the availability of water projected in the Angelina River using the Texas Water Development Board’s Water Availability Models. However, this strategy is dependent on sales with the Angelina Neches River Authority and their application for 10,000 ac-ft per year from the Angelina River (Strategy ID: ANRA-ROR). The quantity of supply from this strategy represents a contract of 305 ac-ft per year, beginning in 2030, and decreases to 22 ac-ft per year in 2050.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between mining water users in Rusk County and the Angelina Neches River Authority should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries in Rusk County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs



assumed 16 miles of pipeline (50% of the approximate distance across Rusk County), a pump station with an intake, a booster pump station, and one terminal storage tank with one day of storage. The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required.

WUG STRATEGY: Raw Water Quantity:	Rusk County - Mining				
	Purchase from Angelina Neches River Authority				
	305	AF/Y		0.5	MGD
 CAPITAL COSTS					
Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	8 in.	84,480	LF	\$48	\$4,040,000
Right of Way Easements Rural (ROW)		84,480	LF	\$30	\$2,536,000
Land and Surveying (10%)					\$253,600
Engineering and Contingencies (30%)					\$1,212,000
Subtotal of Pipeline	16	miles			\$8,041,600
 Pump Station(s)					
Pump with intake	25 HP	1	LS	\$3,087,000	\$3,087,000
Booster Pump Station	25 HP	1	LS	\$880,000	\$880,000
Engineering and Contingencies (35%)					\$1,388,450
Subtotal of Pump Station(s)					\$5,355,450
 Storage Tanks					
Storage Tanks	0.1 MG	1	LS	\$420,238	\$420,000
Engineering and Contingencies (35%)					\$147,000
Subtotal of Storage Tanks					\$567,000
Permitting and Mitigation					\$448,000
CONSTRUCTION TOTAL					\$14,412,050
Interest During Construction			12	Months	\$396,000
TOTAL CAPITAL COST					\$14,808,000
 ANNUAL COSTS					
Debt Service (3.5% for 20 years)					\$1,042,000
Operational Costs*					\$249,000
Total Annual Costs					\$1,291,000
 UNIT COSTS (Until Amortized)					
Per Acre-Foot of treated water					\$4,233
Per 1,000 Gallons					\$12.99
 UNIT COSTS (After Amortization)					
Per Acre-Foot					\$839
Per 1,000 Gallons					\$2.58



* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits mining users in Rusk County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Angelina River will reduce demands on other water supplies in Rusk County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Rusk Mining recommended strategy to purchase water from the Angelina Neches River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	305 ac-ft per year
Reliability	3	Medium Reliable Supply
Cost	2	Medium to High Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Sponsor Identified and committed.
Implementation Issues	4	No known risk

REFERENCES

Discussions with Angelina River Water Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR RUSK STEAM ELECTRIC POWER**

Water User Group Name:	Rusk Steam Electric Power
Strategy Name:	Purchase from Sabine River Authority (Toledo Bend)
Strategy ID:	RUSK-SEP
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	1,103 ac-ft per year (0.98 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$30,008,000 (September 2018)
Annual Cost:	\$2,795,000
Unit Water Cost (Rounded):	\$2,534 per ac-ft (\$7.78 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Steam Electric Power in Rusk County and involves a contract between individual steam electric power water users and the Sabine River Authority for raw water from the Sabine River, as their permit allows. The cost for supply from the Sabine River includes the contractual cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Sabine River Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water need projected for Steam Electric Power in Rusk County projected by the East Texas Regional Planning Group during the planning period (2020-2070). The quantity of supply from this strategy represents a contract of 1,103 ac-ft per year, beginning in 2020, and continuing throughout the planning period to 2070. The reliability of this water supply is considered high due to the availability of water projected in the Sabine River using the Texas Water Development Board's Water Availability Models. However, this strategy is dependent on coordination with the Sabine River Authority. This strategy is not dependent on any other water management strategies in the 2021 East Texas Regional Water Plan.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between steam electric power water users in Rusk County and the Sabine River Authority should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries within Rusk County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 25 miles of pipeline (the approximate distance from the Sabine River to the center of Rusk County), a pump station with an intake, a booster pump station, and a storage tank (0.2 million gallon). The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required.

WUG STRATEGY:	Rusk County - Steam Electric Power				
Raw Water Quantity:	1,103 AF/Y		2.0 MGD		
CAPITAL COSTS					
Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	12 in.	132,000	LF	\$83	\$10,922,000
Right of Way Easements Rural (ROW)		132,000	LF	\$30	\$3,963,200
Land and Surveying (10%)					\$396,320
Engineering and Contingencies (30%)					\$3,277,000
Subtotal of Pipeline	25	miles			\$18,558,520
Pump Station(s)					
Pump Station with intake	183 HP	1	LS	\$5,673,000	\$5,673,000
Booster Pump Station	183 HP	1	LS	\$1,227,000	\$1,227,000
Engineering and Contingencies (35%)					\$2,415,000
Subtotal of Pump Station(s)					\$9,315,000
Storage Tanks	0.2 MG	1	LS	\$487,422	\$487,422
Engineering and Contingencies (35%)					\$170,598
Subtotal of Storage Tanks					\$658,020
Permitting and Mitigation					\$673,000
CONSTRUCTION TOTAL					\$29,204,540
Interest During Construction			12	Months	\$803,000
TOTAL CAPITAL COST					\$30,008,000
ANNUAL COSTS					
Debt Service (3.5% for 20 years)					\$2,111,000
Operational Costs*					\$684,000
Total Annual Costs					\$2,795,000
UNIT COSTS (Until Amortized)					
Per Acre-Foot of treated water					\$2,534
Per 1,000 Gallons					\$7.78
UNIT COSTS (After Amortization)					
Per Acre-Foot					\$655
Per 1,000 Gallons					\$2.01

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.



PROJECT EVALUATION

This strategy benefits steam electric power water users in Rusk County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Sabine River will reduce demands on other water supplies in Rusk County and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the Rusk Steam Electric Power recommended strategy to purchase water from the Sabine River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	1,103 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	2	Medium to High Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Local Sponsorship unknown
Implementation Issues	4	No known risk

REFERENCES

Discussions with Sabine River Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR SAN AUGUSTINE - SAN AUGUSTINE**

Water User Group Name:	San Augustine County - San Augustine
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	SAUG- SAG
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	89 – 120 ac-ft per year (Varies) (0.08 – 0.11 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$1,055,000 (September 2018)
Annual Cost:	\$88,000
Unit Water Cost (Rounded):	\$733 per ac-ft (\$2.25 per 1,000 gallons)

PROJECT DESCRIPTION

San Augustine has needs throughout the planning period, with the maximum need of approximately 120 ac-ft per year occurring in 2020. To meet this need, it is recommended that San Augustine continue to use supplies from Carrizo Wilcox by drilling additional wells. This strategy is a recommended strategy for San Augustine in San Augustine County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Cherokee County. The wells will provide approximately 60 ac-ft per year and are assumed to have a depth of 250 feet. A peaking factor of two was assumed for the well, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply is required throughout the planning cycle, for decades 2020 and 2070. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the San Augustine County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that each well provide 60 ac-ft per year to meet San Augustine's needs in San Augustine County providing a total yield required for the strategy. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of San Augustine County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 1 mile of pipeline, two wells, a peaking factor of two, and a maximum well yield of 100 gpm for each well. This equates to \$807 per acre-foot (\$2.48 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$128 per acre-foot (\$0.39 per 1,000 gallons). Overall, this strategy has a low cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG: San Augustine County - San Augustine
WMS: New wells in Carrizo-Wilcox Aquifer

Supply	120	Ac-ft/yr		74	gpm
Well Depth	250				
Wells Needed	2				

CAPITAL COST

Transmission Pipeline (6 in dia., 1 miles)	\$134,000
Primary Pump Stations (0.1 MGD)	\$192,000
Well Fields (Wells, Pumps, and Piping)	\$378,000
TOTAL COST OF FACILITIES	\$704,000

Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$240,000
Environmental & Archaeology Studies and Mitigation	\$54,000
Land Acquisition and Surveying (6 acres)	\$28,000
Interest During Construction (3% for 1 years with a 0.5% ROI)	\$29,000
TOTAL COST OF PROJECT	\$1,055,000

ANNUAL COST

Debt Service (3.5 percent, 20 years)	\$74,000
Reservoir Debt Service (3.5 percent, 40 years)	\$0
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$5,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$5,000
Dam and Reservoir (1.5% of Cost of Facilities)	\$0
Water Treatment Plant	\$0
Advanced Water Treatment Facility	\$0
Pumping Energy Costs (54366 kW-hr @ 0.08 \$/kW-hr)	\$4,000
Purchase of Water (acft/yr @ \$/acft)	\$0
TOTAL ANNUAL COST	\$88,000

Available Project Yield (acft/yr)	120
Annual Cost of Water (\$ per acft), based on PF=1	\$733
Annual Cost of Water After Debt Service (\$ per acft), based on PF=1	\$117
Annual Cost of Water (\$ per 1,000 gallons), based on PF=1	\$2.25
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=1	\$0.36

PROJECT EVALUATION

This strategy benefits municipal users in San Augustine County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. Developing new groundwater wells in San Augustine County will have no other apparent impact on other State water resources.



Based on the analyses provided above, the recommended strategy for municipal users in San Augustine County to purchase water from the Angelina Neches River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	120 ac-ft per year
Reliability	4	Reliable Supply
Cost	3	Moderate Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Local Sponsor Identified
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR SAN AUGUSTINE LIVESTOCK**

Water User Group Name:	San Augustine County - Livestock
Strategy Name:	Purchase from SRA (Toledo Bend)
Strategy ID:	SAUG-LTK
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	1,333 – 2,349 ac-ft per year (Varies) (1.2 – 2.1 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$41,302,000 (September 2018)
Annual Cost:	\$4,121,000
Unit Water Cost (Rounded):	\$1,754 per ac-ft (\$5.38 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for livestock users in San Augustine County and involves the purchase of supplies from Sabine River Authority’s Toledo Bend Reservoir. The cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

A target yield for this strategy was set to the highest need projected by the East Texas Regional Water Planning Group; the highest need occurs in 2070. Overall, the reliability of this supply is considered high, based on the supply availability from Toledo Bend.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. The impact to the environment due to pipeline construction is expected to be temporary and minimal. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of San Augustine County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. This equates to \$1,754 per acre-foot (\$5.38 per 1,000 gallons); after the infrastructure is fully paid (30 years), the cost drops to \$542 per acre-foot (\$1.66 per 1,000 gallons). Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG

**San Augustine County - Live
Stock**



STRATEGY: **Purchase from Sabine River Authority (Sabine River)**
Raw Water Quantity: **2,349 AF/Y** **4.2 MGD**

CAPITAL COSTS

Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	18 in.	132,000	LF	\$135	\$17,837,000
Right of Way Easements Rural (ROW)		132,000	LF	\$30	\$4,359,520
Engineering and Contingencies (30%)					\$5,351,000
Subtotal of Pipeline	25	miles			\$27,547,520

Pump Station(s)

Pump Station with intake	246 HP	1	LS	\$6,714,000	\$6,714,000
Booster Pump Station	246 HP	1	LS	\$1,565,000	\$1,565,000
Engineering and Contingencies (35%)					\$2,897,650
Subtotal of Pump Station(s)					\$11,176,650

Storage Tanks	0.5 MG	1	LS	\$592,331	\$592,331
Engineering and Contingencies (35%)					\$207,316
Subtotal of Storage Tanks					\$799,647

Permitting and Mitigation \$673,000
\$40,196,817

CONSTRUCTION TOTAL

Interest During Construction 12 Months \$1,105,000
\$41,302,000

TOTAL CAPITAL COST **0**

ANNUAL COSTS

Debt Service (3.5% for 20 years) \$2,906,000
 Operational Costs* \$1,215,000
Total Annual Costs **\$4,121,000**

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water \$1,754
 Per 1,000 Gallons \$5.38



UNIT COSTS (After Amortization)
 Per Acre-Foot

\$542

PROJECT EVALUATION

This strategy benefits livestock water users in San Augustine County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Toledo Bend will reduce demands on other water supplies in San Augustine County and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for livestock users in San Augustine County to purchase water from the Sabine River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	2,349 ac-ft per year
Reliability	4	Reliable Supply
Cost	2	Medium to High Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	No Local Sponsor Identified
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR SAN AUGUSTINE MINING**

Water User Group Name:	San Augustine County - Mining
Strategy Name:	Purchase from Angelina Neches River Authority
Strategy ID:	SAUG-MIN
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	2,102 – 1,102 ac-ft per year (Varies) (1.87 – 0.98 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$42,807,000 (September 2018)
Annual Cost:	\$5,507,000
Unit Water Cost (Rounded):	\$2,620 per ac-ft (\$8.04 per 1,000 gallons)

PROJECT DESCRIPTION

San Augustine County shows shortages for mining users for the decades 2020 and 2030. The mining water users have a contract with Angelina Neches River Authority to use Angelina Neches River Authority's supplies to meet the water needs. Current supply is from other aquifers and San Augustine City Lake. This strategy is a recommended strategy for mining users in San Augustine County and involves a contract between mining water users and the Angelina Neches River Authority for raw water from the run-of-river supplies on Angelina River. The cost for supply from the Angelina River includes the contractual cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Angelina Neches River Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water need projected for mining in San Augustine County projected by the East Texas Regional Planning Group during the planning period (2020-2070). The shortage manifests for decades 2020 and 2030. The quantity of supply from this strategy represents a contract of 2,102 ac-ft per year, beginning in 2020, and drops to 1,102 ac-ft per year in 2030. Angelina Neches River Authority put in an application for 10,000 ac-ft per year of run-of-river supplies and the application is administratively complete. Angelina Neches River Authority has a water management strategy in the 2021 Plan to apply for additional run-of-river supplies to address the mining demands in the region. Because of the nature of the application and the process involved in securing the water rights, this supply is not considered very reliable at this time. Therefore, this strategy is dependent on successful execution of Angelina Neches River Authority's water management strategies in the 2021 East Texas Regional Water Plan to secure additional run-of-river supplies.



ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between mining water users in San Augustine County and the Angelina Neches River Authority should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area.

PERMITTING AND DEVELOPMENT

There are permitting and supply development issues associated with this strategy. Angelina Neches River Authority has to work with Texas Commission on Environmental Quality to furnish all the required documentation required for the successful procurement of the new and currently pending run-of-river water right applications. Also, the availability of this supply is potentially limited to the environmental flow requirements and supply availability in the Angelina River in that region.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 30 miles of pipeline (the approximate distance from Angelina River to the center of San Augustine County), a pump station with an intake, and a terminal storage tank (0.4 million gallon). The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water equal to \$3.00 per 1,000 gallons. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required and the quantity of supply delivered for the infrastructure.

WUG STRATEGY:	San Augustine County - Mining					
Quantity:	Purchase from Angelina River					
CAPITAL COSTS	2,102	AF/Y			2.81	MGD
Pipeline	Size	Quantity	Unit	Unit Price	Cost	
Pipeline Rural	18 in.	158,400	LF	\$135	\$21,404,000	
Right of Way Easements Rural (ROW)		158,400	LF	\$18	\$2,894,800	
Land and Surveying (10%)					\$289,480	
Engineering and Contingencies (30%)					\$6,421,000	
Subtotal of Pipeline					\$31,009,280	
Pump Station(s)						
Pump Station with intake	221 HP	1	LS	\$6,302,000	\$6,302,000	
Engineering and Contingencies (35%)					\$2,205,700	
Subtotal of Pump Station(s)					\$8,507,700	
Storage Tanks	0.4 MG	1	LS	\$1,012,000	\$1,012,000	
Engineering and Contingencies (35%)					\$354,200	
Subtotal of Storage Tanks					\$1,366,200	
Permitting and Mitigation					\$778,000	
CONSTRUCTION TOTAL					\$41,661,180	
Interest During Construction			12	Months	\$1,146,000	
TOTAL COST					\$42,807,000	



ANNUAL COSTS

Debt Service (3.5% for 20 years)	\$3,012,000
Operational Costs*	\$2,495,000
Total Annual Costs	\$5,507,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water	\$2,620
Per 1,000 Gallons	\$8.04

UNIT COSTS (After Amortization)

Per Acre-Foot	\$1,215
Per 1,000 Gallons	\$3.73

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits mining water users in San Augustine County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Angelina River will reduce demands on other water supplies in San Augustine County and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for mining users in San Augustine County to purchase water from the Angelina Neches River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	2,102 ac-ft per year
Reliability	4	Reliable Supply
Cost	2	Medium to High Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Local Sponsor Identified
Implementation Issues	4	No known risks



REFERENCES

Discussions with Angelina Neches River Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR SHELBY SAND HILLS WSC**

Water User Group Name:	Shelby County - Sand Hills WSC
Strategy Name:	Purchase from Center
Strategy ID:	SHEL-SHW
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	61 – 105 ac-ft per year (Varies) (0.05 – 0.09 MGD)
Implementation Decade:	2020
Development Timeline:	2020 - 2070
Project Capital Cost:	\$0 (September 2018)
Annual Cost:	\$102,000
Unit Water Cost (Rounded):	\$971 per ac-ft (\$2.98 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for the Sand Hills WSC in Shelby County and involves a contract between Sand Hills WSC and the City of Center for raw water. As the Sand Hills WSC already purchases water from the City of Center, the only cost for additional supply from the City of Center is the cost of raw water. Ultimately, this cost will need to be negotiated with the City of Center and will reflect the City's wholesale water rates at that time. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The City of Center currently supplies approximately 3,000 ac-ft per year to meet the municipal demands of the Sand Hills WSC in Shelby County. The quantity of supply from this strategy represents a contract increase of 61 ac-ft per year, beginning in 2020, and increases to 105 ac-ft per year, beginning in 2070. From 2020 through 2070, the supply is limited to the Sand Hills WSC's need projected by the East Texas Regional Water Planning Group. These supplies are considered highly reliable.

ENVIRONMENTAL CONSIDERATIONS

There are not any significant environmental considerations associated with this strategy. A contract between the Sand Hills WSC and the City of Center should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries within Shelby County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. No capital costs were assumed, but an annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a low cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WUG STRATEGY:	Shelby County - Sand Hills WSC	
Raw Water Quantity:	105 AF/Y	0.14 MGD

CONSTRUCTION COSTS

ANNUAL CONTRACT COSTS

ANNUAL COSTS

O&M and Other Costs*	34,000	34,000	1000 gal	\$3.00	\$102,000
Treatment		0	1000 gal	\$3.00	\$0
Operational Costs*					\$102,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water	\$971
Per 1,000 Gallons	\$2.98

UNIT COSTS (After Amortization)

Per Acre-Foot	NA
Per 1,000 Gallons	NA

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits municipal users in Sand Hills WSC in Shelby County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the City of Center reservoirs will reduce demands on other water supplies in Shelby County and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for Sand Hills WSC in Shelby County to purchase water from the City of Center was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.



Criteria	Rating	Explanation
Quantity	4	105 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	3	Medium Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Sand Hills WSC
Implementation Issues	4	No known Risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR SHELBY LIVESTOCK**

Water User Group Name:	Shelby County - Livestock
Strategy Name:	Purchase from Sabine River Authority (Toledo Bend)
Strategy ID:	SHEL-LTK
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	6,491 – 19,006 ac-ft per year (Varies) (5.8 –17.0 MGD)
Implementation Decade:	2020
Development Timeline:	2020 - 2070
Project Capital Cost:	\$0 (September 2018)
Annual Cost:	\$18,582,000
Unit Water Cost (Rounded):	\$978 per ac-ft (\$3.00 per 1,000 gallons)

PROJECT DESCRIPTION

Livestock water demands are projected to increase significantly in Shelby County, partially due to the growing poultry industry. Current supply is from Carrizo-Wilcox aquifer and local surface water supplies. It is recommended that any large-scale user should obtain surface water from Toledo Bend Reservoir through a contract with Sabine River Authority. This strategy is a recommended strategy for livestock users in Shelby County and involves a contract between livestock water users and the Sabine River Authority for raw water from the Sabine River, as their permit allows. The cost for supply from the Sabine River includes the contractual cost of raw water. Ultimately, the cost for raw water will need to be negotiated with the Sabine River Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water need projected for Livestock in Shelby County projected by the East Texas Regional Planning Group during the planning period (2020-2070). The quantity of supply from this strategy represents a contract of 6,491 ac-ft per year, beginning in 2020, and increases over time to 19,006 ac-ft per year, beginning in 2070. The reliability of this water supply is considered high due to the availability of water projected in the Sabine River using the Texas Water Development Board’s Water Availability Models. However, this strategy is dependent on coordination with the Sabine River Authority. This strategy is not dependent on any other water management strategies in the 2021 East Texas Regional Water Plan.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between livestock water users in Shelby County and the Sabine River Authority should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries within Shelby County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the length of pipeline required and the large quantity of supply.

WUG	Shelby County - Livestock	
STRATEGY:	Purchase from Sabine River Authority (Toledo Bend)	
Raw Water Quantity:	19,006 AF/Y	25.43 MGD

CONSTRUCTION COSTS
ANNUAL CONTRACT COSTS
ANNUAL COSTS

O&M and Other Costs*	6,194,000	6,194,000	1000 gal	\$3.00	\$18,582,000
Treatment		0	1000 gal	\$3.00	\$0
Operational Costs*					\$18,582,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water	\$978
Per 1,000 Gallons	\$3.00

UNIT COSTS (After Amortization)

Per Acre-Foot	NA
Per 1,000 Gallons	NA

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits livestock water users in Shelby County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Sabine River will reduce demands on other water supplies in Shelby County and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for livestock users in Shelby County to purchase water from the Sabine River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	19,006 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	3	Medium Cost



Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	No Local Sponsor identified
Implementation Issues	4	No known Risks

REFERENCES

Discussions with Sabine River Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR SMITH BULLARD**

Water User Group Name:	Smith County - Bullard
Strategy Name:	Purchase from City of Tyler
Strategy ID:	SMTH-BLD
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	142 – 1,145 ac-ft per year (Varies) (0.13 – 1.00 MGD)
Implementation Decade:	2020
Development Timeline:	2020 - 2070
Project Capital Cost:	\$14,264,000 (September 2018)
Annual Cost:	\$1,615,000
Unit Water Cost (Rounded):	\$1,410 per ac-ft (\$4.33 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for municipal water user Bullard in Smith County and involves a contract between individual Bullard and the City of Tyler for raw water. Bullard is located in ETRWPA region of Smith County. Bullard currently obtains most of its supply from Carrizo Wilcox and sales from North Cherokee WSC. A feasible strategy would be to continue using groundwater from Carrizo Wilcox. However, this cannot be recommended because of the MAG limitations in Smith County. Therefore, a contract to use City of Tyler’s supplies is the recommended strategy for Bullard. In addition to this, municipal conservation is another recommended strategy. Discussion on Conservation strategies is included in a separate technical memorandum. The cost for supply from the City of Tyler includes the contractual cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the City of Tyler and will reflect the wholesale water rates of this entity at the time a contract is made. City of Tyler may have existing infrastructure near the service area for this water user and that can be used to deliver supplies to Bullard’s customers. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water need projected for Bullard in Smith County projected by the East Texas Regional Planning Group during the planning period (2020-2070). The quantity of supply from this strategy represents a contract of 141 ac-ft per year in 2020, increasing to 1,182 ac-ft per year in 2070. The reliability of this water supply is considered high due to the availability of water in City of Tyler’s sources of supply. City of Tyler owns Lake Tyler and has a contract for water from Lake Palestine. In addition to this, the City also has groundwater supplies in the Smith County Carrizo Wilcox. City of Tyler will decide the appropriate source of supply that is in close proximity to the water user location. However, this strategy is dependent on coordination with the City of Tyler. Depending on the source of supply City of Tyler chooses for this water user, this strategy may be dependent on the completion of Tyler’s construction of transmission system to access the full amount of Lake Palestine supplies. This is a recommended water management strategy for City of Tyler in 2021 Regional Water Plan.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In



addition, a contract between Bullard and the City of Tyler should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries within Smith County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed ten miles of pipeline (the approximate distance from the City of Tyler supplies to Bullard’s service area in Smith County), a pump station with an intake, and a terminal storage tank (0.2 million gallon). The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the yield generated by the infrastructure required.

WUG STRATEGY:	Smith County - Bullard					
Quantity:	Purchase from City of Tyler					
CAPITAL COSTS	1,145	AF/Y	1.53 MGD			
Pipeline	Size	Quantity	Unit	Unit Price	Cost	
Pipeline Rural	10 in.	52,800	LF	\$54	\$2,851,000	
Right of Way Easements Rural (ROW)		52,800	LF	\$18	\$964,900	
Land and Surveying (10%)					\$96,000	
Engineering and Contingencies (30%)					\$855,000	
Subtotal of Pipeline					\$4,766,900	
Pump Station(s)						
Pump with intake	178 HP	1	LS	\$5,604,000	\$5,604,000	
Booster Pump Station	0 HP	1	LS	\$0	\$0	
Engineering and Contingencies (35%)					\$1,961,400	
Subtotal of Pump Station(s)					\$7,565,400	
Storage Tanks	0.2 MG	1	LS	\$942,000	\$942,000	
Engineering and Contingencies (35%)					\$330,000	
Subtotal of Storage Tanks					\$1,272,000	
Permitting and Mitigation					\$278,000	
Debt Service (3.5% for 20 years)					\$13,882,300	
Interest During Construction			12	Months	\$382,000	
TOTAL COST					\$14,264,000	
ANNUAL COSTS						
Debt Service (3.5% for 20 years)					\$1,004,000	
Operational Costs*					\$611,000	
Total Annual Costs					\$1,615,000	
UNIT COSTS (Until Amortized)						
Per Acre-Foot of treated water					\$1,410	
Per 1,000 Gallons					\$4.33	



UNIT COSTS (After Amortization)

Per Acre-Foot

\$573

Per 1,000 Gallons

\$1.76

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits municipal water users in Smith County and is expected to have a positive impact on their water supply security. City of Tyler’s supplies provide relief to the Carrizo Wilcox aquifer as more entities switch from groundwater to purchase water from City of Tyler. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the City of Tyler’s supplies will reduce demands on other water supplies in Smith and Anderson Counties and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for Bullard to purchase water from the City of Tyler was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	1,145 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	3	Moderate Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	2	Sponsor identified but uncommitted
Implementation Issues	4	Limited Risk

REFERENCES

Discussions with City of Tyler.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
 TECHNICAL MEMORANDUM FOR SMITH CRYSTAL SYSTEMS TEXAS, INC.**

Water User Group Name:	Smith County - Crystal Systems Texas, Inc.
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	SMTH-CYS
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	78 – 538 ac-ft per year (Varies) (0.07 – 0.48 MGD)
Implementation Decade:	2040
Development Timeline:	2040
Project Capital Cost:	\$2,531,000 (September 2018)
Annual Cost:	\$231,000
Unit Water Cost (Rounded):	\$429 per ac-ft (\$1.32 per 1,000 gallons)

PROJECT DESCRIPTION

The Crystal Systems Texas, Inc. system is located in northwestern Smith County and serves the unincorporated area surrounding Hideaway Lake. In 2018, the system had 2050 residential connections. The population is projected to increase from 4,343 persons in 2020 to 8,881 persons in 2070. The System is included as a W.U.G. in Smith County. The system’s current water supply consists of five water wells from the Carrizo-Wilcox Aquifer. The total rated capacity of these wells is 3,560 GPM, or 1,914 ac-ft/yr. The system is bounded on the north and southeast by the Lindale Rural WSC and on the east by the City of Lindale. The System does have a water conservation plan. The System is projected to have a water supply surplus of 558 ac-ft/yr in 2020 decreasing to a deficit of 816 ac-ft/yr in 2070.

SUPPLY DEVELOPMENT

Below tables show the detail of water supply and demand analysis:

	2020	2030	2040	2050	2060	2070
Population	3026	3384	3812	4324	4950	5715
Projected Water Demand	945	1045	1175	1331	1522	1757
Current Water Supply	1376	1376	1376	1376	1376	1376
Projected Supply Surplus (+)/Deficit (-)	431	331	201	45	-146	-381

Neches River Basin

	2020	2030	2040	2050	2060	2070
Population	1317	1657	2000	2372	2758	3166
Projected Water Demand	411	512	616	730	848	973
Current Water Supply	538	538	538	538	538	538
Projected Supply Surplus (+)/Deficit(-)	127	26	-78	-192	-310	-435



ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Smith County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning Four alternative strategies were considered to meet the Crystal System’s water supply shortages as summarized in the following table. Advanced conservation was not considered because the per capita use per day was below the 140 gpcd threshold set by the planning group. Water reuse was not considered because the system does not have a sewer collection system. Surface water alternatives were omitted since there is not a supply source within close proximity to the system and surface water treatment is not economically feasible for a system of this size. Wells in the Carrizo-Wilcox Aquifer (Sabine and Neches River Basins) were identified as a potentially feasible strategy for the WUG.

Strategy	Firm Yield (AF)	Total Capital Cost	Total Annualized Cost	Unit Cost	Environmental Impact
Advanced Water Conservation					
Water Reuse					
Groundwater (Sabine)	538	\$ 2,531,000	\$ 231,000	\$ 429	1
Groundwater (Neches)	538	\$ 2,531,000	\$ 231,000	\$ 429	1
Surface Water					

Recommendations:

	2020	2030	2040	2050	2060	2070
Drill New Wells (Carrizo-Wilcox Aquifer, Sabine; ac-ft/yr)	0	0	135	135	269	538
Drill New Wells (Carrizo-Wilcox Aquifer, Neches; ac-ft/yr)	0	0	135	135	269	538

The recommended strategy for Crystal Systems to meet their projected deficit of 78 ac-ft/yr in 2040 and 816 ac-ft/yr in 2070 would be to construct four additional water wells similar to their existing wells just prior to each decade as the deficits occur. The recommended supply source will be the Carrizo Wilcox Aquifer in Smith County. Four wells with rated capacity of 500 gpm each would provide approximately 269 acre-feet each. The Carrizo Wilcox Aquifer in Smith County is projected to have a more than ample supply availability to meet the needs of Crystal Systems for the planning period. During the planning period two wells will be drilled in the Carrizo Wilcox formation of the Sabine River Basin while two wells will be drilled into the Carrizo Wilcox formation of the Neches River Basin.



Given the increasing costs to comply with more stringent regulations and the decreasing reliability of groundwater as a future supply source due to quality issues in this region, it is recommended that groundwater supply systems consider combining resources and/or soliciting future water supply from neighboring systems and/or major water providers in the region. If a feasible alternative becomes available, then the recommendations previously discussed should be disregarded and a re-evaluation completed.

PROJECT EVALUATION

This strategy benefits municipal water users in Smith County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. Developing groundwater wells in Region D portion of Smith County will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for Crystal Systems to develop new groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	538 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Sponsor identified
Implementation Issues	4	Limited Risk

REFERENCES

Discussions with Region D.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
 TECHNICAL MEMORANDUM FOR SMITH LINDALE**

Water User Group Name:	Smith County - Lindale
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	SMTH-LIN
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	25 – 696 ac-ft per year (Varies) (0.02 – 0.62 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$7,592,000 (September 2018)
Annual Cost:	\$714,000
Unit Water Cost (Rounded):	\$370 per ac-ft (\$1.13 per 1,000 gallons)

PROJECT DESCRIPTION

The City of Lindale is located in northern Smith County and serves the incorporated city limits and an area immediately northwest of the City of Lindale. The population is projected to increase from 5,806 persons in 2020 to 13,985 persons in 2070. The City is included as a W.U.G. in Smith County. The system’s current water supply consists of four water wells from the Carrizo-Wilcox Aquifer. The total rated capacity of these wells is 2,320 GPM, or 1,247 ac-ft/yr. The system is bounded on the west, north, and east by the Lindale Rural WSC and on the south by the City of Tyler. The City does have a water conservation plan. The City of Lindale is projected to have a water supply deficit of 70 ac-ft/yr in 2020 increasing to a deficit of 1,833 ac-ft/yr in 2070.

SUPPLY DEVELOPMENT

Below tables show the detail of water supply and demand analysis:

Sabine River Basin	2020	2030	2040	2050	2060	2070
Population	3707	4499	5396	6107	7280	8674
Projected Water Demand	841	1005	1195	1347	1607	1910
Current Water Supply	796	779	773	756	762	773
Projected Supply Surplus (+)/Deficit(-)	-45	-226	-422	-591	-842	-1137

Neches River Basin	2020	2030	2040	2050	2060	2070
Population	2099	2704	3311	3964	4629	5311
Projected Water Demand	476	604	733	875	1020	1170
Current Water Supply	451	468	474	491	485	474
Projected Supply Surplus (+)/Deficit(-)	-25	-136	-259	-384	-535	-696



ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Smith County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

Four alternative strategies were considered to meet the City of Lindale’s water supply shortages as summarized in the following table. Advanced conservation was not considered because the per capita use per day was below the 140 gpcpd threshold set by the planning group. Water reuse was not considered because the City does not have a demand for non-potable water. Surface water alternatives were omitted since there is not a supply source within close proximity to the City and surface water treatment is not economically feasible for a system of this size. Groundwater wells in the Carrizo-Wilcox Aquifer in the Neches Basin were identified as a potentially feasible strategy for the City.

Strategy	Firm Yield (AF)	Total Capital Cost	Total Annualized Cost	Unit Cost	Environmental Impact
Advanced Water Conservation					
Water Reuse					
Groundwater	1,932	\$ 7,592,000	\$ 714,000	\$ 370	1
Surface Water					

Recommendations:

	2020	2030	2040	2050	2060	2070
Drill New Wells (Carrizo-Wilcox Aquifer, Neches; ac-ft/yr)	322	644	966	1288	1610	1932

The recommended strategy for the City of Lindale to meet their projected deficit of 70 ac-ft/yr in 2020 and 1,833 ac-ft/yr in 2070 would be to construct six additional water wells similar to their existing wells just prior to each decade as the deficits occur. The recommended supply source will be the Carrizo Wilcox Aquifer in Smith County. Six wells with rated capacity of 600 gpm each would provide approximately 322 acre-feet each. The Carrizo Wilcox Aquifer in Smith County (Neches River Basin) is projected to have a more than ample supply availability to meet the needs of the City of Lindale for the planning period.

Given the increasing costs to comply with more stringent regulations and the decreasing reliability of groundwater as a future supply source due to quality issues in this region, it is recommended that groundwater supply systems consider combining resources and/or soliciting future water supply from neighboring systems and/or major water providers in the region. If a feasible alternative becomes



available, then the recommendations previously discussed should be disregarded and a re-evaluation completed.

PROJECT EVALUATION

This strategy benefits municipal water users in Smith County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. Developing new groundwater wells in Smith County will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for Lindale to develop new groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	1,932 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Sponsor identified
Implementation Issues	4	Limited Risk

REFERENCES

Discussions with Region D.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR SMITH OVERTON**

Water User Group Name:	Smith - Overton
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	SMTH-OVN
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	68 – 407 ac-ft per year (Varies) (0.06 – 0.36 MGD)
Implementation Decade:	2020
Development Timeline:	2020 - 2070
Project Capital Cost:	\$8,849,000 (September 2018)
Annual Cost:	\$839,000
Unit Water Cost (Rounded):	\$2,061 per ac-ft (\$6.33 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for municipal water user Overton in Smith County and involves the development of new wells in the Carrizo Wilcox aquifer. Overton currently obtains most of its supply from Carrizo Wilcox. In addition to new wells, municipal conservation is another recommended strategy. Discussion on Conservation strategies is included in a separate technical memorandum. Overton has a small need starting in 2020 of approximately 70 ac-ft per year, and this need increases to 416 ac-ft per year by 2070. To meet this need, it is recommended that Overton continue to use supplies from Carrizo Wilcox by drilling additional wells. This strategy is a recommended strategy for Overton in Smith County and involves the development of two wells located within the Carrizo-Wilcox Aquifer as this aquifer has been identified as a potential source of water in Smith County. The wells will provide approximately 407 ac-ft per year and are assumed to have a depth of 600 feet. A peaking factor of two was assumed for the well, and the cost estimate includes conveyance infrastructure in order to capture the peak annual supply.

SUPPLY DEVELOPMENT

The supply would be required for the entirety of the planning cycle. Currently, all of the existing needs are being met by supplies from the Carrizo Wilcox aquifer. There are sufficient supplies available in the Smith County Carrizo Wilcox to develop the supply needed for this water management strategy. It is assumed that the wells along with municipal conservation will provide sufficient acre feet per year to meet Overton's needs in Smith County providing a total yield required for the strategy. Overall, the reliability of this supply is considered high, based on the proven use of this source and groundwater availability models.

ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Smith County.



PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 4 miles of pipeline, a pump station, and a terminal storage tank (0.09 million gallon). The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the yield generated by the infrastructure required.

WUG: Smith/Rusk County - Overton

WMS: Nacogdoches County - Carrizo Aquifer Wells

	Supply	416	Ac- ft/yr		258	gpm
	Depth to Water	300				
	Well Depth	600				
	Well Size	12	in			
	Wells Needed	2				

Construction Costs	Number	Unit Cost	Total Cost
Water Wells	2	\$461,866	\$923,732
Connection to Transmission System	2	\$50,000	\$100,000
Engineering and Contingencies (30% for pipelines, 35% for other items)			\$353,000
Subtotal of Well(s)			\$1,376,732

Transmission System	Size	Quantity	Unit	Unit Cost	Total Cost
Pipeline - Rural	8 in.	21,120	LF	\$40	\$839,000
Pump Station	71 HP 0.09	1	EA	\$3,844,000	\$3,844,000
Ground Storage Tank	MG	1	EA	\$429,605	\$429,605
Easement - Rural		21,120	LF	\$18	\$424,600
Engineering and Contingencies (30% for pipelines, 35% for other items)					\$1,747,000
Subtotal for Transmission		4	miles		7,284,205

Permitting and Mitigation	\$132,000
Construction Total	\$8,793,000
Interest During Construction	6 Months \$121,000
TOTAL CAPITAL COST	\$8,914,000

Debt Service (3.5% for 20 years)	\$627,000
Operational Costs*	\$218,700
Total Annual Cost	\$846,000



UNIT COSTS (Until Amortized)

Cost per ac-ft	\$2,034
Cost per 1000 gallons	\$6.24

UNIT COSTS (After Amortization)

Cost per ac-ft	\$526
Cost per 1000 gallons	\$1.61

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits Overton in Smith County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. Developing groundwater wells in Overton will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for Overton to develop new groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	416 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	2	Moderate Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	No Sponsor identified
Implementation Issues	4	No known risks

REFERENCES

Discussions with the East Texas Regional Water Planning Group (Region I).



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
 TECHNICAL MEMORANDUM FOR SMITH RPM WATER SUPPLY CORPORATION IN VAN ZANDT
 COUNTY**

Water User Group Name:	Smith County - R-P-M WSC
Strategy Name:	New wells in Carrizo-Wilcox Aquifer
Strategy ID:	PRM_WSC
Strategy Type:	New Groundwater Source
Potential Supply Quantity:	2 – 17 ac-ft per year (Varies) (0.01 – 0.02 MGD)
Implementation Decade:	2030
Development Timeline:	2030
Project Capital Cost:	\$3,469,000 (September 2018)
Annual Cost:	\$428,000
Unit Water Cost (Rounded):	\$1,972 per ac-ft (\$6.05 per 1,000 gallons)

PROJECT DESCRIPTION

R-P-M WSC provides water service in Van Zandt, Henderson and Smith Counties. The WUG population is projected to be 2,957 by 2020 and increases to 5,530 by 2070. R-P-M WSC supplies its customers with groundwater from the Carrizo-Wilcox and Queen City aquifers with five water wells in Van Zandt County. R-P-M WSC is projected to have a total deficit of 34 ac-ft/yr in 2030 increasing to a deficit of 217 ac-ft/yr by 2070; the shortage projected to occur in Van Zandt County is 25 ac-ft/yr in 2030 increasing to 152 ac-ft/yr by 2070. The shortage in Henderson County is 7 ac-ft/yr in 2030, increasing to 48 ac-ft/yr in 2070. Shortages in Smith County range from 2 ac-ft/yr in 2030 up to 17 ac-ft/yr in 2070.

SUPPLY DEVELOPMENT

Below tables show the detail of water supply and demand analysis:

RPM WSC	2020	2030	2040	2050	2060	2070
Population	2,957	3,602	4,112	4,653	5,116	5,530
Projected Water Demand	323	378	423	475	519	561
Water Demand from other entities	0	0	0	0	0	0
Current Water Supply	344	344	344	344	344	344
Projected Supply Surplus (+) / Deficit (-)	21	-34	-79	-131	-175	-217

Neches River Basin

Projected Supply Surplus (+) / Deficit (-)) by County	2020	2030	2040	2050	2060	2070
Van Zandt	14	-25	-58	-93	-124	-152
Henderson	5	-7	-16	-27	-38	-48
Smith	2	-2	-5	-11	-13	-17
Total	21	-34	-79	-131	-175	-217



ENVIRONMENTAL CONSIDERATIONS

The environmental impacts from this strategy are expected to be low. However, groundwater development from this source should be evaluated for potential impacts on spring flows and base flows of surface water in close proximity. The impact to the environment due to pipeline construction is expected to be temporary and minimal. New wells have a potential decrease in the groundwater-surface water nexus, which could reduce base flows. Impacts to environmental water needs, habitat, and cultural resources are expected to be low. There are no bays or estuaries in close proximity of Smith County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

Four alternative strategies were considered to meet the WSC's water supply shortages as summarized in the following table. Advanced conservation was not selected because the per capita use per day was less than the 140 gpcd threshold set by the water planning group. Water reuse was not considered because the WSC does not have a demand for non-potable water. Surface water was not considered because the WSC does not currently have surface water treatment. Groundwater has been identified as a potential strategy for R-P-M WSC.

Strategy	Firm Yield (AF)	Total Capital Cost	Total Annualized Cost	Unit Cost	Environmental Impact
Demand Reduction					
Water Reuse					
Drill New Wells (Carrizo-Wilcox Aquifer, Neches Basin)	217	\$3,469,000	\$428,000	\$1,972	1
Drill New Wells (Queen City Aquifer, Neches Basin)					

Recommendations:

	2020	2030	2040	2050	2060	2070
Drill New Wells (Carrizo-Wilcox, Neches Basin; ac-ft/yr)	0	34	79	131	175	217

The recommended strategy for R-P-M WSC to meet their projected deficit of 34 ac-ft/yr in 2030 and 217 ac-ft/yr in 2070 would be to construct nine additional water wells similar to their existing wells just prior to each decade as the deficits occur. The recommended supply source will be the Carrizo-Wilcox Aquifer in the Neches Basin in Van Zandt County. Nine wells with rated capacity of 50 gpm each, pumping at an approximately depth of 560 ft., would provide approximately 27 acre-feet each.

PROJECT EVALUATION

This strategy benefits municipal water users in Smith County and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources



or to key parameters of water quality. Developing supplies in Smith County will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for R P M WSC to develop new groundwater wells was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	217 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	2	Moderate to High Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	Sponsor identified
Implementation Issues	4	Limited Risk

REFERENCES

Discussions with Region D



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR SMITH WHITEHOUSE**

Water User Group Name:	Smith County - Whitehouse
Strategy Name:	Purchase from City of Tyler (Lake Palestine/Lake Tyler/Carrizo-Wilcox)
Strategy ID:	SMTH-WTH
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	39 – 257 ac-ft per year (Varies) (0.03 – 0.23 MGD)
Implementation Decade:	2060
Development Timeline:	2060 - 2070
Project Capital Cost:	\$7,666,000 (September 2018)
Annual Cost:	\$737,000
Unit Water Cost (Rounded):	\$2,868 per ac-ft (\$8.80 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Whitehouse in Smith County and involves a contract between Whitehouse and the City of Tyler for raw water. The cost for supply from the City of Tyler includes the cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the City of Tyler and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water need projected for Whitehouse in Smith County projected by the East Texas Regional Planning Group during the planning period (2020-2070). The quantity of supply from this strategy represents a contract of 39 ac-ft per year in 2060, increasing to 257 ac-ft per year in 2070. The reliability of this water supply is considered high due to the availability of water in City of Tyler’s sources of supply. City of Tyler owns Lake Tyler and has a contract for water from Lake Palestine. In addition to this, the City also has groundwater supplies in the Smith County Carrizo Wilcox. City of Tyler will decide the appropriate source of supply that is in close proximity to the water user location. However, this strategy is dependent on coordination with the City of Tyler.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between Whitehouse and the City of Tyler should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries within Smith County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed seven miles of pipeline (the approximate distance from the City of Tyler supplies to Whitehouse’s service area in Smith County), a pump station with an intake, and a terminal storage tank (0.05 million gallon). The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the yield generated by the infrastructure required.

WUG:	Smith County - Whitehouse					
STRATEGY:	Purchase from City of Tyler					
Quantity:	257	AF/Y	0.34	MGD		
CAPITAL COSTS						
Pipeline	Size	Quantity	Unit	Unit Price	Cost	
Pipeline Rural	6 in.	36,960	LF	\$25	\$939,000	
Right of Way Easements Rural (ROW)		36,960	LF	\$18	\$675,500	
Land and Surveying (10%)					\$68,000	
Engineering and Contingencies (30%)					\$282,000	
Subtotal of Pipeline					\$1,964,500	
Pump Station(s)						
Pump with intake	25 HP	1	LS	\$3,087,000	\$3,087,000	
Booster Pump Station	0 HP	1	LS	\$0	\$0	
Engineering and Contingencies (35%)					\$1,080,000	
Subtotal of Storage Tanks					\$4,167,000	
Storage Tanks	0.05 MG	1	LS	\$834,000	\$834,000	
Engineering and Contingencies (35%)					\$292,000	
Subtotal of Pump Station(s)					\$1,126,000	
Permitting and Mitigation					\$203,000	
Debt Service (3.5% for 20 years)					\$7,460,500	
Interest During Construction			12	Months	\$205,000	
TOTAL COST					\$7,666,000	
ANNUAL COSTS						
Debt Service (3.5% for 20 years)					\$539,000	
Operational Costs*					\$198,000	
Total Annual Costs					\$737,000	
UNIT COSTS (Until Amortized)						
Per Acre-Foot of treated water					\$2,868	
Per 1,000 Gallons					\$8.80	
UNIT COSTS (After Amortization)						
Per Acre-Foot					\$798	
Per 1,000 Gallons					\$2.45	



* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits Whitehouse in Smith County and is expected to have a positive impact on their water supply security. City of Tyler’s supplies provide relief to the Carrizo Wilcox aquifer as more entities switch from groundwater to purchase water from City of Tyler. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the City of Tyler’s supplies will reduce demands on other water supplies in Smith and Anderson Counties and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the recommended strategy for Whitehouse to purchase water from the City of Tyler was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	257 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	2	Moderate to High Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Sponsor Identified
Implementation Issues	4	No known risks

REFERENCES

Discussions with City of Tyler.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR SMITH MANUFACTURING**

Water User Group Name:	Smith Manufacturing
Strategy Name:	Purchase from City of Tyler
Strategy ID:	SMTH-MFG
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	84 ac-ft per year (0.08 MGD)
Implementation Decade:	2030
Development Timeline:	2030
Project Capital Cost:	\$6,198,000 (September 2018)
Annual Cost:	\$545,000
Unit Water Cost (Rounded):	\$6,488 per ac-ft (\$19.91 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Manufacturing in Smith County and involves a contract between individual manufacturing water users and the City of Tyler for raw water. City of Tyler already supplies to most of the manufacturing users in the Smith County so in some cases, it might just be an extension of the contract with current customers. This strategy will serve both the East Texas Region and North East Texas Region (Region D) manufacturing demand in Smith County. The cost for supply from the City of Tyler includes the contractual cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the City of Tyler and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water need projected for manufacturing in Smith County projected by the East Texas Regional Planning Group during the planning period (2020-2070). The quantity of supply from this strategy represents a contract of 84 ac-ft per year in 2030 continuing throughout the planning cycle to 2070. The reliability of this water supply is considered high due to the availability of water in City of Tyler's sources of supply. City of Tyler owns Lake Tyler and has contract for water from Lake Palestine. In addition to this, the City also has groundwater supplies in the Smith County Carrizo Wilcox. City of Tyler will decide the appropriate source of supply that is in close proximity to the water user location. However, this strategy is dependent on coordination with the City of Tyler. Depending on the source of supply City of Tyler chooses for this water user, this strategy may be dependent on the completion of Tyler's construction of transmission system to access the full amount of Lake Palestine supplies. This is a recommended water management strategy for City of Tyler in 2021 Regional Water Plan.



ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be temporary and minimal. In addition, a contract between manufacturing water users in Smith County and the City of Tyler should have a minimal impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries within Smith County.

PERMITTING AND DEVELOPMENT

There are no permitting or development issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed seven miles of pipeline (the approximate distance from the City of Tyler supplies to center of Smith County), a pump station with an intake, and a terminal storage tank (0.05 million gallon). The annual cost was estimated using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the yield generated by the infrastructure required.

WUG STRATEGY:	Smith County – Manufacturing Purchase from City of Tyler					
Quantity:	84	AF/Y		0.11		MGD
CAPITAL COSTS						
Pipeline		Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural		6 in.	36,960	LF	\$25	\$939,000
Right of Way Easements Rural (ROW)			36,960	LF	\$18	\$675,500
Land and Surveying (10%)						\$68,000
Engineering and Contingencies (30%)						\$282,000
Subtotal of Pipeline						\$1,964,500
Pump Station(s)						
Pump with intake		5 HP	1	LS	\$2,028,000	\$2,028,000
Booster Pump Station		0 HP	1	LS	\$0	\$0
Engineering and Contingencies (35%)						\$710,000
Subtotal of Storage Tanks						\$2,738,000
Storage Tanks		0.05 MG	1	LS	\$834,000	\$834,000
Engineering and Contingencies (35%)						\$292,000
Subtotal of Pump Station(s)						\$1,126,000
Permitting and Mitigation						\$203,000
Debt Service (3.5% for 20 years)						\$6,031,500
Interest During Construction				12	Months	\$166,000
TOTAL COST						\$6,198,000
ANNUAL COSTS						
Debt Service (3.5% for 20 years)						\$436,000
Operational Costs*						\$109,000
Total Annual Costs						\$545,000

UNIT COSTS (Until Amortized)



Per Acre-Foot of treated water	\$6,488
Per 1,000 Gallons	\$19.91

UNIT COSTS (After Amortization)

Per Acre-Foot	\$1,310
Per 1,000 Gallons	\$4.02

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits manufacturing water users in Smith County and is expected to have a positive impact on their water supply security. Since Tyler is already supplying to Smith County’s manufacturing demands, it would be easy to set up contracts with City of Tyler. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the City of Tyler’s supplies will reduce demands on other water supplies in Smith and Anderson Counties and will have no other apparent impact on other State water resources.

Based on the analyses provided above, the Smith County Manufacturing recommended strategy to purchase water from the City of Tyler was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	84 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	1	High Cost
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	No known impacts to other projects.
Threat to Agricultural Resources/Rural Areas	4	Low Impact
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	1	No sponsor identified
Implementation Issues	4	No known risks

REFERENCES

Discussions with City of Tyler.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
 TECHNICAL MEMORANDUM FOR ANRA LAKE COLUMBIA**

Project Name:	Lake Columbia
Project ID:	ANRA-COL
Project Type:	New Surface Water Source
Potential Supply Quantity (Rounded):	75,400 – 75,720 ac-ft per year (Varies) (67.3 – 67.6 MGD)
Implementation Decade:	2030
Development Timeline:	5-10 years
Project Capital Cost:	\$402,862,000 (September 2018)
Annual Cost:	\$23,509,000
Unit Water Cost (Rounded):	\$311 per ac-ft (\$0.95 per 1,000 gallons)

PROJECT DESCRIPTION

Angelina Neches River Authority is the sponsor for the Lake Columbia project on Mud Creek in Cherokee and Rusk Counties. Lake Columbia is a recommended strategy in the 2011 East Texas Regional Water Plan (ETRWP). Angelina Neches River Authority has been granted a water right permit (Permit No. 4228) by the TCEQ to impound 195,500 acre feet per year and to divert 85,507 acre feet per year (76.3 MGD) for municipal and industrial purposes. Angelina Neches River Authority currently has contracted with customers for 53 percent of the 85,507 ac-ft per year permit of the proposed Lake Columbia reservoir. The City of Dallas is also considering Lake Columbia as a recommended strategy. After considering the local needs in the East Texas Region, Dallas’ projected share of the proposed Lake Columbia project is 56,000 ac-ft per year by 2070. This water management strategy for Angelina Neches River Authority was developed to address the total current contracted and potential future customer demand through the construction of Lake Columbia. Angelina Neches River Authority holds the water right for the supply source and will be the project sponsor. It was specified in the 2014 Draft Dallas Long Range Supply Plan that Dallas will be responsible for 70 percent of the dam, reservoir land acquisition, and relocations, and Angelina Neches River Authority will be responsible for the remaining 30 percent of the reservoir construction and land acquisitions costs. This cost split is subject to change during the potential negotiations between Dallas and Angelina Neches River Authority. The Lake Columbia dam site is located two to three miles downstream of Highway 79 on Mud Creek in Cherokee County. The contributing drainage area for the reservoir is approximately 384 square miles. The total conservation pool volume is 195,500 acre feet per year and the top of conservation pool is at the elevation of 315 ft MSL. The conservation pool covers an area of approximately 10,133 acres and the flood pool covers an additional area of 1,367 acres.

CURRENT CONTRACTED AND POTENTIAL CUSTOMERS

Angelina Neches River Authority has contracts with several customers in East Texas Regional Planning Area. The water suppliers currently under contract with Angelina Neches River Authority are listed in Table 1 below along with the current participation percentage. Also included below is Table 2 showing the potential future customers for Angelina Neches River Authority and their corresponding demands. The contract amounts are based on the full permitted diversion. The development of infrastructure to deliver the water to the end users is discussed in separate strategies.

Customers for Lake Columbia



Recipient	County	Basin	Percent Participation in Columbia	Contract Amount (ac-ft per year)
Current Contracted Customers				
Afton Grove WSC, Stryker Lake WSC	Cherokee	Neches	4.5%	3,848
Jacksonville	Cherokee	Neches	5.0%	4,275
New Summerfield	Cherokee	Neches	3.0%	2,565
North Cherokee WSC	Cherokee	Neches	5.0%	4,275
Rusk	Cherokee	Neches	5.0%	4,275
Rusk Rural WSC	Cherokee	Neches	1.0%	855
City of Alto	Cherokee	Neches	0.5%	428
Caro WSC	Nacogdoches	Neches	0.5%	428
Nacogdoches	Nacogdoches	Neches	10.0%	8,551
New London	Rusk	Sabine	1.0%	855
Troup	Smith	Neches	5.0%	4,275
Arp	Smith	Neches	0.5%	428
Blackjack WSC	Smith	Neches	1.0%	855
Jackson WSC	Smith	Neches	1.0%	855
Whitehouse	Smith	Neches	10.0%	8,551
Additional Customers for Lake Columbia				
City of Dallas		Trinity		56,050

Table 2. Potential Future Customer Demand (ac-ft per year) for Lake Columbia

Recipient	2020	2030	2040	2050	2060	2070
Holmwood Utility	65	70	70	70	70	70
Steam Electric Demand – Cherokee	8,000	15,000	20,000	20,000	20,000	20,000
Manufacturing – Rusk County Refinery	5,600	5,600	5,600	5,600	5,600	5,600
Mining - Angelina	474	573	398	300	225	168
Mining - Cherokee	238	247	210	147	84	40
Mining - Nacogdoches	5,475	2,975	118	0	0	0
Mining – San Augustine	2,102	1,102	0	0	0	0
Mining – Rusk	1,075	2,092	1,955	1,809	1,686	1,677
Total Future Customer Demand	23,028	27,658	28,350	27,926	27,665	27,555

SUPPLY DEVELOPMENT

Firm yield for Lake Columbia was determined by means of the water availability analysis using the Neches Basin Water Availability Model (WAM). This model was downloaded from TCEQ website in 2009. The firm yield of the Lake was estimated to be 75,720 acre feet per year in 2030 and reducing to 75,400 acre feet per year in 2070. It should be noted that the water management strategies for the reservoir development and the transmission connections were all based on the firm supplies available from Lake Columbia.

ENVIRONMENTAL CONSIDERATIONS

The summary of environmental considerations was developed based on the known environmental factors

that have been discussed in the Draft Environmental Impact Study (DEIS).

Habitat – The footprint of Lake Columbia will impact approximately 5,746.5 acres of waters of the U.S., including 3,689 acres of forested wetlands and the remainder comprised of shrub and emergent wetlands (144 and 1,518 acres, respectively), open water, streams and a hillside bog.

Environmental Flows – The current TCEQ Permit No. 4228 allowing the construction and operation of Lake Columbia does not require any instream flow releases. However, if Dallas wants to move water from Lake Columbia in Neches Basin to Trinity River Basin, an amendment to the Permit is required to allow interbasin transfers. Amendments to the Permit may be subject to recently adopted instream flow standards.

Bays and Estuaries – Lake Columbia project is over 280 river miles upstream from the Neches estuary at Sabine Lake and is therefore expected to have no measureable effect on the fresh water inflows into Sabine Lake and Sabine Lake estuary. Recognizing the diminishing effect of upstream distance on bay and estuary inflows, the Texas Water Code (Section 11.147) requires consideration of such effects only if a proposed project is within 200 river miles of the coast.

Threatened and Endangered Species - The Lake Columbia project area includes six federally listed species, five of which are also listed by the state. The state lists fourteen additional species within Smith and Cherokee Counties where the lake would be developed.

Environmental Factors	Level of Concern
Habitat	High
Environmental Water Needs	Medium Impact
Bay and Estuaries	Low Impact
Threatened and Endangered Species	Low Impact
Wetlands	High (5,351.5 acres of wetlands)

PERMITTING AND DEVELOPMENT

Angelina Neches River Authority has a water right for Lake Columbia and is currently seeking a 404 permit for construction. A draft environmental impact study (DEIS) has been prepared for Lake Columbia by the USACE. The DEIS was published on January 29, 2010 and public and agency comments were provided on March 30, 2010. Currently, the Lake Columbia project is subject to completion of the EIS and issuance of a 404 permit from the U.S Army Corps of Engineers (USACE).

Lake Columbia is in the permitting phase, and has contracts with several local participants. According to Angelina Neches River Authority, the participants have the right of first refusal to contract for water in the next phase of the project. The Texas Water Development Board is a 47% participant and has the right of refusal for 35.9 MGD (40,188 acre feet per year) of supply. Process for water contracts will be initiated after the issuance of the Section 404 permit from the USACE.

If Dallas were to participate in the Lake Columbia project, the current permit no. 4228 has to be amended for an interbasin transfer from the Neches to the Trinity basin. There is a potential that the authorized diversions from Lake Columbia project may be subject to some reductions due to the environmental flow standards that may be applied during the amendment process.

Permit	Regulatory Entity	Potential Challenges
Water Right Permit Amendment	TCEQ	May require interbasin transfer authorization for Dallas to transfer water from Neches to Trinity basin.
404	USACE	Required to proceed with construction in waters of the US.



PLANNING LEVEL OPINION OF COST

Both Angelina Neches River Authority and participating entities will share in the costs associated with the Lake Columbia water management strategy. Construction costs are divided into three separate categories: reservoir, water treatment plant and transmission system. A planning level opinion of cost (PLOC) for the construction of the reservoir is included below. A planning level opinion of cost (PLOC) for the water treatment plant and distribution system is included in a separate Tech Memo. For reservoir construction, unit costs are based on the WAM Run 3 yield estimate of 75,720 ac-ft per year. The detailed cost estimate below represents the total cost for the construction of the project. It was noted in the Dallas Long Range Supply Plan that Dallas will bear responsibility for 70 percent of reservoir construction and relocation costs and Angelina Neches River Authority will be responsible for the remaining 30 percent. However, the actual percent distribution of the project cost will be determined based on the future negotiations between Angelina Neches River Authority and other participants. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WWPNAME: ANRA
STRATEGY: Lake Columbia
AMOUNT (ac-ft/yr): 75,720

Dam	Cost
Embankment	\$32,037,700
Internal Drainage	\$769,107
Slope Protection & Crest Roadway	\$5,411,955
Service Spillway	\$7,476,287
Outlet Works	\$1,532,309
Instrumentation	\$812,378
Miscellaneous Items	\$6,226,744
Engineering	\$8,856,606
Contingencies	\$10,853,320
Sub Total for Dam	\$73,976,406
Transportation Conflicts	
Roads	\$3,850,237
Highways	\$42,063,937
Railroads	\$35,612,042
Erosion Protection	\$5,183,911
Engineering	\$13,603,352
Contingencies	\$17,341,977
Subtotal for Transportation Conflicts	\$117,655,457
Utility Conflicts	
Communications	\$3,158,631
Electric Utilities	\$18,945,279
Oil and Gas	\$4,735,054
Water Utilities	\$199,961
Engineering	\$81,117
Contingencies	\$5,407,737
Subtotal for Utility Conflicts	\$32,527,778
Project Site Acquisition	
Property Purchase	\$28,698,031
Conservation Easement	\$2,079,519
Survey and Appraisal	\$1,627,287
Professional Fees	\$944,721

Engineering	\$1,024,994
Contingencies	\$6,669,936
Sub Total for Project Site Acquisition	\$41,044,488

Mitigation	
Mitigation	\$107,357,398
Contingencies	\$9,098,150
Sub Total for Mitigation	\$116,455,548

Cultural Resources	
Archeological/Historical Resources	\$17,379,101
Engineering	\$347,611
Contingencies	\$3,475,868
Sub Total for Cultural Resources	\$21,202,580

TOTAL CONSTRUCTION COST \$402,862,000

ANNUAL COSTS	
Debt Service for Reservoirs (3.5% for 40 years)	\$11,832,272
Debt Service for Relocations (3.5% for 20 years)	\$10,567,054
Operation & Maintenance	\$1,109,600
Total Annual Costs	\$23,509,000

UNIT COSTS (Until Amortized)	
Per Acre-Foot of treated water	\$311
Per 1,000 Gallons	\$0.95

UNIT COSTS (After Amortization)	
Per Acre-Foot	\$14.7
Per 1,000 Gallons	\$0.04



PROJECT EVALUATION

Based on the analysis provided above, the Lake Columbia Reservoir Construction project was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	75,600 acre feet per year
Reliability	4	Reliable Supply
Cost	4	Medium Cost
Environmental Factors	3	Medium Impacts
Impact on Other State Water Resources	4	No Impacts
Threat to Agricultural Resources/Rural Areas	4	No Impacts
Interbasin Transfers		Yes, if Dallas uses the Supplies
Other Natural Resources	4	No Impacts
Major Impacts on Key Water Quality Parameters	4	No Impacts
Political Feasibility	4	Local Sponsor is ANRA
Implementation Issues	3	Contract with City of Dallas

REFERENCES

October 2014 Draft Dallas Long Range Water Supply Plan.
 2016 East Texas Regional Plan.

ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS TECHNICAL MEMORANDUM FOR ANRA WTP

Project Name:	ANRA Treatment Plant and Distribution System
Project ID:	ANRA-WTP
Project Type:	Existing Surface Water Source
Potential Supply Quantity (Rounded):	0 ac-ft per year (0 MGD)
Implementation Decade:	2020
Development Timeline:	5 years
Project Capital Cost:	\$228,001,000 (September 2018)
Project Annual Cost:	\$49,839,000
Unit Water Cost (Rounded):	\$2,242 per ac-ft (during loan period) \$6.88 per 1,000 gallons

PROJECT DESCRIPTION

Angelina Nacogdoches River Authority is the sponsor for the Lake Columbia project on Mud Creek in Cherokee and Rusk Counties. Lake Columbia is a recommended strategy in the 2011 East Texas Regional Water Plan (ETRWP). Angelina Neches River Authority has been granted a water right permit (Permit No. 4228) by the TCEQ to impound 195,500 acre feet per year and to divert 85,507 acre feet per year (76.3 MGD) for municipal and industrial purposes. Angelina Neches River Authority currently has contracted customers for 53 percent of the 85,507 ac-ft per year permit of the proposed Lake Columbia reservoir. This water management strategy for Angelina Neches River Authority was developed to address the current contracted demand for the customers receiving treated water from this wholesale provider.

Angelina Neches River Authority has contracts with several customers in East Texas Regional Planning Area. The water suppliers currently under contract with Angelina Neches River Authority are listed in Table below along with the current participation percentage. It is assumed that Afton Grove WSC, Stryker Lake WSC, New Summerfield, and all municipal customers in Smith County will purchase treated water from Angelina Neches River Authority. Therefore, a recommended water management strategy for Angelina Neches River Authority is to construct a Water Treatment Plant and the distribution system to supply treated water to these customers. Transmission system costs are shared among the contracted suppliers that receive treated water.

SUPPLY DEVELOPMENT

The cities of Nacogdoches, Jacksonville, and Rusk are assumed to purchase raw water from Lake Columbia and develop their own raw water transmission and treatment facilities. Most of the municipal water users (and current customers of Angelina Neches River Authority) in Cherokee, Rusk, and Smith Counties will be purchasing treated water from Angelina Neches River Authority. Costs for water treatment and transmission system are shared among currently contracted entities that are assumed to buy treated water from Angelina Neches River Authority.

STRATEGY DESCRIPTION

The purpose of this water management strategy is to develop a treatment facility to treat the supplies delivered to potential municipal customers purchasing treated water from Angelina Neches River Authority. The municipal customers are Stryker WSC, Afton Grove WSC, Jackson WSC, Blackjack WSC, City of New Summerfield, City of New London, City of Troup, City of Arp, and City of Whitehouse.



ENVIRONMENTAL CONSIDERATIONS

There are no significant environmental considerations associated with the treatment plant construction and the transmission system strategy.

PERMITTING AND DEVELOPMENT

There are no permitting issues associated with the construction of the water treatment facilities and the transmission facilities.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for the water treatment plant and distribution system is included below. Construction costs include the construction of water treatment plant, pipeline segments, pump station and storage tank to deliver the supplies. The annual costs were estimated assuming 3.5% interest rate over a period of 20 years. The planning level opinion of probable construction cost estimates also include cost of purchase of raw water and treated water from Angelina Neches River Authority. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WWPNAME:	ANRA					
STRATEGY:	Regional Water Treatment Facilities					
Quantity:	0	AF/Y	30 MGD		Peak	
CONSTRUCTION COSTS						
Pipeline	Size	Quantity	Unit	Unit Price	Cost	
Segment A: WTP to Troup	30 in.	57,771	LF	\$197	\$11,374,000	
Segment B: Troup to Arp	12 in.	36,610	LF	\$68	\$2,500,000	
Segment C: Troup to Whitehouse & Jackson WSC	24 in.	40,879	LF	\$154	\$6,296,000	
Segment D: Arp to New London & Blackjack WSC	8 in.	42,398	LF	\$40	\$1,683,000	
Segment E: WTP to New Summerfield	18 in.	1,916	LF	\$111	\$213,000	
Pipeline Segments Subtotal					\$22,066,000	
Right of Way Easements Rural (ROW)		179,573	LF	\$30	\$5,391,500	
Land and Surveying (10%)					\$539,150	
Engineering and Contingencies (30%)					\$6,620,000	
Subtotal of Pipeline					\$34,616,650	
Pump Station(s)						
Pump with intake & building	3157 HP	2	LS	\$37,283,000	\$74,566,000	
Engineering and Contingencies (35%)					\$26,098,100	
Subtotal of Pump Station(s)					\$100,664,100	
Water Treatment Plant	30 MGD	1	LS	\$61,736,000	\$61,736,000	
Storage Tanks	3.7 MG	1	LS	\$1,715,865	\$1,716,000	
Engineering and Contingencies (35%)					\$22,208,200	
Subtotal					\$85,660,200	
Permitting and Mitigation					\$957,746	
Construction Total					\$221,898,696	
Interest During Construction			12	Months	\$6,102,000	
TOTAL COST					\$228,001,000	



ANNUAL COSTS

Debt Service (3.5% for 20 years)			\$16,042,000
Electricity (\$0.08 kWh)			\$1,149,000
Operational Costs*			\$33,797,300
Raw Water Purchase	1000 gal	\$1.00	\$7,244,000
Treatment	1000 gal	\$3.00	\$21,733,000
Total Annual Costs			\$49,839,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water	\$2,242
Per 1,000 Gallons	\$6.88

UNIT COSTS (After Amortization)

Per Acre-Foot	\$1,520
Per 1,000 Gallons	\$4.67

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

Based on the analysis provided above, the Angelina Neches River Authority Regional Water Treatment Facilities project was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.



Criteria	Rating	Explanation
Quantity	4	22,232 ac-ft per year
Reliability	3	Highly Reliable Supply
Cost	2	Medium to High Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Local Sponsorship by ANRA
Implementation Issues	3	Dependent on Lake Columbia Construction

REFERENCES

2011 East Texas Regional Plan



ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS TECHNICAL MEMORANDUM FOR ANRA GW WELLS

Project Name:	ANRA Groundwater Wells
Project ID:	ANRA-GW
Project Type:	New Groundwater Source
Potential Supply Quantity (Rounded):	5,600 ac-ft per year (5 MGD)
Implementation Decade:	2020
Development Timeline:	3 years
Project Capital Cost:	\$29,775,000 (September 2018)
Annual Cost:	\$3,185,000
Unit Water Cost (Rounded):	\$569 per ac-ft (\$1.75 per 1,000 gallons)

PROJECT DESCRIPTION

Angelina Neches River Authority will plan to develop groundwater wells in Cherokee and Rusk counties to supply water to manufacturing demand in Rusk County. Angelina Neches River Authority will develop approximately 5,600 ac-ft per year.

SUPPLY DEVELOPMENT

The supply for this strategy comes from Carrizo Wilcox aquifer in Cherokee and Rusk counties. Based on the supplies reported in the Modeled Available Groundwater (MAG) reports, there are sufficient groundwater supplies available in Cherokee and Rusk counties for this strategy. It was noted that developing this strategy will not result in over allocation of groundwater supplies in those counties.

ENVIRONMENTAL CONSIDERATIONS

There are no significant environmental considerations associated with the treatment plant construction and the transmission system strategy.

PERMITTING AND DEVELOPMENT

There are no permitting issues associated with the construction of the water treatment facilities and the transmission facilities.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for the constructing new wells, transmission system and storage is included below. The annual costs were estimated assuming 3.5% interest rate over a period of 20 years. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.



WWP: ANRA - New Ground Water Wells

WMS: New Wells in Cherokee and Rusk Counties

Supply	5,600	Ac-ft/yr	3,472	gpm
Depth to Water	300	ft		
Well Depth	1,000	ft		
Well Yield	200	gpm		
Well Size	12	in		

Construction Costs	Number	Unit Cost	Total Cost
Water Wells	18	\$559,437	\$10,069,861
Connection to Transmission System	18	\$50,000	\$900,000
Engineering and Contingencies (30% for pipelines, 35% for other items)			\$3,794,000
Subtotal of Well(s)			\$14,763,861

Transmission System	Size	Quantit y	Unit	Unit Cost	Total Cost
Pipeline - Rural	24 in.	26,400	LF	\$154	\$4,066,000
Pump Station	890 HP	1	EA	\$5,450,000	\$5,450,000
Ground Storage Tank	0.63 MG	1	EA	\$630,505	\$630,505
Easement - Rural		26,400	LF	\$18	\$482,500
Land and Surveying Rural (10%)					\$48,250
Engineering and Contingencies (30% for pipelines, 35% for other items)					\$3,348,000
Subtotal for Transmission		5	miles		\$14,025,255

Permitting and Mitigation				\$189,000
Construction Total				\$28,978,116
Interest During Construction	12	Months		\$797,000
TOTAL CAPITAL COST				\$29,775,000

Debt Service (3.5% for 20 years)				\$2,095,000
Operational Costs*				\$1,090,490
Total Annual Cost				\$3,185,000

UNIT COSTS (Until Amortized)

Cost per ac-ft	\$569
Cost per 1000 gallons	\$1.75

UNIT COSTS (After Amortization)

Cost per ac-ft	\$195
Cost per 1000 gallons	\$0.60

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.



PROJECT EVALUATION

Based on the analysis provided above, the ANRA Groundwater Wells project was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	5,600 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	3	Low to Medium Costs
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Local Sponsorship by ANRA
Implementation Issues	4	No known Implementation Risks

REFERENCES

Discussions with Angelina Neches River Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR ANWCID#1 LAKE STRIKER**

Project Name:	Volumetric Survey and Normal Pool Elevation Adjustment
Project ID:	ANCD-VOL
Project Type:	Existing Surface Water Source
Potential Supply Quantity (Rounded):	5,600 ac-ft per year (5 MGD)
Implementation Decade:	2040
Development Timeline:	5 years
Project Capital Cost:	\$23,716,000
Unit Water Cost (Rounded):	\$476 per ac-ft \$1.46 per 1,000 gal

PROJECT DESCRIPTION

Internal studies conducted by Angelina Nacogdoches WCID #1 resulted in higher yield estimates for Lake Striker than those obtained from the Water Availability Model. Angelina Nacogdoches WCID #1 believes that the additional yield in Lake Striker is sufficient to meet the shortages manifested for this entity in this planning cycle. To address this inconsistency, Angelina Nacogdoches WCID #1 is considering a recommended strategy to conduct volumetric survey of Lake Striker to determine the Lake yield. Angelina Nacogdoches WCID #1 will coordinate with TWDB to get on a schedule for the lake volumetric survey. Angelina Nacogdoches WCID #1 believes that the volumetric survey will result in an additional yield that will address shortages in the first two decades. To address the shortages in the later decades, a recommended strategy was proposed. The strategy is to work with the Texas Water Development Board on the Normal Pool Elevation Adjustment of Lake Striker. The timing for the volumetric surveys and potential normal pool elevation adjustment is 2040.

SUPPLY DEVELOPMENT

At this time it is not known how much (if any) additional yield will be realized from the normal pool elevation adjustment but for planning purposes it is assumed to be 5,600 acre-feet per year.

ENVIRONMENTAL CONSIDERATIONS

No known environmental considerations at this time but these would be studied in further details during the volumetric survey process.

PERMITTING AND DEVELOPMENT

The process for volumetric survey and adjusting of the normal pool elevation may require some significant coordination with the Texas Water Development Board and Texas Council on Environmental Quality on permitting and development issues.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) was not developed for this strategy. TWDB will charge a fixed fee for conducting volumetric surveys. A cost estimate is not included for this strategy, as this cost will be determined by Angelina Nacogdoches WCID #1 during their negotiations with TWDB.



PROJECT EVALUATION

The addition of the additional yield from Lake Striker will help address the shortages in Angelina Nacogdoches WCID #1's customer demands.

The recommended strategy for infrastructure improvements was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity		NA
Reliability		NA
Cost	5	No Significant Costs
Environmental Factors	4	No Impacts
Impact on Other State Water Resources	4	No Impacts
Threat to Agricultural Resources/Rural Areas	4	No Impacts
Interbasin Transfers		No
Other Natural Resources	4	No Impacts on other natural resources
Major Impacts on Key Water Quality Parameters	4	No Impacts
Political Feasibility	4	AN WCID#1 is local sponsor committed to the strategy
Implementation Issues	4	No known risks

REFERENCES

Discussions with Angelina Nacogdoches WCID #1.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR ATHENS MWA FISH HATCHERIES**

Water User Group Name:	Athens MWA
Strategy Name:	Indirect Reuse of Flows from Fish Hatcheries
Strategy ID:	AMWA-FH
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	2,872 ac-ft per year (2.6 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$0 (September 2018)
Annual Cost:	\$0 per ac-ft
Unit Water Cost (Rounded):	\$0 per ac-ft (\$0 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Athens MWA. The strategy involves an indirect reuse project from the flows returned by the Fish Hatcheries to Lake Athens. Athens MWA has a contract to supply 3,023 acre feet per year to the Fish Hatcheries. The Fish Hatcheries have a separate intake on Lake Athens to access the lake supplies. Currently, approximately 95 to 100 percent of the diverted water for the Fish Hatchery is returned to Lake Athens; however, the Fish Hatchery is under no contractual obligations to continue this practice. To assure adequate supplies for the fish hatchery and other uses, Athens MWA should work with the fish hatchery to assure that the hatchery continues to return diverted water to Lake Athens for subsequent reuse. For purposes of this plan, it is assumed that 95 percent of the contracted water will be returned. This equates to 2,872 ac-ft per year of additional supply. Athens MWA has to apply for a permit amendment on their permit to provide water to fish hatcheries to be able to utilize the flows returned by the fish hatcheries.

SUPPLY DEVELOPMENT

The fish hatcheries return approximately 95 to 100 percent of the water diverted from Lake Athens. Assuming that 95% of the water is returned, approximately 2,872 acre feet per year of supplies can be developed from this strategy.

ENVIRONMENTAL CONSIDERATIONS

The yield of this strategy will be dependent upon negotiations with the TCEQ regarding environmental flow requirements. Environmental flow requirements will be set so the new permit has a minimum impact to environmental water needs and the surrounding habitat. No impacts to cultural resources in the area are expected.

PERMITTING AND DEVELOPMENT

Athens MWA has to apply for an amendment to their permit to supply water to the fish hatcheries. This amendment will allow them to utilize the water returned by the fish hatcheries to Lake Athens. Previous attempts of working with TCEQ on the permit amendment have not been successful. Athens MWA is hopeful that the amendment will be approved during the planning period. This permit amendment is dependent upon coordination with the TCEQ.



PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) was not prepared for this strategy because costs associated with the permit amendment are considered minimal. Any costs incurred by Athens MWA will be related to engineering and lawyer fees.

PROJECT EVALUATION

The recommended strategy for infrastructure improvements was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	2,872 acre feet per year
Reliability	4	Highly Reliable Supply
Cost	5	No Cost (Excluding Administrative and Lawyer Fees)
Environmental Factors	4	Low to No Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No Impacts on other natural resources
Major Impacts on Key Water Quality Parameters	4	No Major Impacts
Political Feasibility	4	Athens MWA is the Local Sponsor. Sponsor is committed.
Implementation Issues	3	Requires agreement with Fish Hatcheries

REFERENCES

2011 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR ATHENS MWA ADDITIONAL CARRIZO-WILCOX
GROUNDWATER**

Water User Group Name:	Athens MWA - Additional Carrizo-Wilcox Groundwater
Alternative Strategy Name:	Groundwater Supply Expansion
Alternative Strategy ID:	AMWA-AGW
Alternative Strategy Type:	New Groundwater Source
Potential Supply Quantity:	2,000 ac-ft per year (Varies) (1.78 MGD)
Implementation Decade:	2040
Development Timeline:	2040
Project Capital Cost:	\$15,151,000 (September 2018)
Annual Cost:	\$1,885,000 per ac-ft
Unit Water Cost (Rounded):	\$ 941 per ac-ft (\$ 2.89 per 1,000 gallons)

PROJECT DESCRIPTION

Athens MWA is currently pursuing developing groundwater from the Carrizo-Wilcox aquifer on property near Lake Athens. It is anticipated that 17 new wells (with a capacity of 250 gallons per minute each) will be drilled to provide around 1.78 MGD of groundwater supply. The water would be transported directly from the well field to the distribution system. It should be noted that although Athens MWA has permits to develop the wells, this strategy cannot be included in the 2021 Regional Plan as a recommended strategy because of the MAG limitations.

SUPPLY DEVELOPMENT

Current use in the Carrizo-Wilcox aquifer in Henderson County (both in Region C and I) is near the MAG for the county. Therefore, the groundwater wells are included as an alternative strategy for Athens MWA in the 2021 Regional Plan. The strategy will be changed to a recommended strategy when the MAG volumes are updated in the near future. Currently there is an unmet need of 5,567 ac-ft per year in 2070 for Athens MWA. Since this is a primary strategy for Athens MWA, the 2021 Regional Plan will show shortages for Athens MWA, which in reality will be addressed by the well field development.

ENVIRONMENTAL CONSIDERATIONS

No environmental issues identified.

PERMITTING AND DEVELOPMENT

Athens MWA already has permits to drill the wells. The yield from the new wells is above the MAG limits for Henderson County in Regions C and I. If and when the MAG numbers are updated, the yield from the wells will be compared with the MAG availability and the project will be converted to a recommended strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) is provided below. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.



Cost Estimate Summary	
Water Supply Project Option	
September 2018 Prices	
Athens - New Well(s) in Carrizo-Wilcox Aquifer	
Cost based on ENR CCI 11170.28 for September 2018 and a PPI of 201.9 for September 2018	
Item	Estimated Costs for Facilities
CAPITAL COST	
Transmission Pipeline (16 in dia., 5 miles)	\$2,551,000
Primary Pump Stations (3.6 MGD)	\$50,000
Well Fields (Wells, Pumps, and Piping)	\$8,025,000
Disinfection Facilities (3.6 MGD)	\$225,000
TOTAL COST OF FACILITIES	\$10,851,000
Engineering and Feasibility Studies, Legal Assistance, Financing, Bond Counsel, and Contingencies (30% for pipes & 35% for all other facilities)	\$3,670,000
Environmental & Archaeology Studies and Mitigation	\$312,000
Land Acquisition and Surveying (36 acres)	\$112,000
Interest During Construction (3% for 0.5 years with a 0.5% ROI)	<u>\$206,000</u>
TOTAL COST OF PROJECT	\$15,151,000
ANNUAL COST	
Debt Service (3.5 percent, 20 years)	\$1,066,000
Operation and Maintenance	
Pipeline, Wells, and Storage Tanks (1% of Cost of Facilities)	\$106,000
Intakes and Pump Stations (2.5% of Cost of Facilities)	\$1,000
Disinfection Facilities	\$135,000
Pumping Energy Costs (1097876 kW-hr @ 0.08 \$/kW-hr)	\$88,000
Purchase of Water (2000 acft/yr @ 244.38825 \$/acft)	<u>\$489,000</u>
TOTAL ANNUAL COST	\$1,885,000
Available Project Yield (acft/yr)	2,000
Annual Cost of Water (\$ per acft), based on PF=2	\$943
Annual Cost of Water After Debt Service (\$ per acft), based on PF=2	\$410
Annual Cost of Water (\$ per 1,000 gallons), based on PF=2	\$2.89
Annual Cost of Water After Debt Service (\$ per 1,000 gallons), based on PF=2	\$1.26



PROJECT EVALUATION

The recommended strategy for infrastructure improvements was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	2,000 acre feet per year
Reliability	2	Not reliable because of MAG overallocation
Cost	2	Low Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No Impacts on other natural resources
Major Impacts on Key Water Quality Parameters	4	No Major Impacts
Political Feasibility	4	City of Athens is the local sponsor committed to implement the strategy
Implementation Issues	1	Supply from this strategy reaches or exceeds MAG limits for Henderson County in Regions C and I.

REFERENCES

Discussions with Region C.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR ATHENS MWA GROUNDWATER SUPPLY EXPANSION**

Water User Group Name:	Athens MWA
Alternative Strategy Name:	Groundwater Supply Expansion
Alternative Strategy ID:	AMWA-GWE
Alternative Strategy Type:	New Groundwater Source
Potential Supply Quantity:	200 ac-ft per year (0.18 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$2,573,000 (September 2018)
Annual Cost:	\$218,000 per ac-ft
Unit Water Cost (Rounded):	\$1,090 per ac-ft (\$3.35 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is an alternate strategy for Athens MWA. The strategy involves addition of new groundwater wells in the Carrizo Wilcox aquifer in Henderson County. Athens MWA is currently pursuing developing groundwater from Carrizo Wilcox aquifer on the property near Lake Athens. The water would be transported directly from the well field to the distribution system. The Carrizo Wilcox in Henderson County (both in Region C and I) is severely limited by its availability for additional wells. Therefore, the groundwater wells is included as an alternate strategy for Athens MWA in the 2021 Regional Plan. The strategy will be changed to a recommended strategy if the MAG volumes are updated in the near future.

SUPPLY DEVELOPMENT

The City of Athens and Athens MWA are considering increasing the groundwater supply capacity that pumps directly into their distribution system. This strategy consists of developing infrastructure to increase this groundwater supply, including a new well (with a capacity of 250 gallons per minute), ground storage tank, and booster pump station.

ENVIRONMENTAL CONSIDERATIONS

No environmental issues identified.

PERMITTING AND DEVELOPMENT

Athens MWA already has permits to drill the wells. The yield from the new wells is above the MAG limits for Henderson County in Regions C and I. If and when the MAG numbers are updated, the yield from the wells will be compared with the MAG availability and the project will be converted to a recommended strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) is provided below. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.



WWP: Athens MWA
WMS: Groundwater Supply Expansion
 Supply 200 Ac-ft/yr 250 gpm

Construction Costs	Size	Quantity	Unit Cost	Total Cost
New Well	250 gpm	1	\$500,000	\$500,000
Booster Pump Station, Connection to Distribution System		1	\$128,000	\$128,000
Ground Storage Tank	0.30 MG	1	\$565,000	\$565,000
Contingencies (35%)				\$418,000
Subtotal of Well, Pump Station, and Storage Tank				\$1,611,000

Construction Allowance (5%)				\$80,550
Mobilization (5%)				\$84,578
Overhead and Profit (18%)				\$320,000
Construction Total				\$2,096,000

Professional Services/Engineering, Construction (20%)				\$419,000
Interest During Construction		12 Months		\$58,000
TOTAL CAPITAL COST				\$2,573,000

Debt Service (3.5% for 20 years)				\$181,000
Operational Costs*				\$36,600
Disinfection	65,170	\$0.30	per 1000 gal	\$19,600
Total Annual Cost				\$218,000

UNIT COSTS (First 30 Years)

Cost per ac-ft				\$1,090
Cost per 1000 gallons				\$3.35

UNIT COSTS (After 30 Years)

Cost per ac-ft				\$183
Cost per 1000 gallons				\$0.56

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

The recommended strategy for infrastructure improvements was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	200 acre feet per year
Reliability	4	Reliable
Cost	3	Moderate Cost



Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No Impacts on other natural resources
Major Impacts on Key Water Quality Parameters	4	No Major Impacts
Political Feasibility	4	Athens MWA is the local sponsor committed to implement the strategy
Implementation Issues	4	No Known Issues

REFERENCES

Discussions with Athens Municipal Water Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR ATHENS MWA PUMP STATION**

Water User Group Name:	Athens MWA
Strategy Name:	WTP Booster PS Improvement
Strategy ID:	AMWA-BSI
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	450 ac-ft per year (0.4 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$65,000 (September 2018)
Annual Cost:	\$57,000 per ac-ft
Unit Water Cost (Rounded):	\$127 per ac-ft (\$.39 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Athens MWA. The strategy involves infrastructure improvements at the water treatment plant owned by Athens MWA. The improvements will be applied to the existing booster pump station located at the water treatment plant.

Existing treatment capacity for City of Athens is 8 MGD, with a 7.5 MGD treated water pipeline to the city of Athens. The total yield from Lake Athens and the groundwater well at the WTP property is approximately 6 MGD. The WTP has sufficient capacity to treat the current supplies. Since the future supply from the groundwater wells will be directly added to the distribution system, there is no need for WTP capacity improvements. However, the Booster pump station at the WTP is limited by its capacity (5 MGD) and age. Athens MWA plans to replace the existing pump station with a new 8 MGD pump station. Therefore, the recommended water management strategy for Athens MWA is to address the booster pump station infrastructure improvements at the WTP.

In this strategy, the existing booster pump station will be replaced by a new booster pump station of 6 MGD average capacity and 9 MGD peak capacity.

SUPPLY DEVELOPMENT

No additional supplies associated with this strategy. This strategy will ensure access to the permitted supply from Lake Athens and the amount that is treated at the water treatment plant.

ENVIRONMENTAL CONSIDERATIONS

No known environmental impacts associated with this strategy.

PERMITTING AND DEVELOPMENT

No permitting issues associated with this strategy.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for the infrastructure improvements is provided below. Overall, this strategy has a low cost compared to other strategies in the 2021 East Texas Regional Water Plan.



WWP:	Athens MWA					
WMS:	Booster PS Improvements at WTP					
Amount	450	Ac-ft/yr		0.60	MGD	
Construction Costs		Size	Quantity	Unit Cost		Total Cost
Pump Replacement at WTP		1600 gpm	1	\$30,000		\$30,000
Contingencies (35%)						\$11,000
Subtotal of Well(s)						\$41,000
Construction Allowance (5%)						\$2,000
Mobilization (5%)						\$2,000
Overhead and Profit (18%)						\$8,000
Construction Total						\$53,000
Professional Services/Engineering, Construction (20%)						\$11,000
Interest During Construction			12	Months		\$1,000
TOTAL CAPITAL COST						\$65,000
Debt Service (3.5% for 20 years)						\$5,000
Operational Costs*						\$52,000
Total Annual Cost						\$57,000
 UNIT COSTS (First 30 Years)						
Cost per ac-ft						\$127
Cost per 1000 gallons						\$0.39
 UNIT COSTS (After 30 Years)						
Cost per ac-ft						\$116
Cost per 1000 gallons						\$0.36

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

The recommended strategy for infrastructure improvements was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	450 acre-feet per year
Reliability	4	Highly Reliable Supply



Cost	4	Low Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No Impacts on other natural resources
Major Impacts on Key Water Quality Parameters	4	No Major Impacts
Political Feasibility	5	Athens MWA is the identified sponsor committed to the strategy
Implementation Issues	4	No known risk

REFERENCES

Discussions with Athens Municipal Water Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR CITY OF CENTER REUSE PIPELINE**

Project Name:	City of Center Reuse Pipeline from WWTP to Lake Center
Project ID:	CENT-REU
Project Type:	Existing Surface Water Source
Potential Supply Quantity (Rounded):	1,121 ac-ft/yr (1 MGD)
Implementation Decade:	2020
Development Timeline:	5 years
Project Capital Cost:	\$18,110,000 (September 2018)
Project Annual Cost:	\$1,927,000
Unit Water Cost (Rounded):	\$1,719 per ac-ft (during loan period) \$5.28 per 1,000 gallons.

PROJECT DESCRIPTION

City of Center owns water rights for supplies in Lake Center and Lake Pinkston. Currently the City has sufficient supplies to meet the demand in decades 2020 to 2060 and a small shortage in 2070. The City is planning water management strategies to proactively prepare for satisfying any additional demand in the decades through 2060 and also to address the shortage in 2070. One of the recommended water management strategies is to add the return flows from City's WWTP to Lake Center. The City is permitted to use the return flows from the East Bank WWTP. The discharge point for the treated effluent from the WWTP is on a tributary to Mill Creek upstream of Lake Center. The City is planning an indirect reuse project by means of a reuse pipeline from East Bank WWTP to Lake Center. The total capacity for the indirect reuse project will be approximately 1 MGD (1,121 ac-ft per year) and the project will be online in 2020.

SUPPLY DEVELOPMENT

Supply is readily available at the East Bank WWTP owned and operated by the City. City has a permit to use the return flows origination from the WWTP.

ENVIRONMENTAL CONSIDERATIONS

Impacts of the return flows on the receiving water body's water quality parameters needs to be analyzed in detail. Additional environmental considerations may apply during the permitting process.

PERMITTING AND DEVELOPMENT

The City needs to apply for a bed and banks permit to put the supplies in Lake Center.



PLANNING LEVEL OPINION OF COST

Included below is a planning level opinion of cost (PLOC) for the Phase I of the pipeline from City of Center's East Bank WWTP to Lake Center. The transmission system cost estimate also includes a 90 HP pump station, expansion of the treatment plant to treat the additional supplies. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WWPNAME: City of Center
STRATEGY: Pipeline from East Bank WWTP to Lake Center
Quantity: 1,121 AF/Y 1.50 MGD

CAPITAL COSTS

Pipeline to Lake

Nacogdoches

	Size	Qty	Unit	Unit Price	Cost
Pipeline Rural	10 in.	2,000	LF	\$54	\$108,000
Pipeline Urban	10 in.	19,164	LF	\$69	\$1,316,000
Right of Way Easements Rural (ROW)		2,000	LF	\$18	\$36,600
Land and Surveying Rural (10%)					\$4,000
Right of Way Easements Urban (ROW)		19,164	LF	\$108	\$2,076,000
Land and Surveying Urban (10%)					\$208,000
Engineering and Contingencies (30%)					\$427,000
Subtotal of Pipeline					\$4,175,600

Pump Station(s)

Pump with intake & building	90 HP	1	LS	\$4,146,000	\$4,146,000
Ground Storage Tank	0.19 MG	1	EA	\$465,000	\$465,000
Engineering and Contingencies (35%)					\$1,614,000
Subtotal of Pump Station(s)					\$6,225,000

Water Treatment Facility

Expand Existing Water Treatment Plant	2 MGD	1	LS	\$5,254,000	\$5,254,000
Engineering and Contingencies (35%)					\$1,839,000
Subtotal of WTP					\$7,093,000

Permitting and Mitigation \$131,208

Construction Total

Interest During Construction	12	Months			\$485,000
TOTAL COST					\$18,110,000

ANNUAL COSTS

Debt Service (3.5% for 20 years)					\$1,274,000
Operational Costs*					\$653,300
Total Annual Costs					\$1,927,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water					\$1,719
Per 1,000 Gallons					\$5.28

UNIT COSTS (After Amortization)

Per Acre-Foot					\$583
Per 1,000 Gallons					\$1.79



* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

City of Center already has a permit to use the return flows so this project has the benefit of providing a renewable source of supply that is readily available in the close proximity of Lake Center. The addition of the additional 1,120 ac-ft per year will help City of Center supply to the increasing manufacturing demand in Shelby County. City of Center believes that the manufacturing demand reflected in the regional plan is not reflective of the more aggressive growth in the manufacturing use in the region. This strategy will help meet some of the needs in the region.

The recommended strategy for infrastructure improvements was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	1,120 ac-ft per year.
Reliability	5	Highly Reliable Supply
Cost	2	Medium Cost
Environmental Factors	3	Medium Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No Impacts on other natural resources
Major Impacts on Key Water Quality Parameters	3	Impact of the return flows on the quality of the receiving bodies
Political Feasibility	4	City of Center is the local sponsor committed to this strategy
Implementation Issues	4	No known risks

REFERENCES

Discussions with City of Center.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR CITY OF CENTER TOLEDO BEND PIPELINE**

Project Name:	Pipeline from Toledo Bend to Lake Center
Project ID:	CENT-TOL
Project Type:	Existing Surface Water Source
Potential Supply Quantity (Rounded):	2,242 ac-ft per year (5 MGD)
Implementation Decade:	2020
Development Timeline:	5 years
Project Capital Cost:	\$38,916,000 (September 2018)
Project Annual Cost:	\$4,038,000
Unit Water Cost (Rounded):	\$1,801 per ac-ft (during loan period) \$5.53 per ac-ft (1,000 gallons of water)

PROJECT DESCRIPTION

To meet the current demands and higher expected future demands, the City has proposed this water management strategy for the planning period. The City is planning to purchase water from Sabine River Authority to transfer water from Toledo Bend Lake to Lake Center. The City will construct the raw water transmission pipeline from Toledo Bend Reservoir to Lake Center. At this time, it is not clear the total amount of water that will be transferred through this pipeline. For planning purposes, it is assumed that the pipeline will be delivering approximately 2 MGD (2,242 ac-ft per year).

SUPPLY DEVELOPMENT

Supply is available from the Toledo Bend Reservoir owned and operated by Sabine River Authority. After honoring the current contracted amounts, SRA has sufficient supplies to provide the amount requested by City of Center.

ENVIRONMENTAL CONSIDERATIONS

There may be some minor impacts of adding water from SRA's Toledo Bend Reservoir to Lake Center. There are not additional environmental considerations known at this time.

PERMITTING AND DEVELOPMENT

No additional permitting issues associated with the project. City of Center will need to sign a contract with Sabine River Authority for the purchase of the water.

PLANNING LEVEL OPINION OF COST

Included below is a planning level opinion of cost for the transmission system from Toledo Bend to Lake Center. Planning level opinion of probable construction cost estimates include a 16-inch pipeline from Toledo Bend to Lake Center, an intake and a booster pump station, and storage tanks. The annual costs are calculated assuming 3.5% interest rate and 20 years of return period. The estimate includes the cost for the purchase of raw water from SRA. For purposes of developing costs for purchasing water, costs were estimated at the regional rate chosen for the ETRWPA. Actual costs will be determined during contract negotiations. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan.



WWPNAME: City of Center
STRATEGY: Pipeline from Toledo Bend to Lake Center

Quantity: 2,242 AF/Y 3.00 MGD

CAPITAL COSTS

Pipeline	Size	Qty	Unit	Unit Price	Cost
Pipeline Rural	16 in.	100,529	LF	\$97	\$9,737,000
Right of Way Easements Rural (ROW)		100,529	LF	\$18	\$1,837,000
Land and Surveying (10%)					\$184,000
Engineering and Contingencies (30%)					\$2,921,000
Subtotal of Pipeline	19	Miles			\$14,679,000

Pump Station(s)

Pump with intake & building	130 HP	1	LS	\$4,800,000	\$4,800,000
Booster Pump Station	130 HP	1	LS	\$1,062,000	\$1,062,000
Storage Tanks	0.38 MG	1	EA	\$536,000	\$536,000
Engineering and Contingencies (35%)					\$2,239,300
Subtotal of Pump Station(s)					\$8,637,300

Water Treatment Facility

Expand Existing Water Treatment Plant	3 MGD	1	LS	\$9,660,000	\$9,660,000
Engineering and Contingencies (35%)					\$3,381,000
Subtotal of WTP					\$13,041,000

Permitting and Mitigation					\$529,990
Construction Total					\$36,887,290
Interest During Construction			24	Months	\$2,029,000
TOTAL COST					\$38,916,000

Debt Service (3.5% for 20 years)					\$2,738,000
Operational Costs*					\$1,300,000
Total Annual Costs					\$4,038,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water	\$1,801
Per 1,000 Gallons	\$5.53

UNIT COSTS (After Amortization)

Per Acre-Foot	\$937
Per 1,000 Gallons	\$2.88

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

The addition of the additional 2,242 ac-ft per year will help City of Center supply to the increasing manufacturing demand in Shelby County. City of Center believes that the manufacturing demand reflected in the regional plan is not reflective of the more aggressive growth in the manufacturing use in the region. This strategy will help meet some of the needs in the region.



The recommended strategy for infrastructure improvements was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	2,242 ac-ft per year.
Reliability	4	Highly Reliable Supply
Cost	2	Medium Cost
Environmental Factors	4	Low Impact
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No Impacts on other natural resources
Major Impacts on Key Water Quality Parameters	4	Minor Impact of the addition of raw water on the quality of the receiving bodies
Political Feasibility	4	City of Center is the local sponsor committed to this strategy
Implementation Issues	4	No known risks

REFERENCES

Discussions with City of Center.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR HOUSTON COUNTY WCID #1 PERMIT AMENDMENT**

Water User Group Name:	Houston County WCID #1
Strategy Name:	Permit Amendment for Houston County Lake
Strategy ID:	HCWC-PA
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	3,500 ac-ft per year (3.1 MGD)
Implementation Decade:	2020
Development Timeline:	2020
Project Capital Cost:	\$0
Annual Cost:	\$0 per ac-ft
Unit Water Cost (Rounded):	\$0 per ac-ft (\$0 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for Houston County WCID #1 located in Houston County. The strategy involves a permit amendment to take 3,500 ac-ft per year from Houston County Lake in addition to the 3,500 ac-ft per year included in their existing permit.

SUPPLY DEVELOPMENT

Houston County WCID #1 was originally permitted for 7,000 ac-ft per year from Houston County Lake; in 1987, this supply was reduced by the Texas Commission on Environmental Quality (TCEQ) to 3,500 ac-ft per year. Houston County WCID #1 has applied for a permit amendment to return their permitted diversion to the firm yield of the lake, 7,000 ac-ft per year, and add industrial use to the permit. The reliability of this water supply is considered medium because while the firm yield of the lake allows for this permit amendment, the amendment is dependent upon decisions made by the TCEQ.

ENVIRONMENTAL CONSIDERATIONS

The yield of this strategy will be dependent upon negotiations with the TCEQ regarding environmental flow requirements. Environmental flow requirements will be set so the new permit has a minimum impact to environmental water needs and the surrounding habitat. No impacts to cultural resources in the area are expected. There are no bays or estuaries in close proximity Houston County.

PERMITTING AND DEVELOPMENT

This permit amendment is dependent upon coordination with the TCEQ.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) was not developed for this strategy because costs associated with the permit amendment are considered minimal. Any costs incurred by Houston County WCID #1 will be related to engineering and lawyer fees.



PROJECT EVALUATION

This strategy benefits both municipal and non-municipal users in Houston County and would have a positive impact on their water supply security. Since 2007, Houston County WCID #1 has received multiple requests for additional water supplies from entities and business including the City of Crockett, the Crockett Economic & Industrial Development Corporation, The Consolidated WSC, Nacogdoches Power, LLC, and the Houston County Judge, Erin Ford.

This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from Houston County Lake will reduce demands on other water supplies in Houston County and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this permit amendment for existing surface water supplies will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Houston County WCID #1 recommended strategy for a permit amendment was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	3,500 acre feet per year
Reliability	3	Medium Reliable Supply
Cost	5	No Cost (Excluding Administrative and Lawyer Fees)
Environmental Factors	4	Low Impact
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No Impacts on other natural resources
Major Impacts on Key Water Quality Parameters	4	No Impacts
Political Feasibility	4	Sponsored by Houston County WCID #1
Implementation Issues	4	No known risks

REFERENCES

2011 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR CITY OF JACKSONVILLE RAW WATER TRANSMISSION**

Project Name:	Supply from Lake Columbia
Project ID:	JACK-COL
Project Type:	Existing Surface Water Source
Potential Supply Quantity (Rounded):	1,700 ac-ft per year (3 MGD)
Implementation Decade:	2040
Development Timeline:	5 years
Project Capital Cost:	\$29,390,000 (September 2018)
Project Annual Cost:	\$3,150,000
Unit Water Cost (Rounded):	\$1,853 per ac-ft (during loan period) \$5.69 (per 1,000 gallons)

PROJECT DESCRIPTION

Lake Columbia is a water management strategy for Angelina Nacogdoches River Authority. Angelina Neches River Authority has contracts with several customers that are participants in the project development. City of Jacksonville is included in the list, participating at five percent contribution. It is assumed that Jacksonville will be purchasing raw water from Angelina Neches River Authority. City of Jacksonville will need a transmission project to transfer supplies from Lake Columbia to the City. The water management strategy associated with the transmission project is discussed in this tech memo. The current contract amount for City of Jacksonville is 4,275 acre feet. However, City of Jacksonville currently does not have any supply shortages and is also not expecting tremendous growth in the recent future. For these reasons, it is assumed that the transmission strategy will be developed in phases with the first phase for a potential supply of 1,700 acre feet per year (3 MGD). The tech memo discussion is associated with the Phase I of the transmission project. Additional phases will be developed at a later stage. The transmission project will include a 5-mile pipeline from Lake Columbia to the City, an intake pump station, and a 3-MGD water treatment plant to treat the supplies before delivery. Figure included at the end of the tech memo show the location map of the project and a preliminary pipeline corridor for the transmission system.

PERMITTING AND DEVELOPMENT

No additional permitting issues associated with the project. The project will commence after the commencement of the Lake Columbia project by Angelina Neches River Authority.

PLANNING LEVEL OPINION OF COST

Included below is a planning level opinion of cost (PLOC) for Phase I of the pipeline from Lake Columbia to City of Jacksonville. Costs are estimated for half-mile of pipeline in urban areas and 4.5 miles of pipeline in rural areas. The transmission system cost estimate also includes the cost of 100 HP intake pump station and a 3 MGD water treatment plant for treating the raw water. The annual costs are calculated assuming 3.5% interest rate and 20 years of return period. The estimate includes the cost for the purchase of raw water from Angelina Neches River Authority. Overall, this strategy has a medium cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WWPNAME: Jacksonville
STRATEGY: Lake Columbia Pipeline



Quantity for Phase I **1,700** AF/Y

2.27 MGD

CAPITAL COSTS

Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	12 in.	23,544	LF	\$68	\$1,608,000
Pipeline Urban	12 in.	3,000	LF	\$87	\$262,000
Right of Way Easements Rural (ROW)		23,544	LF	\$18	\$430,000
Right of Way Easements Urban (ROW)		3,000	LF	\$108	\$325,000
Land and Surveying Rural (10%)					\$43,000
Land and Surveying Urban (10%)					\$33,000
Engineering and Contingencies (30%)					\$561,000
Subtotal of Pipeline					\$3,262,000

Pump Station(s)

Pump with intake & building	100 HP	1	LS	\$4,315,000	\$4,315,000
Storage Tanks	0.28 MG	1	EA	\$502,000	\$502,000
Engineering and Contingencies (35%)					\$1,686,000
Subtotal of Pump Station(s)					\$6,503,000

Water Treatment Facility

New Water Treatment Plant	3 MGD	1	LS	\$13,837,000	\$13,837,000
Engineering and Contingencies (35%)					\$4,842,950
Subtotal of WTP					\$18,679,950

Permitting and Mitigation

CONSTRUCTION TOTAL \$158,231

Interest During Construction \$787,000

TOTAL COST **\$29,390,000**

ANNUAL COSTS

Debt Service (3.5% for 20 years) \$2,068,000

Operational Costs* \$1,082,000

Total Annual Costs **\$3,150,000**

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water \$1,853

Per 1,000 Gallons \$5.69

UNIT COSTS (After Amortization)

Per Acre-Foot \$636

Per 1,000 Gallons \$1.95

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.



PROJECT EVALUATION

Based on the analysis provided above, the Lake Columbia to Jacksonville Raw Water Transmission System project was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	1,700 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	2	Medium to Moderate High Costs
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	City of Jacksonville is the local sponsor committed to this project
Implementation Issues	3	Dependent on the completion of Lake Columbia construction

REFERENCES

2011 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR LNVA PURCHASE FROM SRA**

Water User Group Name:	Lower Neches Valley Authority
Strategy Name:	Purchase from Sabine River Authority (Toledo Bend)
Strategy ID:	LNVA-SRA
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	200,000 ac-ft per year (178.4 MGD)
Implementation Decade:	2040
Development Timeline:	2040
Project Capital Cost:	\$529,606,000 (September 2018)
Annual Cost:	\$110,157,000
Unit Water Cost (Rounded):	\$551 per ac-ft (\$1.69 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for the Lower Neches Valley Authority and involves a contract to take raw surface water from the Sabine River Authority's Toledo Bend system as their permit allows. The cost for supply from the Sabine River Authority includes the cost of raw water and infrastructure related to water conveyance. Ultimately, the cost for raw water will need to be negotiated with the Sabine River Authority and will reflect the wholesale water rates of this entity at the time a contract is made. The cost estimate included in this technical memorandum utilizes an assumed rate for the East Texas Regional Water Planning Area regional rate for raw surface water.

SUPPLY DEVELOPMENT

The quantity of supply from this strategy represents the water requested by the Lower Neches Valley Authority as part of their long term planning. This is equal to 200,000 ac-ft per year beginning in 2040 and continuing through the end of the planning period, 2070. The reliability of this water supply is considered medium to high due to the availability of water from the Toledo Bend system. However, this project is dependent on coordination with the Sabine River Authority.

ENVIRONMENTAL CONSIDERATIONS

The impact to the environment due to pipeline construction is expected to be moderate. In addition, a contract between the Lower Neches Valley Authority and Sabine River Authority should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries in close proximity to the project area located in Jefferson and Orange Counties. Before this project could be pursued, the Lower Neches Valley Authority would need to perform a site selection study to identify environmental impacts associated with the project.



PERMITTING AND DEVELOPMENT

This strategy is dependent on the Sabine River Authority completing a project to move the location of one of their existing pump stations.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The capital costs assumed 13 miles of pipeline and 17 miles of open canals (distance determined by the Lower Neches Valley Authority), one pump station with an intake, and two booster pump station. The annual cost was estimated assuming a debt service of 3.5% for 20 years and using the East Texas Regional Water Planning Area regional rate for raw surface water. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WWP:	Lower Neches Valley Authority	
STRATEGY:	Purchase from Sabine River Authority (Toledo Bend)	
Raw Water Quantity:	200,000 AF/Y	356.8 MGD
CONSTRUCTION COSTS		

Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline/Canal Rural	144 in.	158,400	LF	\$1,806	\$286,117,000
Right of Way Easements Rural (ROW)		158,400	LF	\$30	\$4,755,800
Land and Surveying (10%)					\$475,580
Engineering and Contingencies (30%)					\$85,835,000
Subtotal of Pipeline/Canal	30	miles			\$377,183,380

Pump Station(s)	HP	Quantity	Unit	Unit Price	Cost
Pump with intake	3150	1	LS	\$37,274,000	\$37,274,000
Booster Pump Station	3150	2	LS	\$18,002,000	\$36,004,000
Engineering and Contingencies (35%)					\$25,647,300
Subtotal of Pump Station(s)					\$98,925,300

Storage Tanks	7.0 MG	3	LS	\$3,037,231	\$9,111,694
Engineering and Contingencies (35%)					\$3,189,093
Subtotal of Storage Tanks					\$12,300,787

Permitting and Mitigation					\$834,000
Construction Total					\$489,243,467
Interest During Construction			36 Months		\$40,363,000
TOTAL CAPITAL COST					\$529,606,000

ANNUAL COSTS	
Debt Service (3.5% for 20 years)	\$37,264,000
Operational Costs*	\$72,893,000
Total Annual Costs	\$110,157,000

UNIT COSTS (Until Amortized)	
Per Acre-Foot of treated water	\$551
Per 1,000 Gallons	\$1.69

UNIT COSTS (After Amortization)



Per Acre-Foot \$364
 Per 1,000 Gallons \$1.12
 * Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits customers of the Lower Neches Valley Authority and is expected to have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. A contract to pull water from the Toledo Bend system will reduce demands on Toledo Bend and the Sabine River and will have no other apparent impact on other State water resources. From a third party social and economic perspective, this voluntary redistribution of water will be beneficial because it provides water for economic growth.

Based on the analyses provided above, the Lower Neches Valley recommended strategy to purchase water from the Sabine River Authority was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	200,000 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low to Medium Impacts to the environment
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Local sponsorship by Lower Neches Valley Authority
Implementation Issues	3	Contract with SRA

REFERENCES

2011 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR LNVA BEAUMONT WEST REGIONAL RESERVOIR**

Water User Group Name:	Lower Neches Valley Authority
Strategy Name:	Beaumont West Regional Reservoir
Strategy ID:	LNVA-WRR
Strategy Type:	New Surface Water Source
Potential Supply Quantity:	7,700 ac-ft per year (6.9 MGD)
Implementation Decade:	2020
Development Timeline:	5 Years
Project Capital Cost:	\$37,538,000 (September 2018)
Project Annual Cost:	\$1,970,00
Unit Water Cost (Rounded):	\$256 per ac-ft (\$0.79 per 1,000 gallons)

PROJECT DESCRIPTION

This recommended strategy involves the construction of an approximate 1,100-acre reservoir on the northwest end of Beaumont. In addition, the location of the reservoir provides a significant advantage to provide water in case of an emergency fire water demand, source pollution in the Neches River or Pine Island Bayou, or losses of either of the Lower Neches Valley Authority pumping stations in severe events, such as what occurred during Hurricane Harvey.

SUPPLY DEVELOPMENT

The reservoir is anticipated to have an approximate capacity of 7,700 acre-feet, which is equivalent to approximately three (3) weeks of water supply to meet municipal and industrial demands downstream. This reservoir is located so that stored water can be sent to all industrial and municipal customers on the LNVA system.

ENVIRONMENTAL CONSIDERATIONS

With the construction of any new reservoir several environmental impacts will be considered. A summary of environmental considerations would be developed based on the known environmental factors such as habitat and aquatic resources for threatened or endangered species within surrounding the reservoir footprint. Environmental flow considerations and how the construction of a reservoir effects the surrounding hydrologic environment is also a consideration.

PERMITTING AND DEVELOPMENT

If this strategy is implemented the Lower Neches Valley Authority well need a water rights permit as well as 404 permit before construction can begin.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for the construction of a new reservoir for this strategy includes costs from all aspects of planning to design to construction. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the yield generated by the infrastructure required.



WWP: Lower Neches Valley Authority
STRATEGY: Beaumont West Regional Reservoir
Raw Water Quantity 7,700 acre-feet 2,509 MG
RESERVOIR STORAGE CAPACITY (1 day of storage = 2,509 MG)

PROJECT COSTS	Cost
Planning	\$350,000
Design	\$1,700,000
Real Estate	\$9,000,000
Environmental	\$150,000
Permitting	\$150,000
Construction	\$13,800,000
Engineering and Contingencies (30%)	\$7,545,000
TOTAL COST	\$33,000,000

Interest During Construction	60 Months	\$4,538,000
TOTAL CAPITAL COST		\$37,538,000

ANNUAL COSTS	
Debt Service (3.5% for 40 years)	\$1,758,000
Operational Costs*	\$212,000
Total Annual Costs	\$1,970,000

UNIT COSTS (Until Amortized)	
Per Acre-Foot of treated water	\$256
Per 1,000 Gallons	\$0.79

UNIT COSTS (After Amortization)	
Per Acre-Foot	\$28
Per 1,000 Gallons	\$0.08

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits both municipal and non-municipal customers of the Lower Neches Valley Authority and would have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. The strategy will have no other apparent impact on other State water resources. From a third party social and economic perspective, this permit amendment for existing surface water supplies will be beneficial because it provides water for economic growth.



Based on the analyses provided above, the Lower Neches Valley Authority recommended strategy for a permit amendment was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	7,700 ac-ft per year
Reliability	5	Highly Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low to Medium Impacts to the environment
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Sponsorship by Lower Neches Valley Authority
Implementation Issues	4	Limited risk; dependent on TCEQ

REFERENCES

Discussions with Lower Neches Valley Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR LNVA NECHES-TRINITY BASIN INTERCONNECT**

Water User Group Name:	Lower Neches Valley Authority
Strategy Name:	Neches-Trinity Basin Interconnect
Strategy ID:	LNVA-WRR
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	67,000 ac-ft per year (60 MGD)
Implementation Decade:	2020
Development Timeline:	5 Years
Project Capital Cost:	\$102,375,000 (September 2018)
Project Annual Cost:	\$8,907,000
Unit Water Cost (Rounded):	\$133 per ac-ft (\$0.41 per 1,000 gallons)

PROJECT DESCRIPTION

The Lower Neches Valley Authority is planning to construct an approximate 13 mile, single 84-inch pipeline that runs in an east-west direction, as well as a 62,000 gpm pump station. The proposed pipeline enables the movement of Neches River water westward toward the upper reaches of the Devers Canal system and potentially back into the Trinity River. The water from this strategy will enable LNVA to provide water for irrigation customers in Region H, as well as to serve new industries as they emerge along the IH-10 corridor.

SUPPLY DEVELOPMENT

The purpose of this water management strategy is to allow the Lower Neches Valley Authority to divert existing supply to areas with greater water need and plan for water needs in areas of future development.

ENVIRONMENTAL CONSIDERATIONS

The pipeline construction is expected to have a moderate impact to the environment, the route would be chosen as to minimize impacts. In addition, the transport of water towards the Devers Canal system should have a minimum impact to environmental water needs, no impact to the surrounding habitat, and a low impact to cultural resources in the area. There are no bays or estuaries in close proximity to the project area located in Jefferson and Orange Counties. Before this project could be pursued, the Lower Neches Valley Authority may need to perform additional studies to identify environmental impacts associated with the project.

PERMITTING AND DEVELOPMENT

The Lower Neches Valley Authority may need to apply for a bed and banks permit to put supplies in the Devers Canal system and possibly the Trinity River.

PLANNING LEVEL OPINION OF COST

Included below is a planning level opinion of cost (PLOC) for the interconnect pipeline and pump station for the Lower Neches Valley Authority. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan due to the yield generated by the infrastructure required.



WWP: Lower Neches Valley
STRATEGY: Authority
Raw Water Quantity: Neches-Trinity Basin Interconnect
 67,000 AF/Y 89.7 MGD

PROJECT COSTS	Cost
Planning	\$1,500,000
Design	\$6,800,000
Real Estate	\$3,500,000
Environmental	\$2,000,000
Permitting	\$2,000,000
Construction 13-mile 84" pipeline, 62,000 gpm pump station	\$53,500,000
Engineering and Contingencies (30%)	\$20,790,000
TOTAL COST	\$90,000,000

Interest During Construction	60 Months	\$12,375,000
TOTAL CAPITAL COST		\$102,375,000

ANNUAL COSTS	
Debt Service (3.5% for 20 years)	\$7,203,000
Operational Costs*	\$1,704,000
Total Annual Costs	\$8,907,000

UNIT COSTS (Until Amortized)	
Per Acre-Foot of treated water	\$133
Per 1,000 Gallons	\$0.41

UNIT COSTS (After Amortization)	
Per Acre-Foot	\$25
Per 1,000 Gallons	\$0.08

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits both municipal and non-municipal customers of the Lower Neches Valley Authority and would have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality.

Based on the analyses provided above, the Lower Neches Valley Authority recommended strategy for an interconnect was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.



Criteria	Rating	Explanation
Quantity	4	67,000 ac-ft per year
Reliability	5	Highly Reliable Supply
Cost	4	Low Cost
Environmental Factors	3	Low to Medium Impacts to the environment
Impact on Other State Water Resources	3	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		Yes
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	3	No known Impacts
Political Feasibility	4	Sponsorship by Lower Neches Valley Authority
Implementation Issues	4	Limited risk; dependent on TCEQ

REFERENCES

Lower Neches Valley Authority



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
 TECHNICAL MEMORANDUM FOR CITY OF LUFKIN**

Water User Group Name:	City of Lufkin
Strategy Name:	Conveyance from Sam Rayburn to Kurth Lake
Strategy ID:	LUFK-RAY
Strategy Type:	Existing Surface Water Source
Potential Supply Quantity:	28,000 ac-ft per year (25 MGD)
Implementation Decade:	2030
Development Timeline:	2030-2050
Project Capital Cost:	Phase 1: \$78,220,000 Phase 2: \$78,199,000 Phase 3: \$8,834,000 (September 2018)
Annual Cost:	Phase 1: \$14,413,000 Phase 2: \$27,911,000 Phase 3: \$25,722,000
Unit Water Cost (Rounded):	Phase 1: \$1,286 per ac-ft (\$3.95 per 1,000 gallons) Phase 2: \$1,255 per ac-ft (\$3.85 per 1,000 gallons) Phase 3: \$919 per ac-ft (\$2.82 per 1,000 gallons)

PROJECT DESCRIPTION

This strategy is a recommended strategy for the City of Lufkin to provide conveyance from Sam Rayburn to Kurth Lake as their permit allows. The cost of the project will occur in three phases and includes the cost of a water treatment plant and infrastructure related to water conveyance. This is a supply that will provide water to both municipal and non-municipal customers in Angelina County; manufacturing in Angelina County is projected to have a need and has a strategy to contract water from this supply. Ultimately, manufacturing water users in Angelina County will make contracts with the City of Lufkin to purchase the water supply created by this project. The cost for raw water will need to be negotiated with the City of Lufkin and will reflect the wholesale water rates of this entity at the time a contract is made.

SUPPLY DEVELOPMENT

As requested by the City of Lufkin, the supply from this strategy represents their water right from Sam Rayburn for 28,000 ac-ft per year. However, since the strategy will be implemented in phases, the full supply will not be available until 2050, pending the demands of potential future customers. The supply in 2030 will be 11,210 ac-ft per year (10 MGD), 22,420 ac-ft per year (20 MGD) in 2040, and 28,000 ac-ft per year (25 MGD) in 2050. The reliability of this water supply is considered high due to the availability of water from the Sam Rayburn system and because the City of Lufkin already has the water right in place to access this water. In addition, the City of Lufkin would not be dependent on sponsorship from another entity



ENVIRONMENTAL CONSIDERATIONS

A specific location for the new water treatment plant has not been determined. Before this strategy could be pursued, a site selection study would need to be performed, in addition to other studies to identify and quantify potential environmental impacts associated with the projected. For the purposes of this analysis, it is assumed that a site could be selected that would have acceptable impacts. Once the water treatment plant is constructed, expanding the water treatment plant will have minimum environmental impacts.

During the construction of the pipeline, impacts to the environment and other natural resources are expected to be minimal and temporary.

PERMITTING AND DEVELOPMENT

Additional study and mitigation may be required before construction of the transmission pipeline.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below; an estimate was prepared for each phase of this strategy. The total capital cost assumes a pipeline length of 12.4 miles, and the water treatment plant would include a 5 million gallon storage tank. The annual cost was estimated assuming a debt service of 3.5% for 20 years as well as electrical and operation and maintenance costs. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WWPNAME:	Lufkin				
STRATEGY:	Develop Water from Sam Rayburn				
Water Quantity	28,000	AF/Y		37.5	MGD
PHASE 1 - 2030 DECADE		Total Capacity (acre-feet per year)			11,210
Treated Water Quantity	11,210	AF/Y	15	MGD	
Pipeline & Treatment Facility	Size	Quantity	Unit	Unit Price	Cost
Pipeline from Sam Rayburn	30 in.	65,500	LF	\$197	\$12,896,000
Right of Way Easements Rural (ROW)		65,500	LF	\$30	\$1,967,000
Land and Surveying (10%)					\$197,000
Engineering and Contingencies (30%)					\$3,869,000
Subtotal of Pipeline	12.4	Miles			\$18,929,000
Pump Station(s)					
Lake Intake and Pump Station	900 HP	1	LS	\$17,465,000	\$17,465,000
Engineering and Contingencies (35%)					\$6,113,000
Subtotal of Pump Station(s)					\$23,578,000
Water Treatment Facility					
Storage	5.00 MG	1	EA	\$2,282,000	\$2,282,000
Water Treatment Facility	10 MGD	1	LS	\$20,886,000	\$20,886,000
Engineering and Contingencies (35%)					\$8,108,800
Subtotal of WTP					\$31,277,000
Permitting and Mitigation					\$358,133



CONSTRUCTION TOTAL				\$74,142,000
Interest During Construction	24	Months		\$4,078,000
PHASE I TOTAL CAPITAL COST				\$78,220,000
Debt Service (3.5% for 20 years)				\$5,504,000
Debt Service from Previous Phase				\$0
Electricity (\$0.08 kWh)				\$229,000
Operational Costs*				\$5,027,000
Raw Water Treatment	3,653,000	1000 gal	\$1.00	\$3,653,000
Total Annual Costs				\$14,413,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water		\$1,286
Per 1,000 Gallons		\$3.95

UNIT COSTS (After Amortization)

Per Acre-Foot		\$795
Per 1,000 Gallons		\$2.44

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PHASE 2 - 2040 DECADE		Total Capacity (acre-feet per year)		22,240
Treated Water Quantity	11,210	AF/Y	15	MGD
Expand Treated Water Supply	Size	Quantity	Unit	Unit Price
Pipeline from Sam Rayburn	30 in.	65,500	LF	\$197
Right of Way Easements Rural (ROW)		65,500	LF	\$30
Land and Surveying (10%)				\$197,000
Engineering and Contingencies (30%)				\$3,869,000
Subtotal of Pipeline	12.4	Miles		\$0
Upgrades to Pump Stations				
Lake Intake and Pump Station	900 HP	1	LS	\$17,465,000
Engineering and Contingencies (35%)				\$6,112,750
Subtotal of Pump Station(s)				\$23,577,750
Water Treatment Facility				
Storage	0.00 MG	0	EA	\$0
Upgrade Treatment Facility	22 MGD	1	LS	\$37,162,000
Engineering and Contingencies (35%)				\$13,006,700
Subtotal of WTP				\$50,168,700
Permitting and Mitigation				\$375,066
CONSTRUCTION TOTAL				\$74,122,000
Interest During Construction	24	Months		\$4,077,000
PHASE 2 TOTAL CAPITAL COST				\$78,199,000



Debt Service (3.5% for 20 years)				\$5,502,000
Debt Service from Previous Phase				\$5,504,000
Electricity (\$0.08 kWh)				\$458,000
Operational Costs*				\$9,200,000
Raw Water Treatment	7,248,000	1000 gal	\$1.00	\$7,247,000
Total Annual Costs				\$27,911,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water				\$1,255
Per 1,000 Gallons				\$3.85

UNIT COSTS (After Amortization)

Per Acre-Foot				\$760
Per 1,000 Gallons				\$2.33

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PHASE 3 - 2050 DECADE	Total Capacity (acre-feet per year)				28,000
Treated Water Quantity	5,580	AF/Y			7 MGD
Expand Pump Stations	Size	Quantity	Unit	Unit Price	Cost
Pipeline from Sam Rayburn	30 in.	65,500	LF	\$197	\$12,896,000
Right of Way Easements Rural (ROW)		65,500	LF	\$30	\$1,967,000
Land and Surveying (10%)					\$197,000
Engineering and Contingencies (30%)					\$3,869,000
Subtotal of Pipeline	12.4	Miles			\$0
Pump Station(s)					
Lake Intake and Pump Station	200 HP	1	LS	\$5,958,000	\$5,958,000
Engineering and Contingencies (35%)					\$2,085,300
Subtotal of Pump Station(s)					\$8,043,300
Water Treatment Facility					
Storage	0.00 MGD	0	EA	\$0	\$0
Water Treatment Facility	0 MGD	0	LS	\$0	\$0
Engineering and Contingencies (35%)					\$0
Subtotal of WTP					\$0



Permitting and Mitigation		\$330,133
CONSTRUCTION TOTAL		\$8,373,000
Interest During Construction	24	Months
PHASE 3 TOTAL CAPITAL COST		\$8,834,000

Debt Service (3.5% for 20 years)		\$622,000
Debt Service from Previous Phase		\$5,502,000
Electricity (\$0.08 kWh)		\$536,000
Operational Costs*		\$9,938,000
Raw Water Treatment	9,125,000	1000 gal
		\$1.00
Total Annual Costs		\$25,722,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water		\$919
Per 1,000 Gallons		\$2.82

UNIT COSTS (After Amortization)

Per Acre-Foot		\$700
Per 1,000 Gallons		\$2.15

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

This strategy benefits both municipal and non-municipal customers in Angelina County, specifically manufacturing water users. Angelina Manufacturing has a recommended strategy to purchase water from Lufkin created by this new supply (Strategy ID: ANGL-MFG1). Overall, providing conveyance from Sam Rayburn to Kurth Lake will have a positive impact on their water supply security. This analysis did not identify any impacts to agricultural or natural resources or to key parameters of water quality. This project may reduce demands on other water resources in Angelina County; however, the project is not expected to impact any other State water resources.

Based on the analyses provided above, the City of Lufkin recommended strategy to develop supplies from Sam Rayburn in Angelina County was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the 2021 East Texas Regional Water Plan. The results of this evaluation can be seen in the table below.



Criteria	Rating	Explanation
Quantity	4	28,000 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	3	Medium Cost
Environmental Factors	4	Minimum to moderate impacts to the environment from construction
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	Sponsorship by City of Lufkin
Implementation Issues	4	No known risks

REFERENCES

2016 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR NACOGDOCHES RAW WATER TRANSMISSION**

Project Name:	Lake Columbia to Nacogdoches Raw Water Transmission System
Project ID:	NACP-COL
Project Type:	Existing Surface Water Source
Potential Supply Quantity (Rounded):	8,551 ac-ft per year (7.6 MGD)
Implementation Decade:	2030
Development Timeline:	2 years
Project Capital Cost:	\$50,754,000 (September 2018)
Project Annual Cost:	\$6,739,000
Unit Water Cost (Rounded):	\$788 per ac-ft (during loan period) \$2.42 (per 1,000 gallons)

PROJECT DESCRIPTION

Lake Columbia is a water management strategy for Angelina Nacogdoches River Authority. Angelina Neches River Authority has contracts with several customers that are participants in the project development. City of Nacogdoches is included in the list, participating at 10 percent contribution respectively. It is assumed that Nacogdoches will be purchasing raw water from Angelina Neches River Authority. City of Nacogdoches will need a transmission project to transfer supplies from Lake Columbia to the City.

The water management strategy associated with the transmission project is discussed in this technical memorandum. The total current contract amount for City of Nacogdoches is 8,551 acre feet. It is assumed that the transmission strategy will be developed for a potential supply of 8,551 acre feet per year (7.6 MGD). The transmission project will include a 3.5-mile pipeline from Lake Columbia to the City, an intake pump station, and a 12-MGD water treatment plant to treat the supplies before delivery.

PERMITTING AND DEVELOPMENT

No additional permitting issues associated with the project. The project will commence after the commencement of the Lake Columbia project by Angelina Neches River Authority.

PLANNING LEVEL OPINION OF COST

Included below is a planning level opinion of cost (PLOC) for the pipeline from Lake Columbia to City of Nacogdoches. Costs are estimated for 3.5 miles of pipeline in urban areas. The transmission system cost estimate also includes the cost of 324 HP intake pump station and a 12 MGD water treatment plant for treating the raw water. The annual costs are calculated assuming 3.5% interest rate and 20 years of return period. The estimate includes the cost for the purchase of raw water from Angelina Neches River Authority. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan.



WWPNAME: Nacogdoches
STRATEGY: Lake Columbia Transmission System
Quantity: 8,551 AF/Y 11.44 MGD

CAPITAL COSTS

Pipeline to Lake Nacogdoches	Size	Qty	Unit	Unit Price	Cost
Pipeline Rural	30 in.	18,117	LF	\$197	\$3,567,000
Right of Way Easements Rural (ROW)		18,117	LF	\$30	\$544,000
Land and Surveying (10%)					\$54,000
Engineering and Contingencies (30%)					\$1,070,000
Subtotal of Pipeline					\$5,235,000

Pump Station(s)

Pump with intake & building	324 HP	1	LS	\$7,991,000	\$7,991,000
Engineering and Contingencies (35%)					\$2,797,000
Subtotal of Pump Station(s)					\$10,788,000

Water Treatment Facility

Expand Existing Water Treatment Plant	12 MGD	1	LS	\$22,731,000	\$22,731,000
Storage Tanks	1.43 MG	1	LS	\$934,000	\$934,000
Engineering and Contingencies (35%)					\$8,283,000
Subtotal of WTP					\$31,948,000

Permitting and Mitigation					\$136,665
Construction Total					\$48,108,000
Interest During Construction			24	Months	\$2,646,000
TOTAL COST					\$50,754,000

ANNUAL COSTS

Debt Service (3.5% for 20 years)					\$3,571,000
Operational Costs*					\$3,168,000
Total Annual Costs					\$6,739,000

UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water					\$788
Per 1,000 Gallons					\$2.42

UNIT COSTS (After Amortization)

Per Acre-Foot					\$370
Per 1,000 Gallons					\$1.14

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.



PROJECT EVALUATION

Based on the analysis provided above, the Lake Columbia to Nacogdoches Raw Water Transmission System project was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	8,500 ac-ft per year
Reliability	4	Highly Reliable Supply
Cost	3	Medium Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	City of Nacogdoches is the local sponsor
Implementation Issues	3	Dependent on the completion of Lake Columbia project

REFERENCES

2016 East Texas Regional Water Plan



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR CITY OF PORT ARTHUR ADVANCED CONSERVATION**

Project Name:	City of Port Arthur – Advanced Conservation
Project ID:	PORT-CONS
Project Type:	Conservation
Potential Supply Quantity (Rounded):	2,708 – 7,664 ac-ft per year (2.42 – 6.84 MGD)
Implementation Decade:	2020
Development Timeline:	1 years
Project Capital Cost:	\$51,618,000 (September 2018)
Project Annual Cost:	\$1,981,000
Unit Water Cost (Rounded):	\$295 per ac-ft (during loan period) \$0.91 (per 1,000 gallons)

PROJECT DESCRIPTION

The City provides treated water to municipal users both inside and outside their city limits and industrial users including Cheniere LNG and Motiva Enterprises. Port Arthur is not projected to have a water shortage within the planning period. However, the City had an average per capita consumption of 320 gpcd in 2011. This value is well over the statewide goal of 140 gpcd. In addition, their 2013 Water Loss Report submitted to the TWDB had a total percent loss of over 66%. After performing a conservation analysis, the ETRWPG believes a water conservation strategy for the City is economically achievable. The recommended water management strategy for Port Arthur is water conservation, which includes planning level opinion of probable construction cost estimates related to enhanced public and school education, water conservation pricing implementation, and an enhanced water loss control program.

SUPPLY DEVELOPMENT

The supply for this strategy represents conservation savings due to enhanced public and school education, water conservation pricing implementation, and an enhanced water loss control program.

ENVIRONMENTAL CONSIDERATIONS

No environmental considerations associated with this strategy.

PERMITTING AND DEVELOPMENT

No additional permitting required for this strategy

PLANNING LEVEL OPINION OF COST

The planning level opinion of cost (PLOC) for this strategy includes \$51,618,000 capital costs and the annual cost for this strategy is \$1,981,000. The unit cost is \$295 per ac-ft of supply and \$0.91 per 1,000 gallons of supply.



PROJECT EVALUATION

Based on the analysis provided above, the City of Port Arthur Municipal Conservation project was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	7,664 ac-ft per year
Reliability	4	Reliable Supply
Cost	4	Low Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	4	City of Port Arthur is the local sponsor
Implementation Issues	4	No known risks



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR CITY OF TYLER LAKE PALESTINE EXPANSION**

Project Name:	City of Tyler – Lake Palestine Expansion
Project ID:	TYLR-PAL
Project Type:	Existing Surface Water Source
Potential Supply Quantity (Rounded):	16,815 ac-ft per year (15 MGD)
Implementation Decade:	2020
Development Timeline:	1 years
Project Capital Cost:	\$111,190,000 (September 2018)
Project Annual Cost:	\$15,385,000
Unit Water Cost (Rounded):	\$915 per ac-ft (during loan period) \$2.81 (per 1,000 gallons)

PROJECT DESCRIPTION

The current supplies for the City include 34 MGD from Lake Tyler, 30 MGD from Lake Palestine, 0.4 MGD from Bellwood Lake, and 12 groundwater wells in Carrizo Wilcox aquifer producing approximately 8 MGD. The City of Tyler is shown to have sufficient supplies through the planning period using the TWDB approved demand projections.

In addition, there is considerable interest in other users in Smith County contracting with the City of Tyler for water supplies. There are recommended strategies for Tyler to provide additional water to Bullard, Crystal Systems Inc., Lindale, Walnut Grove WSC, Mining, and Manufacturing in Smith County. Until 2060, City of Tyler has sufficient supplies to meet the proposed demands for the potential future customers. City of Tyler has a small shortage in 2070 when current and future customer demands are taken into consideration.

City of Tyler proposed the following recommended strategies for the 2021 regional plan. City of Tyler will develop the additional 30 MGD of Lake Palestine water. The City has developed about half of its contracted supply in Lake Palestine and plans to develop the remaining supply by 2030, as part of its long-term water supply plan.

SUPPLY DEVELOPMENT

The supply for this strategy represents City of Tyler’s contract with Upper Neches River Municipal Water Authority for 67,200 ac-ft per year supplies from Lake Palestine. City of Tyler has transmission capacity to access half of the supplies and plans to develop this recommended strategy to access the other half. The reliability of this water supply is not considered high due to reduction in Lake Palestine yield due to sedimentation issues.

ENVIRONMENTAL CONSIDERATIONS

A specific location for the new water treatment plant has been determined. The new water treatment plant will be at the same location as the current plant and the process train will be a mirror image of the current process train. For the purposes of this analysis, it is assumed that the current site would have acceptable impacts. Once the water treatment plant is constructed, expanding the water treatment plant will have minimum environmental impacts. During the construction of the pipeline, impacts to the environment and other natural resources are expected to be minimal and temporary.



PERMITTING AND DEVELOPMENT

Additional study and mitigation may be required before construction of the transmission pipeline.

PLANNING LEVEL OPINION OF COST

A planning level opinion of cost (PLOC) for this strategy is included in the table below. The total capital cost assumes a pipeline length of 5 miles, and 30 MGD water treatment plant would include a 2 million gallon storage tank. The annual cost was estimated assuming a debt service of 3.5% for 20 years as well as electrical and operation and maintenance costs. Overall, this strategy has a high cost compared to other strategies in the 2021 East Texas Regional Water Plan.

WWPNAME: City of Tyler
STRATEGY: Lake Palestine Expansion
Quantity: 16,815 AF/Y 30 MGD

CAPITAL COSTS

Pipeline	Size	Quantity	Unit	Unit Price	Cost
Pipeline Rural	42 in.	23,400	LF	\$283	\$6,613,000
Pipeline Urban	42 in.	3,000	LF	\$370	\$1,109,000
Right of Way Easements Rural (ROW)		23,400	LF	\$30	\$703,000
Right of Way Easements Urban (ROW)		3,000	LF	\$180	\$540,000
Land and Surveying Rural (10%)					\$70,000
Land and Surveying Urban (10%)					\$54,000
Engineering and Contingencies (30%)					\$2,317,000
Subtotal of Pipeline		5	mile		\$11,406,000

Pump Station(s)

Ground Storage Tanks	2 MG	1	LS	\$1,102,000	\$1,102,000
Booster Pump Station	1400 HP	1	LS	\$8,357,000	\$8,357,000
Engineering and Contingencies (35%)					\$3,311,000
Subtotal of Pump Station(s)					\$12,770,000

Water Treatment Facility

Expand Water Treatment Plant	30 MGD	1	LS	\$62,137,000	\$62,137,000
Engineering and Contingencies (35%)					\$21,748,000
Subtotal of WTP					\$83,885,000

Permitting and Mitigation \$153,000

CONSTRUCTION TOTAL

Interest During Construction	12	Months			\$2,976,000
TOTAL COST					\$111,190,000

ANNUAL COSTS

Debt Service (3.5% for 20 years)					\$7,823,000
Electricity (\$0.08 kWh)					\$216,000
Operational Costs*					\$7,562,000
Raw Water Purchase	1000 gal		\$1.00		\$5,479,000
Total Annual Costs					\$15,385,000



UNIT COSTS (Until Amortized)

Per Acre-Foot of treated water \$915
Per 1,000 Gallons \$2.81

UNIT COSTS (After Amortization)

Per Acre-Foot \$788
Per 1,000 Gallons \$2.42

* Includes, as appropriate, operation and maintenance, power, water purchase (raw or treated), water treatment chemicals, well pumping (for groundwater), ongoing regulatory support (as needed) and other anticipated annual operating costs.

PROJECT EVALUATION

Based on the analysis provided above, the City of Tyler Lake Palestine Expansion project was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	16,815 ac-ft per year
Reliability	4	Moderately Reliable Supply
Cost	3	Medium Cost
Environmental Factors	4	Low Impacts
Impact on Other State Water Resources	4	Low Impact
Threat to Agricultural Resources/Rural Areas	4	Low
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	City of Tyler is the local sponsor
Implementation Issues	4	No known risks

REFERENCES

2011 East Texas Regional Water Plan.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
 TECHNICAL MEMORANDUM FOR UNRMWA RUN OF RIVER, NECHES WITH LAKE PALESTINE**

WMS Name:	Run of River, Neches with Lake Palestine
WMS Project ID:	UNM-LP
WMS Type:	New Surface Water Source
Potential Supply Quantity (Rounded):	68,625 ac-ft/yr (61.2 MGD)
Implementation Decade:	2020
Development Timeline:	2-4 years
Strategy Capital Cost:	\$518,977,000 (September 2018)
Strategy Annual Cost:	\$47,246,000
Unit Water Cost (Rounded):	\$688 per ac-ft (during loan period) \$2.11 (per 1,000 gallons)

STRATEGY DESCRIPTION

The Upper Neches River Municipal Water Authority (UNRMWA) owns and operates the Lake Palestine system in the Neches River Basin. Upper Neches River Municipal Water Authority has a water right for 238,110 ac-ft per year from Lake Palestine and a downstream run-of-river diversion. City of Palestine, City of Tyler, and City of Dallas have contracts for supplies from Lake Palestine for amounts of 28,000 ac-ft per year, 67,200 ac-ft per year, and 114,337 ac-ft per year respectively. After supplying the contracted amounts to these three contracted customers, Upper Neches River Municipal Water Authority is expected to have 28,573 ac-ft per year available to supply to other entities in ETRWPA.

Based on current contracts and the available supplies from the Neches Basin WAM, the UNRMWA shows a small shortage during the planning period for Lake Palestine supplies. UNRMWA does not think the shortages to be real as the shortage is primarily associated with the reduced firm yield of Lake Palestine due to projected sediment accumulation in the lake. UNRMWA believes that the storage-area-elevation curves used in the Water Availability Models are severely under-predicting the storage volumes available in various parts of the lake. Therefore, UNRMWA believes that the lake yield is much larger than what is projected by the Water Availability Models.

To address the shortages for the planning period UNRMWA has evaluated multiple potentially feasible WMSs and have various recommendation for the 2021 ETRWPA Regional Plan. UNRMWA and City of Dallas are considering development of a water supply project from the run-of-river diversions on Upper Neches River and using Lake Palestine, tributary storage, and/or groundwater as system resources. Using the run-of-river diversions operated as a system with Lake Palestine is the recommended strategy. Run-of-river diversions operated as a system with off-channel tributary storage and as conjunctive use along with groundwater are proposed as alternative strategies. All the potentially feasible WMSs for UNRMWA and City of Dallas are discussed in the 2015 Report *Upper Neches River Water Supply Project Feasibility Study*.

STRATEGY DEVELOPMENT

This recommended strategy includes run-of-river diversions near SH 21 on Neches River operated as a system with storage in Lake Palestine. UNRMWA will be the project sponsor for this WMS. The run-of-river diversions will be taken from the river segment between the existing Rocky Point diversion and the Weches Dam site below the SH21 crossing, between the Neches River National Wildlife Refuge and upstream of the Weches Dam site. The run-of-the-river diversions will be authorized under a new appropriation of surface water, subject to senior water rights and environmental flows. New facilities required for this WMS include a small diversion dam on the Neches River, a river intake and pump station,



and a transmission pipeline and booster pump station supporting transmission to Lake Palestine. The run-of-river diversions are an interruptible supply and the firm yield associated with the WMS is the incremental increase in the firm yield of Lake Palestine resulting from the system operation of the new diversions and the transmission facilities with the Lake Palestine.

The feasibility report includes multiple infrastructure alternatives for the recommended strategy, each resulting in a different amount of firm yield at Lake Palestine. Run-of-river diversions with a 108-inch transmission pipeline and a pump station capacity of 317 cfs was selected as the recommended transmission system to yield 68,625 ac-ft per year of firm yield at Lake Palestine. It should be noted that the project configuration for the recommended WMS for UNRMWA in the 2021 ETRWPA Regional Plan is different from the configuration discussed in Dallas’ October 2014 Draft Long Range Water Supply Plan (Draft LRWSP). The project configuration discussed in the City of Dallas Draft LRWSP resulted in a firm yield of 47,250 ac-ft per year (42 MGD) that is projected to meet Dallas needs starting 2070. A project configuration with a larger firm yield was recommended in ETRWPA Regional Plan so as to meet the projected needs for City of Dallas, shortages for UNRMWA associated with reduced Lake Palestine yield due to sedimentation, and needs for other potential customers in ETRWPA. For regional planning purposes, the WMS is expected to be online in 2020 to address the shortages projected for the current contracted customers for Lake Palestine and potential steam electric power customers in Anderson County. The WMS timing can be changed to a later date if the timing of needs for the current contracted customers and steam-electric power customers changes. City of Dallas is expected to use their share of supplies from this WMS starting in 2060.

SUPPLY DEVELOPMENT

Availability of the Run-of-River supplies was determined using the Neches Basin Water Availability Model and reported in the 2015 Report *Upper Neches River Water Supply Project Feasibility Study*.

PERMITTING AND DEVELOPMENT

The Neches River Run-of-the-River Diversion would require a new water rights permit and an interbasin transfer permit.

COST ANALYSIS

The cost estimates for the Run-of-River strategy were obtained from the 2015 Report *Upper Neches River Water Supply Project Feasibility Study*. Additional details of the cost estimates can be obtained from the report.

PROJECT EVALUATION

Based on the analysis provided above, the Neches River Run-of-the-River Diversion strategy was evaluated across eleven different criteria for the purpose of quick comparison against alternative strategies that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	68,625 ac-ft per year
Reliability	4	Reliable Supply
Cost	3	Low – Medium Cost



Environmental Factors	3	Medium Impacts
Impact on Other State Water Resources	4	Low Impacts
Threat to Agricultural Resources/Rural Areas	4	Low Impacts
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	UNRMWA is the local sponsor for this strategy
Implementation Issues	2	Need to secure the run-of-river rights

WATER USER GROUP APPLICATION

The Neches River Run-of-the-River Diversion strategy was evaluated on a basis of several criteria to determine the Water User Groups (WUGs) to which it may be applied. Consideration was given to the proximity of the project to identified needs, the volume of the supply made available, the quality of the water provided, and the unit cost of the strategy as well as other factors that may relate to the auditability of the strategy to the WUGs served.

REFERENCES

Discussions with Upper Neches River Municipal Water Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM FOR UNRMWA RUN OF RIVER, NECHES WITH TRIBUTARY
STORAGE**

WMS Name:	Run of River, Neches with Tributary Storage
WMS Project ID:	UNM-TS
WMS Type:	New Surface Water Source
Potential Supply Quantity (Rounded):	75,000 ac-ft/yr (67 MGD)
Implementation Decade:	2020
Development Timeline:	2-4 years
Strategy Capital Cost:	\$404,497,000 (September 2018)
Strategy Annual Cost:	\$26,598,000
Unit Water Cost (Rounded):	\$355 per ac-ft (during loan period) \$1.09 (per 1,000 gallons)

STRATEGY DESCRIPTION

The Upper Neches River Municipal Water Authority (UNRMWA) owns and operates the Lake Palestine system in the Neches River Basin. Upper Neches River Municipal Water Authority has a water right for 238,110 ac-ft per year from Lake Palestine and a downstream run-of-river diversion. City of Palestine, City of Tyler, and City of Dallas have contracts for supplies from Lake Palestine for amounts of 28,000 ac-ft per year, 67,200 ac-ft per year, and 114,337 ac-ft per year respectively. After supplying the contracted amounts to these three contracted customers, Upper Neches River Municipal Water Authority is expected to have 28,573 ac-ft per year available to supply to other entities in ETRWPA.

Based on current contracts and the available supplies from the Neches Basin WAM, the UNRMWA shows a small shortage during the planning period for Lake Palestine supplies. UNRMWA does not think the shortages to be real as the shortage is primarily associated with the reduced firm yield of Lake Palestine due to projected sediment accumulation in the lake. UNRMWA believes that the storage-area-elevation curves used in the Water Availability Models are severely under-predicting the storage volumes available in various parts of the lake. Therefore, UNRMWA believes that the lake yield is much larger than what is projected by the Water Availability Models.

To address the shortages for the planning period UNRMWA has evaluated multiple potentially feasible WMSs and have various recommendation for the 2021 ETRWPA Regional Plan. UNRMWA and City of Dallas are considering development of a water supply project from the run-of-river diversions on Upper Neches River and using Lake Palestine, tributary storage, and/or groundwater as system resources. Using the run-of-river diversions operated as a system with Lake Palestine is the recommended strategy. Run-of-river diversions operated as a system with off-channel tributary storage and as conjunctive use along with groundwater are proposed as alternative strategies. All the potentially feasible WMSs for UNRMWA and City of Dallas are discussed in the 2015 Report Upper Neches River Water Supply Project Feasibility Study.

STRATEGY DEVELOPMENT

The first alternative strategy for UNRMWA includes new run-of-river diversions from the Neches River segment between the existing Rocky Point diversion dam and the Weches dam site with storage in a new tributary or off-channel reservoir. This alternative strategy includes system operations with Lake Palestine. Facilities for implementation of this WMS include a small diversion dam on the Neches River, a high capacity river intake pump station, a transmission pipeline to the reservoir, and a tributary or off-channel reservoir. The interruptible run-of-river diversions will be backed up using stored water in the tributary or off-channel



reservoir. Run-of-river diversions and any impoundment of local runoff in a tributary or off-channel reservoir are subject to inflow passage for senior water rights and environmental protection. The recommended infrastructure combinations for this WMS can provide a firm yield of 75,000 ac-ft per year (67 MGD).

SUPPLY DEVELOPMENT

Availability of the Run-of-River supplies was determined using the Neches Basin Water Availability Model and reported in the 2015 Report *Upper Neches River Water Supply Project Feasibility Study*.

PERMITTING AND DEVELOPMENT

The Neches River Run-of-the-River Diversion would require a new water rights permit and an interbasin transfer permit.

COST ANALYSIS

The cost estimates for the Run-of-River strategy were obtained from the 2015 Report *Upper Neches River Water Supply Project Feasibility Study*. Additional details of the cost estimates can be obtained from the report.

WATER MANAGEMENT STRATEGY EVALUATION

Based on the analysis provided above, the Neches River Run-of-the-River with Tributary Storage strategy was evaluated across eleven different criteria for the purpose of quick comparison against alternative strategies that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	75,000 ac-ft per year
Reliability	4	Reliable Supply
Cost	3	Low – Medium Cost
Environmental Factors	3	Medium Impacts
Impact on Other State Water Resources	4	Low Impacts
Threat to Agricultural Resources/Rural Areas	4	Low Impacts
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	UNRMWA is the local sponsor for this strategy
Implementation Issues	2	Need to secure the run-of-river rights

WATER USER GROUP APPLICATION

The Neches River Run-of-the-River Tributary Storage strategy was evaluated on a basis of several criteria to determine the Water User Groups (WUGs) to which it may be applied. Consideration was given to the proximity of the project to identified needs, the volume of the supply made available, the quality of the water provided, and the unit cost of the strategy as well as other factors that may relate to the auditability



of the strategy to the WUGs served.

REFERENCES

Discussions with Upper Neches River Municipal Water Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
 TECHNICAL MEMORANDUM FOR UNRMWA RUN OF RIVER, NECHES WITH GROUNDWATER**

WMS Name:	Run of River, Neches with Groundwater
WMS Project ID:	UNM-GW
WMS Type:	New Surface Water Source
Potential Supply Quantity (Rounded):	84,875 ac-ft/yr (76 MGD)
Implementation Decade:	2020
Development Timeline:	2-4 years
Strategy Capital Cost:	\$326,646,000 (September 2018)
Strategy Annual Cost:	\$38,237,000
Unit Water Cost (Rounded):	\$451 per ac-ft (during loan period) \$1.38 (per 1,000 gallons)

STRATEGY DESCRIPTION

The Upper Neches River Municipal Water Authority (UNRMWA) owns and operates the Lake Palestine system in the Neches River Basin. Upper Neches River Municipal Water Authority has a water right for 238,110 ac-ft per year from Lake Palestine and a downstream run-of-river diversion. City of Palestine, City of Tyler, and City of Dallas have contracts for supplies from Lake Palestine for amounts of 28,000 ac-ft per year, 67,200 ac-ft per year, and 114,337 ac-ft per year respectively. After supplying the contracted amounts to these three contracted customers, Upper Neches River Municipal Water Authority is expected to have 28,573 ac-ft per year available to supply to other entities in ETRWPA.

Based on current contracts and the available supplies from the Neches Basin WAM, the UNRMWA shows a small shortage during the planning period for Lake Palestine supplies. UNRMWA does not think the shortages to be real as the shortage is primarily associated with the reduced firm yield of Lake Palestine due to projected sediment accumulation in the lake. UNRMWA believes that the storage-area-elevation curves used in the Water Availability Models are severely under-predicting the storage volumes available in various parts of the lake. Therefore, UNRMWA believes that the lake yield is much larger than what is projected by the Water Availability Models.

To address the shortages for the planning period UNRMWA has evaluated multiple potentially feasible WMSs and have various recommendation for the 2021 ETRWPA Regional Plan. UNRMWA and City of Dallas are considering development of a water supply project from the run-of-river diversions on Upper Neches River and using Lake Palestine, tributary storage, and/or groundwater as system resources. Using the run-of-river diversions operated as a system with Lake Palestine is the recommended strategy. Run-of-river diversions operated as a system with off-channel tributary storage and as conjunctive use along with groundwater are proposed as alternative strategies. All the potentially feasible WMSs for UNRMWA and City of Dallas are discussed in the 2015 Report Upper Neches River Water Supply Project Feasibility Study.

STRATEGY DEVELOPMENT

A conjunctive use WMS is the second proposed alternative strategy for UNRMWA. The WMS includes new run-of-river diversions from the Neches River segment between the existing Rocky Point diversion dam and the Weches dam site with groundwater supplies from new wells in Carrizo, Wilcox, and Queen City aquifers in Anderson and Cherokee Counties. This alternative strategy includes system operations with Lake Palestine. New facilities for the implementation of this WMS include a small diversion dam on the Neches River, a river intake and pump station, wells located on properties controlled by Campbell Timberland Management, LLC and Forestar (USA) Real Estate Group, Inc., and a transmission system for the delivery



of the supplies to the potential customers. The interruptible run-of-river supplies will be backed up using groundwater delivered to the run-of-river diversion point using bed and banks of the Neches River and several tributary streams. The run-of-river diversions are subject to inflow passage for senior water rights and environmental protection, but the groundwater supplies are not. The recommended infrastructure combinations for this WMS can provide a firm yield of 84,875 ac-ft per year (76 MGD).

SUPPLY DEVELOPMENT

Availability of the Run-of-River supplies was determined using the Neches Basin Water Availability Model and reported in the 2015 Report *Upper Neches River Water Supply Project Feasibility Study*.

PERMITTING AND DEVELOPMENT

The Neches River Run-of-the-River Diversion would require a new water rights permit and an interbasin transfer permit.

COST ANALYSIS

The cost estimates for the Run-of-River strategy were obtained from the 2015 Report *Upper Neches River Water Supply Project Feasibility Study*. Additional details of the cost estimates can be obtained from the report.

WATER MANAGEMENT STRATEGY EVALUATION

Based on the analysis provided above, the groundwater supply strategy was evaluated across eleven different criteria for the purpose of quick comparison against alternative strategies that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity	4	84,875 ac-ft per year
Reliability	4	Reliable Supply
Cost	3	Low – Medium Cost
Environmental Factors	3	Medium Impacts
Impact on Other State Water Resources	4	Low Impacts
Threat to Agricultural Resources/Rural Areas	4	Low Impacts
Interbasin Transfers		No
Other Natural Resources	4	No known Impacts
Major Impacts on Key Water Quality Parameters	4	No known Impacts
Political Feasibility	3	UNRMWA is the local sponsor for this strategy
Implementation Issues	2	Need to secure groundwater rights

WATER USER GROUP APPLICATION

The groundwater strategy was evaluated on a basis of several criteria to determine the Water User Groups (WUGs) to which it may be applied. Consideration was given to the proximity of the project to identified



needs, the volume of the supply made available, the quality of the water provided, and the unit cost of the strategy as well as other factors that may relate to the auditability of the strategy to the WUGs served.

REFERENCES

Discussions with Upper Neches River Municipal Water Authority.



**ETRWPA WATER MANAGEMENT STRATEGY ANALYSIS
TECHNICAL MEMORANDUM**

Project Name:	Municipal Conservation – Multiple Water Users
Project ID:	WUG_CONS
Project Type:	Conservation
Potential Supply Quantity (Rounded):	Varies, Specific to WUG
Implementation Decade:	2020 ()
Development Timeline:	1 years
Project Capital Cost:	\$0 (Sept. 2018)
Annual Cost:	Varies, Specific to WUG
Unit Water Cost (Rounded):	Varies, Specific to WUG

STRATEGY DESCRIPTION

Water Conservation best management practices were evaluated for municipal water user groups that have a projected per capita water use greater than 140 gpcd and have either demonstrated needs in the planning period or recommended water management strategies that involve interbasin transfer. Evaluated water conservation practices included enhanced public and school education, water conservation pricing, and an enhanced water loss control program. In ETRWPA, water conservation strategies are identified for the following list of municipal water user groups. In addition to this basic and advanced conservation strategies are proposed for the following wholesale water providers with municipal customers. Discussion of the basic conservation measures, conservation savings, and the corresponding annual costs for these municipal water user groups is discussed in this technical memorandum.

SUPPLY DEVELOPMENT

The supply for this strategy represents conservation savings due to enhanced public and school education, water conservation pricing implementation, and an enhanced water loss control program. Below is a table showing the conservation savings for the municipal water user groups.

ENVIRONMENTAL CONSIDERATIONS, PERMITTING AND DEVELOPMENT

No environmental considerations associated with this strategy. No additional permitting required for this strategy.



WUG	Conservation Amount (Acre-ft/yr)						Capital Costs	Annual Costs	Unit Cost Before Amm.	
	2020	2030	2040	2050	2060	2070			\$ per AF	\$ per Kgal
ALTO	4	6	7	7	9	10	\$0	\$3,000	\$325.58	\$1.00
ALTO RURAL WSC	9	16	18	21	25	28	\$0	\$8,000	\$316.24	\$0.97
APPLEBY WSC	9	17	20	23	27	32	\$0	\$9,000	\$335.94	\$1.03
ARP	2	0	0	0	0	0	\$0	\$2,000	\$1,000.00	\$3.07
ATHENS	7	13	16	20	23	27	\$786,000	\$25,000	\$1,155.70	\$3.55
BEAUMONT	2,027	3,425	4,202	5,112	6,171	7,382	\$60,175,000	\$2,076,000	\$370.87	\$1.14
BLACKJACK WSC	2	3	4	5	5	6	\$0	\$2,000	\$360.00	\$1.10
BROWNSBORO	3	0	0	0	0	0	\$0	\$2,000	\$666.67	\$2.05
BULLARD	11	22	28	36	44	54	\$0	\$14,000	\$297.44	\$0.91
CARTHAGE	23	39	41	44	47	50	\$0	\$11,000	\$266.39	\$0.82
CENTER	26	45	52	57	64	70	\$0	\$11,000	\$187.90	\$0.58
CHANDLER	9	17	21	26	32	36	\$0	\$11,000	\$361.70	\$1.11
CHESTER WSC	2	5	5	5	6	6	\$0	\$2,000	\$413.79	\$1.27
COLMESNEIL	4	6	6	7	7	8	\$0	\$2,000	\$315.79	\$0.97
COUNTY-OTHER, HOUSTON	2	3	3	4	4	4	\$0	\$1,000	\$300.00	\$0.92
COUNTY-OTHER, JEFFERSON	34	0	0	0	0	0	\$0	\$20,000	\$588.24	\$1.80
CROCKETT	19	29	30	32	34	36	\$0	\$11,000	\$366.67	\$1.13
CRYSTAL SYSTEMS TEXAS	18	38	52	71	92	118	\$954,000	\$39,000	\$471.16	\$1.45
CUSHING	10	19	24	30	37	45	\$1,030,000	\$42,000	\$1,083.14	\$3.32
CYPRESS CREEK WSC	2	3	3	3	3	4	\$0	\$1,000	\$333.33	\$1.02
DEAN WSC	11	18	0	0	0	0	\$0	\$7,000	\$482.76	\$1.48
ELKHART	4	6	6	7	7	8	\$0	\$2,000	\$315.79	\$0.97
FRANKSTON	4	6	7	7	7	8	\$0	\$2,000	\$307.69	\$0.94
GARRISON	4	6	8	9	10	12	\$0	\$3,000	\$285.71	\$0.88
HEMPHILL	4	8	7	7	8	8	\$0	\$2,000	\$285.71	\$0.88
HENDERSON	83	148	179	235	283	334	\$9,900,000	\$370,000	\$1,430.53	\$4.39
JACKSONVILLE	50	85	110	129	152	178	\$0	\$42,000	\$291.19	\$0.89



JASPER	75	124	141	158	178	196	\$15,444,000	\$532,000	\$3,007.61	\$9.23
KILGORE	10	19	21	25	28	32	\$0	\$8,000	\$288.89	\$0.89
KIRBYVILLE	6	9	10	11	11	12	\$0	\$3,000	\$305.08	\$0.94
LINDALE	7	14	18	23	29	36	\$0	\$8,000	\$259.84	\$0.80
LOVELADY	2	3	3	3	4	4	\$0	\$1,000	\$315.79	\$0.97
LUFKIN	151	239	273	0	0	0	\$0	\$60,000	\$271.49	\$0.83
MT ENTERPRISE WSC	4	8	0	0	0	0	\$0	\$3,000	\$500.00	\$1.53
NACOGDOCHES	247	426	532	656	802	966	\$27,720,000	\$986,000	\$1,349.27	\$4.14
NEW LONDON	13	22	26	30	36	40	\$0	\$6,000	\$173.65	\$0.53
NEWTON	6	10	10	11	12	12	\$0	\$4,000	\$393.44	\$1.21
NORWOOD WSC	2	0	0	0	0	0	\$0	\$1,000	\$500.00	\$1.53
OVERTON	8	15	18	21	24	28	\$0	\$7,000	\$289.47	\$0.89
PALESTINE	81	129	140	150	161	172	\$0	\$30,000	\$212.48	\$0.65
PANOLA-BETHANY WSC	0	0	0	0	1	2	\$0	\$0	\$0.00	\$0.00
PLEASANT SPRINGS WSC	2	4	5	5	5	6	\$0	\$2,000	\$407.41	\$1.25
PORT ARTHUR	2,708	4,449	5,222	6,029	6,844	7,664	\$51,618,000	\$1,981,000	\$295.29	\$0.91
RUSK	15	26	30	34	40	46	\$0	\$14,000	\$361.26	\$1.11
SAN AUGUSTINE	10	17	18	20	22	23	\$2,297,000	\$79,000	\$3,660.77	\$11.23
SAND HILLS WSC	4	8	8	9	10	12	\$0	\$3,000	\$352.94	\$1.08
SOUTHERN UTILITIES	514	866	1,058	1,279	1,527	1,803	\$33,264,000	\$1,249,000	\$807.75	\$2.48
TATUM	4	8	9	10	12	14	\$0	\$4,000	\$315.79	\$0.97
TDCJ BETO GURNEY & POWLEDGE UNITS	16	27	29	30	32	34	\$0	\$6,000	\$208.33	\$0.64
TDCJ COFFIELD MICHAEL	44	75	80	85	91	96	\$0	\$8,000	\$101.91	\$0.31
TDCJ EASTHAM UNIT	15	25	27	29	30	32	\$0	\$4,000	\$151.90	\$0.47
TENAHA	4	6	6	7	8	8	\$0	\$2,000	\$307.69	\$0.94
TROUP	6	11	12	14	17	18	\$0	\$5,000	\$320.51	\$0.98
TYLER	657	1,101	1,338	1,613	1,924	2,268	\$58,766,000	\$2,026,000	\$1,123.06	\$3.45
WELLS	2	0	0	0	0	0	\$0	\$1,000	\$500.00	\$1.53
WILDWOOD POA	4	6	7	7	8	8	\$0	\$2,000	\$300.00	\$0.92
WOODVILLE	17	28	30	32	34	36	\$0	\$9,000	\$305.08	\$0.94



COST ANALYSIS

Capital costs were identified for some of the conservation strategies. Table above includes a summary of capital costs, annual costs, and the unit costs for the water users with conservation strategies.

PROJECT EVALUATION

Based on the analysis provided above, the municipal conservation project was evaluated across eleven different criteria for the purpose of quick comparison against alternative projects that may be incorporated into the Regional Water Plan. The results of this evaluation can be seen in the table below.

Criteria	Rating	Explanation
Quantity		Varies, Specific to Entities
Reliability	1	Reliable Supply
Cost	1	Low Cost
Environmental Factors	1	Low Impacts
Impact on Other State Water Resources	1	No Impacts
Threat to Agricultural Resources/Rural Areas	1	No Impacts
Interbasin Transfers		No
Other Natural Resources	1	No Impacts
Major Impacts on Key Water Quality Parameters	1	No Impacts
Political Feasibility	1	
Implementation Issues	1	Limited Risk

REFERENCES

